

Boiler Attendance Policy

PURPOSE

- The following policy has been developed to provide a resource for licensed engineers, owners, principals and superintendents to determine the frequency of boiler checks in schools and other locations to maintain them as safely as possible without extensive amounts of overtime and wasted man hours.
- During the heating season, this policy must be followed for boiler maintenance checks to avoid endangering human life and property. This policy takes into consideration the recommendations of the American Society of Mechanical Engineers Boiler Code Section VI, public occupancy of the building, condition of heating systems, size and capacity of the boiler plant, and severity of weather.

PROCEDURES

- **Minnesota rules**
In accordance with Minnesota Rules 5225.1110, the chief engineer or operating engineer and the division of Code Administration and Inspection Services (chief boiler inspector) will determine the minimum attendance of all boilers.
- **Normal workdays**
A properly licensed engineer must check the boiler(s) at least once each day. This check must include a visual examination of all associated equipment, and a logbook entry of the conditions observed. The requirements of this section may only be reduced by the chief engineer of the facility, or the properly licensed engineer in charge of the boilers.
- **Weekends and holidays**
When one or more of the following conditions occur, a properly licensed engineer must check the boiler(s). This check must include a visual examination of all associated equipment, and a logbook entry of the conditions observed. The requirements of this section may only be reduced by the chief engineer of the facility, or the properly licensed engineer in charge of the boilers.
 - **Severe weather:** The boiler(s) must be checked when it is forecasted that the outside air temperature will reach 10 degrees fahrenheit or colder.
 - **Safety concerns:** The boiler(s) must be checked when a situation occurs that impacts the safety of the boiler or associated equipment.
 - **Public occupancy of the building(s):** The boiler(s) must be checked if the building is, or will be, occupied by employees or the public.
 - **Minimum attendance:** No boiler will be left unattended for more than two consecutive days (48 hours).

COMMUNICATION

- The chief engineer or operating engineer must notify the supervisor if he or she believes there is justification for additional boiler checks required for unique situations regarding the safety of the boiler, building, or its occupants.
- If the chief engineer or operating engineer has found the boiler to be in an unsafe condition, the engineer must notify the owner or employer and the chief boiler inspector as soon as possible. If the unsafe boiler is not immediately taken out of service, the chief engineer or operating engineer must ensure that the boiler is continuously monitored by a properly licensed engineer, 24 hours per day, until the division has either sealed the boiler, verified the unsafe condition has been corrected, or determined that continuous monitoring is no longer required.



**Chief Boiler Inspector – Joel Amato
Construction Codes and Licensing Division
Minnesota Department of Labor and Industry**

**7/29/2014
Date**