

MINNESOTA RULES, CHAPTER 1305
ADOPTION OF THE ~~2006-2012~~ INTERNATIONAL BUILDING
CODE

Comment [PH1]: 2012 code or 2013 code ????

1305.0010 [Repealed, 27 SR 1474]

1305.0011 ADOPTION OF INTERNATIONAL BUILDING CODE BY REFERENCE AND ADMINISTRATIVE AUTHORITY.

Comment [PH2]: 2012 code or 2013 code ????

Subpart 1. **General.** For purposes of this chapter, "IBC" means the ~~2006~~ 2012 edition of the International Building Code as promulgated by the International Code Council, Falls Church, Virginia. The IBC is incorporated by reference and made part of the Minnesota State Building Code except as qualified by the applicable provisions in chapter 1300, part 1305.0021, and as amended in this chapter. Portions of this chapter reproduce text and tables from the IBC. The IBC is not subject to frequent change and a copy of the IBC, with amendments for use in Minnesota, is available in the office of the commissioner of labor and industry. The IBC is copyright ~~2006~~ 2011 by the International Code Council, Inc. All rights reserved.

Subp. 2. **Mandatory chapters.** IBC Chapters 2 through 33 and 35 must be administered by any municipality that has adopted the code, except as qualified by the applicable provisions in chapter 1300, and as amended by this chapter. Amendments to IBC Chapters 11 and 30 are incorporated by reference in this rule chapter, but the actual amendments for those chapters are located in chapters 1341, the Minnesota Accessibility Code, and 1307, the Minnesota Elevator Code, respectively. Referenced documents cited in IBC Chapters 11 and 30, and chapters 1307 and 1341, apply, unless otherwise stated or deleted. For the complete application and mandatory requirements relating to IBC Chapter 11, see chapter 1341. For the complete application and mandatory requirements relating to IBC Chapter 30, see chapter 1307.

Subp. 3. **Replacement chapters.** The following IBC chapters are deleted and replaced with the Minnesota Rules chapters listed in items A and B.

A. IBC Chapter 1 and any references to code administration are deleted and replaced with chapter 1300, Minnesota Administration Code.

B. IBC Chapter 34 and any references to conservation or rehabilitation of existing buildings are deleted and replaced with chapter 1311, Minnesota Building Conservation Code.

Subp. 4. **Seismic or earthquake provisions.** Any seismic or earthquake provisions of the IBC and any references to them are deleted and are not included in this code.

Subp. 5. **Flood hazard or floodproofing provisions.** Any flood hazard or floodproofing provisions in the IBC, and any reference to those provisions, are deleted in their entirety. Requirements for floodproofing are located in chapter 1335, Floodproofing Regulations.

1305.0020 [Repealed, 27 SR 1474]

1305.0021 REFERENCES TO OTHER INTERNATIONAL CODE COUNCIL CODES.

Subpart 1. **General.** References to other codes and standards promulgated by the International Code Council in the IBC are modified in subparts 2 to 12.

Subp. 2. **Building code.** References to the IBC in this code mean the Minnesota Building Code, adopted pursuant to this chapter and Minnesota Statutes, section ~~326B.???~~ ~~16B.61,~~ ~~subdivision 1.~~

Comment [PH3]: 5/16/12 Change to reflect new 326 Statute ?????

Subp. 3. **Residential code.** References to the International Residential Code in this code mean the Minnesota Residential Code, adopted pursuant to chapter 1309 and Minnesota Statutes, section ~~326B.???~~ ~~16B.61, subdivision 1.~~

Comment [PH4]: 5/16/12 Colleen to check reference to new 326B Statute ?????

Subp. 4. **Electrical code.** References to the International Code Council Electrical Code in this code mean the Minnesota Electrical Code, adopted pursuant to chapter 1315 and Minnesota Statutes, ~~section 326.243.~~

Comment [PH5]: 5/16/12 ??? Colleen to check Statute reference ???

Subp. 5. **Fuel gas code.** References to the International Fuel Gas Code in this code mean the Minnesota Mechanical Code, adopted pursuant to chapter 1346 and Minnesota Statutes, section ~~326B.???~~ ~~16B.61, subdivision 1.~~

Comment [PH6]: 5/16/12 ??? Colleen to check Statute reference ???

Subp. 6. **Mechanical code.** References to the International Mechanical Code in this code mean the Minnesota Mechanical Code, adopted pursuant to chapter 1346 and Minnesota Statutes, ~~326B.????~~ ~~section 16B.61, subdivision 1.~~

Comment [PH7]: 5/16/12 ??? Colleen to check reference to new Statutes ???

Subp. 7. **Plumbing code.** References to the International Plumbing Code in this code mean the Minnesota Plumbing Code, adopted pursuant to chapter 4715 and Minnesota Statutes, section ~~16B.61, subdivisions 1 and 2~~ ~~???????~~.

Comment [PH8]: 5/16/12 ??? Colleen to check reference to new Statute ???

Subp. 8. **Private sewage disposal code.** References to the International Private Sewage Disposal Code in this code mean the Minnesota Pollution Control Agency's minimum standards and criteria for individual sewage treatment systems adopted pursuant to Minnesota Rule eChapters 7080, 7081, 7082, and 7083, and Minnesota Statutes, chapters 103F, 103G, 115, and 116.

Comment [PH9]: 5/16/12 MPCA Septic Rules include all of these and must be included to be accurate

Subp. 9. **Energy conservation code.** References to the International Energy Conservation Code in this code mean the Minnesota Energy Code, adopted pursuant to Minnesota Statutes, ~~326B.???~~ ~~section 16B.617.~~

Comment [PH10]: 5/16/12 ??? Colleen to check references to new Statute ???

Subp. 10. **Property maintenance code.** References to the International Property Maintenance Code in this code do not apply.

Subp. 11. **Fire code.** References to the International Fire Code in this code mean the Minnesota State Fire Code, adopted pursuant to chapter ~~7511~~ ~~7510~~ and Minnesota Statutes, chapter 299F.

Comment [PH11]: 5/16/12 Done to reference proper Rule for SFC

Subp. 12. **International Existing Building Code.** References to the International Existing Building Code in this code mean Minnesota ~~Existing Building Code State Building Conservation Code~~, adopted pursuant to chapter 1311 and Minnesota Statutes, ~~326B.???~~ ~~section 16B.61, subdivision 1.~~

Comment [PH12]: 5/16/12 ??? Colleen to check reference new Statute ????

1305.0030 ADMINISTRATIVE PROCEDURE CRITERIA.

Procedures relating to the administration and enforcement of this code under Minnesota Statutes, section ~~326B.???~~ ~~16B.57~~, are contained in chapter 1300, Minnesota Administration Code, which governs the application of this code.

Comment [PH13]: 5/16/12 ??? Colleen to check references to new Statute ???

~~**1305.0040 VIOLATION.**~~

~~A violation of this code is a misdemeanor under Minnesota Statutes, section 16B.69.~~

Comment [GN14]: Covered in MN 1300 per Mike Godfrey

1305.0100 [Repealed, 19 SR 1340]

1305.0101 CHAPTER 1, ADMINISTRATION.

IBC Chapter 1 is deleted and replaced with the following:

CHAPTER 1
ADMINISTRATION

This code shall be administered in accordance with Minnesota Rules, chapter 1300.

1305.0102 [Repealed, 27 SR 1474]

1305.0103 [Repealed, 27 SR 1474]

1305.0105 [Repealed, 27 SR 1474]

1305.0106 [Repealed, 27 SR 1474]

1305.0107 [Repealed, 27 SR 1474]

1305.0108 [Repealed, 27 SR 1474]

1305.0109 [Repealed, 27 SR 1474]

1305.0150 [Repealed, 19 SR 1340]

1305.0200 [Repealed, 19 SR 1340]

1305.0201 SECTION 201, GENERAL.

IBC Section 201.4 is amended to read as follows:

201.4 Terms not defined. Where terms are not defined through the methods authorized by this chapter, the Merriam-Webster Collegiate Dictionary, available at www.m-w.com, shall be considered as providing ordinarily accepted meanings. The dictionary is incorporated by reference, is subject to frequent change, and is available through the Minitex interlibrary loan system.

1305.0202 SECTION 202, DEFINITIONS.

Subpart 1. **Agricultural building.** The definition of "agricultural building" in IBC Section 202 is amended as follows:

AGRICULTURAL BUILDING. Pursuant to Minnesota Statutes, ~~326B.???~~ ~~section 16B.60,~~ an agricultural building means a structure on agricultural land as defined in Minnesota Statutes, section 273.13, subdivision 23, that is designed, constructed, and used to house farm implements, livestock, or agricultural produce or products used by the owner, lessee, and sublessee of the building and members of their immediate families, their employees, and persons engaged in the pickup or delivery of agricultural products.

Comment [PH15]: 5/16/12 ????. Colleen to check new Statute reference ????

Subp. 2. **Townhouse.** The definition of "townhouse" in IBC Section 202 is ~~deleted in its entirety.~~ Amended as follows:

TOWNHOUSE. ~~A single family dwelling unit constructed in a group of three two or more attached units in which each unit extends from the foundation to the roof and having open space on at least two sides of each unit. Each single family dwelling unit shall be considered to be a separate building and shall be separated from other single family dwelling units by a fire wall, party wall or multiple fire-resistance rated exteriors walls. Separate building service utilities shall be provided to each single family dwelling unit when required by other chapters of the State Building Code.~~

Formatted: Strikethrough

Subp. 2a. **LIVE/WORK UNIT.** The definition of "Live/Work Unit" in IBC Section 202 is ~~deleted in its entirety.~~

Comment [B16]: See proposal 1305-7 on website, approved by 1305 committee.

Subp. 3. IBC Section 202 is amended by adding or replacing the following definitions:

AISLE. ~~That portion of an exit access that connects an aisle accessway to an exit access doorway, corridor, or an exit.~~

AMBULATORY CARE FACILITY. ~~Buildings or portions thereof used to provide medical, surgical, psychiatric, nursing or similar care on a less than 24-hour basis to individuals who are rendered incapable of self-preservation by the services provided. For the purposes of this provision federally certified End Stage Renal Disease (a.k.a. kidney dialysis) facilities shall not be considered ambulatory care facilities.~~

Formatted: Font: Times New Roman, Bold

Formatted: Font: Times New Roman

CORRIDOR. ~~An interior passageway having a length at least three times its width, having walls, partitions, or other obstructions to exit travel over 6 feet (1829 mm) in height on two opposing sides, and having openings from rooms or similar spaces.~~

ROOM. A space or area bounded by any obstruction over 6 feet in height which at any time encloses more than 80 percent of the perimeter of the area. In computing the unobstructed perimeter, openings less than 3 feet (914 mm) in clear width and less than 6 feet 8 inches (2032 mm) in height shall not be considered. Aisles and corridors shall not be construed to form rooms

Formatted: Indent: First line: 0"

ROOF COVERING. The covering applied to the roof deck for weather resistance, fire classification or appearance. Roof covering materials consist of two basic types: (1) roofing systems, and (2) prepared materials.

Comment [PH17]: These 4 new/revised definitions have been moved from IBC Chapter 10 (old 1305.1001) to IBC Chapter 2 due to reformatting of the code

Comment [GN18]: Relocated from individual chapters

1305.0300 [Repealed, 15 SR 74]

1305.0301 [Repealed, 27 SR 1474]

1305.0302 [Repealed, 31 SR 1165]

1305.0302 CLASSIFICATION.

IBC Section 302 is amended by adding a new section 302.2 to provide a table pertaining to care facilities as follows:

302.2. Care facilities shall be classified in accordance with the following table:

**Table 302.2
Care Facilities**

<u>Type of Licensed Facility</u>	<u>Number of Occupants</u>	<u>IBC Occupancy Classification</u>
<u>Child Care (Day Care) < 24 hours per day</u>	<u>Family Child Care Home</u>	10 occupants maximum with < 6 below school age
	<u>Group Child Care Home</u>	11-14 occupants maximum
	<u>Child Care Center</u>	>5 but <100 children < 2.5 yrs. of age & each room at, and with, an exit at the level of exit discharge
	<u>Child Care Center</u>	More than 5 children > 2.5 yrs of age
	<u>Child Care Center</u>	More than 5 children < 2.5 yrs. of age
<u>Adult Day Care < 24 hours per day</u>	<u>Family Adult Day Services</u>	< 8 impaired adults
	<u>Adult Daycare Center</u>	6 or more occupants, all may – or may not be capable of self-preservation

Formatted: Font: 11 pt

Formatted Table

Formatted: Font: 11 pt

Formatted: Font: 11 pt

	<u>Adult Daycare Center</u>	<u>6 or more occupants – but having no more than 50% of the occupants who are not capable of self-preservation</u>	<u>E</u>
<u>Supervised Living Facilities</u>	<u>Class A-1</u>	<u>6 or fewer residents – all of whom are capable of self-preservation</u>	<u>R-3</u>
	<u>Class A-2</u>	<u>7 - 16 residents – all of whom are capable of self-preservation</u>	<u>R-4</u>
	<u>Class A-2</u>	<u>More than 16 residents – all of whom are capable of self-preservation</u>	<u>I-1</u>
	<u>Class B-1</u>	<u>6 or fewer residents – all of whom may not be capable of self-preservation</u>	<u>R-3</u>
	<u>Class B-2</u>	<u>7 - 16 residents – all of whom may not be capable of self-preservation</u>	<u>R-4</u>
	<u>Class B-3</u>	<u>More than 16 residents – all of whom may not be capable of self-preservation</u>	<u>I-2</u>
<u>Hospice</u>	<u>Residential Hospice Facility</u>	<u>1 - 5 terminally ill persons</u>	<u>R-3</u>
	<u>Residential Hospice Facility</u>	<u>6 - 12 terminally ill persons</u>	<u>R-4</u>
<u>Adult Foster Care</u>	<u>Family Adult Foster Care Home</u>	<u>1 - 5 Impaired Adults</u>	<u>R-3</u>
<u>Child Foster Care</u>	<u>Foster Care</u>	<u>1-6 Foster children w/o severe disability or assisted medical technology</u>	<u>R-3</u>
	<u>Foster Care</u>	<u>1 - 4 Foster children w/medical or special care services</u>	<u>R-3</u>
<u>Housing with Services Facility</u>	<u>Housing with Services Establishment</u>	<u>1 - 5 Adults residents > 80% 55 yrs of age unless registered under 144D.025</u>	<u>R-3</u>
	<u>Housing with Services Establishment Providing Assisted Living Services</u>		

Formatted: Font: 11 pt

	<u>Housing with Services Establishment</u>	6-16 Adults residents > 80% 55 yrs of age unless registered under <u>144D.025</u>	<u>R-4</u>
	<u>Housing with Services Establishment Providing Assisted Living Services</u>		
	<u>Housing with Services Establishment</u>	> 16 Adults residents > 80% 55 yrs of age unless registered under <u>144D.025</u>	<u>I-1</u>
	<u>Housing with Services Establishment Providing Assisted Living Services</u>		
<u>Boarding Care</u>	<u>Boarding Care Home</u>	< 5 Residents	<u>R-3</u>
	<u>Boarding Care Home</u>	6-16 Residents	<u>R-4</u>
	<u>Boarding Care Home</u>	> 16 Residents	<u>I-1</u>
<u>Boarding and Lodging</u>	<u>Boarding and Lodging</u>	< 5	<u>R-3</u>
	<u>Boarding and Lodging</u>	6 or more	<u>R-2</u>
	<u>Boarding and Lodging</u>	< 30 Days or Bed & Breakfast with 6 or more guest rooms	<u>R-1</u>
	<u>Boarding and Lodging</u>	< 30 Days or Bed and Breakfast with 5 or fewer guest rooms	<u>R-3</u>
<u>Senior Housing</u>	<u>Senior Housing (See IBC 310)</u>	Under the scope of the 2006 IBC and having more than 2 dwelling units	<u>R-2</u>
	<u>Senior Housing (See IBC 310)</u>	1 or 2 family dwelling units under the scope of the 2006 IBC	<u>R-3</u>
<u>Congregate Residence</u>	<u>Congregate Residence</u>	< 16	<u>R-3</u>
	<u>Congregate Residence</u>	17 or more	<u>R-2</u>

Formatted: Font: 11 pt

1305.0305 [Repealed, 27 SR 1474]

1305.0308 INSTITUTIONAL GROUP I.

Subpart 1. Section ~~308.2308.3~~. IBC Section ~~308.2308.3~~ is amended to read as follows:

~~308.2308.3~~ **Institutional Group I-1.** This occupancy shall include buildings, structures, or portions thereof housing for more than 16 persons, who persons who reside on a 24 hour

basis, ~~who because of age, mental disability, or other reasons, live~~ in a supervised residential environment ~~and receive custodial~~that provides personal care services. The ~~persons~~occupants receiving care are capable of ~~responding to an emergency situation without physical assistance from staff~~self preservation. This group shall include, but not be limited to, the following:

~~Alcohol and drug centers~~residential board and care facilities

~~A~~assisted living facilities

~~Boarding care~~

~~Congregate care facilities~~

~~Convalescent facilities~~

~~halfway houses~~

~~G~~roup homes

~~e~~ongregate care facilities

~~Halfway houses~~

~~Housing with services~~

~~Residential board and care facilities~~

~~S~~social rehabilitation facilities

~~Supervised living facilities Class A-2~~

~~alcohol and drug centers~~

~~convalescent facilities~~

Comment [GN19]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Comment [GN20]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Comment [GN21]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Formatted: Indent: First line: 0"

~~308.3.1~~ Five or fewer persons receiving care. A facility such as the above with five or fewer persons receiving such care shall be classified as Group R-3.

~~308.3.2~~ Six to sixteen persons receiving care. A facility such as above, housing not fewer than at least six and not more than 16 persons receiving such care, shall be classified as Group R-4.

Subp. 2. **Section 308.3.** IBC Section 308.3 is amended to read as follows:

~~308.3~~308.4 **Institutional Group I-2.** This occupancy shall include buildings and structures used for medical ~~care, surgical, psychiatric, nursing, or custodial care~~ on a 24 hour basis for more than five persons who are ~~incapable~~not capable of self-preservation. This group shall include, but not be limited to, the following:

~~Foster care facilities~~

~~Detoxification facilities~~

~~H~~ospitals

~~N~~ursing homes, ~~both intermediate care facilities and skilled nursing facilities~~

~~Psychiatric~~mental hospitals

~~Supervised living facilities Class B-3~~

~~detoxification facilities~~

Comment [GN22]: Added to coordinate with DOH or DHS

Formatted: Underline

Formatted: Underline

Formatted: Indent: First line: 0"

~~308.4.1~~ Five or fewer persons receiving care. A facility such as the above with five or fewer persons receiving such care shall be classified as Group R-3.

Subp. 3. **Section ~~308.5~~308.6.** IBC Section ~~308.5~~308.6 is amended to read as follows:

~~308.5~~308.6 **Institutional Group I-4, day care facilities.** This group shall include buildings and structures occupied by more than five persons of any age who receive custodial care for fewer less than 24 hours per day by ~~persons~~individuals other than parents or guardians, relatives by

blood, marriage, or adoption, and in a place other than the home of the person cared for.—~~A facility such as the above with five or fewer persons shall be classified as Group R 3. Places of worship during religious functions are not included. This group shall include, but not limited to, the following:~~

- ~~Adult daycare center~~
- ~~Child care center~~

1305.0310 SECTION 310 RESIDENTIAL GROUP R.

IBC Section ~~310.1310~~ is amended to read as follows:

310.1 Residential Group R. Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classified as an Institutional Group I ~~or when not regulated by the International Residential Code.~~

310.2 Definitions. The following terms are defined in Chapter 2:

- ~~BOARDING HOUSE~~
- ~~CONGREGATE LIVING FACILITY~~
- ~~DORMITORY~~
- ~~GROUP HOME~~
- ~~PERSONAL CARE SERVICE~~
- ~~TRANSIENT.~~

310.3 Residential Group R-1. ~~Residential occupancies shall include the following:~~

~~R-1~~ Residential occupancies containing sleeping units where the occupants are primarily transient in nature, including:

- ~~Bed and breakfast facilities with six or more guest rooms. A facility with less than six guest rooms shall be classified as a Group R 3 occupancy~~
- ~~Boarding houses (transient) with more than 10 occupants~~
- ~~Congregate living facilities (transient) with more than 10 occupants~~
- ~~Hhotels (transient)~~
- ~~Mmotels (transient)~~
- ~~bed and breakfast facilities with six or more guest rooms. A facility with less than six guest rooms shall be classified as a Group R 3 occupancy.~~

Formatted: Indent: Left: 0.5", First line: 0"

310.4 Residential Group R-2 Residential occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

- ~~A~~apartment houses
- ~~B~~boarding houses (~~not non~~transient) with more than 16 occupants
- ~~C~~ongregate living facilities (nontransient) with more than 16 occupants
- ~~C~~onvents
- ~~D~~ormitories
- ~~F~~raternities and sororities
- ~~H~~hotels (nontransient)
- ~~L~~ive/work units
- ~~M~~onasteries
- ~~M~~motels (nontransient)
- ~~V~~acation timeshare properties

Formatted: Indent: First line: 0"

Comment [PH23]: Strike out Live work units. This was deleted by the IBC AC and through 1341 Rule

~~Congregate living facilities with 16 or fewer occupants are permitted to comply with construction that complies with the requirements for Group R-3.~~

~~310.5 Residential Group R-3 Residential occupancies where the occupants are primarily permanent in nature and not classified as R-1, R-2, R-4, or I including:~~

~~Assisted living facility~~

~~Buildings that do not contain more than two dwelling units~~

~~Boarding Care Home~~

~~Boarding houses (nontransient) with 16 or fewer occupants~~

~~Boarding houses (transient) with 10 or fewer occupants~~

~~Care adult facilities that provide accommodations for five or fewer persons receiving care of any age for less than 24 hours~~

~~child care facilities that provide accommodations for five or fewer persons of any age for less than 24 hours~~

~~Congregate living facilities (nontransient) with 16 or fewer occupants persons~~

~~Congregate living facilities (transient) with 10 or fewer occupants~~

~~Family adult foster home~~

~~Foster care~~

~~Housing with services~~

~~Residential hospice with 5 or fewer occupants~~

~~adult and child care facilities~~

~~310.5.1 Care facilities within a dwelling. Care facilities for five or fewer persons receiving care that are within a single family dwelling are permitted to comply with the International Residential Code provided an automatic sprinkler system is installed in accordance with Section 903.3.1.3 or with Section P2904 of the International Residential Code.~~

~~310.6 Residential Group R-4. This occupancy shall include buildings, structures or portions thereof for Residential occupancies shall include buildings arranged for occupancy as residential care/assisted living facilities including more than five but not more than 16 persons/occupants, excluding staff, who staff, who reside on a 24-hour basis in a supervised residential environment and receive custodial care. The person receiving care are capable of self-preservation. This group shall include, but not be limited to, the following:~~

~~Alcohol and drug centers~~

~~Boarding Care Home~~

~~Congregate care facilities~~

~~Group Homes~~

~~Halfway houses~~

~~Housing with services (including those that provide assisted living services)~~

~~Residential board and care facilities~~

~~Residential hospice with 12 or fewer occupants~~

~~Social rehabilitation facilities~~

~~Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3, except as otherwise provided for in this code.~~

Formatted: Indent: First line: 0"

Comment [GN24]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Comment [GN25]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Comment [GN26]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Indent: First line: 0"

Formatted: Indent: Left: 0"

Formatted: Strikethrough

Formatted: Indent: First line: 0"

Formatted: Font: Italic, Strikethrough

Formatted: Strikethrough

Formatted: Font: Italic, Strikethrough

Formatted: Strikethrough

Comment [B27]: ?

Formatted: Font: Italic, Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Indent: First line: 0"

Comment [GN28]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Comment [GN29]: Added to coordinate with DOH or DHS

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

Formatted: Underline, Font color: Light Blue

1305.0400 [Repealed, 19 SR 1340]

1305.0402 SECTION 402, COVERED MALL BUILDINGS.

Subpart 1. Section ~~402.4.2.2.2~~402.7. IBC Section ~~402.4.2.2~~402.7 is amended by adding a subsection to read as follows:

~~402.4.2.2.2~~~~402.7.4~~ **Property lines.** Property lines may be platted between an *anchor building* and a *covered mall building* separated in accordance with Section ~~402.7.3~~ ~~402.4.2.2~~ without requiring the construction of a party wall if there are legal agreements recorded with the deed for each of the separate properties. These recorded agreements shall require that buildings as divided by property lines be in conformance with the applicable provisions of the State Building Code, as if the buildings were a single building on a single piece of property. In addition, the agreement must state that no individual building or property owner may modify any portion of the building in any way that would not comply with the State Building Code.

- Formatted: Font: Italic
- Formatted: Font: Italic
- Formatted: Font color: Red, Strikethrough

Subp. 2. Repealed, 31 SR 1165

Subpart 3. Section 402.7.2 IBC Section 402.7.2 is amended to read as follows:

~~402.7.2~~ Smoke control. Where a *covered mall building* contains an *atrium*, a smoke control system shall be provided in accordance with Section 404.5.

- Formatted: Font: Italic
- Formatted: Font: Italic

Exception: Smoke control is not required in *covered mall buildings* where an *atrium* connects only two stories.

- Formatted: Indent: Left: 0.25"
- Formatted: Font: Italic
- Formatted: Font: Italic

~~Covered mall buildings~~ exceeding 50,000 square feet (4645 m²) in floor area, excluding *anchor buildings*, not provided with an approved smoke control system shall be provided with a post fire smoke exhaust system in accordance with Section 916.

- Formatted: Font: Italic, Font color: Custom Color(RGB(79,129,189))

~~1305.0403 SECTION 403, HIGH-RISE BUILDINGS.~~

- Formatted: Font color: Custom Color(RGB(79,129,189))

~~Subpart 1. IBC Section 403.3.2. IBC Section 403.3.2 is deleted in its entirety.~~

- Formatted: Font: Italic, Font color: Custom Color(RGB(79,129,189))

~~Subp. 2. IBC Section 403. IBC Section 403 is amended by adding a section to read as follows:~~

- Formatted: Font: Italic, Font color: Light Blue

~~403.15 Post fire smoke exhaust system.~~ A post fire smoke exhaust system in compliance with IBC Section 913 shall be provided for high rise buildings.

- Formatted: Font color: Custom Color(RGB(79,129,189))

~~1305.0403 HIGH-RISE BUILDINGS~~

Comment [PH30]: The 2012 IBC has now incorporated smoke control into the code for high-rise buildings, so this is no longer needed.

IBC Sec.403.4.8.2 is amended to read as follows:

IBC Section 403.4.8.2 Standby power loads. The following are classified as standby power loads:

- Formatted: Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

1. Power and lighting for the fire command center required by Section 403.4.6;
2. Ventilation and automatic fire detection equipment for smokeproof enclosures; and
3. Passenger elevators serving occupied floors more than 75 feet (22860 mm) above the lowest level of fire department vehicle access.

- Formatted: Font color: Light Blue
- Formatted: Font color: Light Blue
- Comment [GN31]: Wording added to elevator to qualify that it is only elevators serving the floors that qualify it as a high-rise.

1305.0404 SECTION 404, ATRIUMS.

IBC Section ~~404.5404.4~~ is amended to read as follows:

~~404.5404.4~~ **Smoke control.** A smoke control system shall be installed in accordance with Section 909.

Exception: Smoke control is not required for atriums that connect only two stories. ~~Covered mall buildings shall be provided with a post fire smoke exhaust system in accordance compliance with Section 913.~~

1305.0405 [Repealed, 27 SR 1474]

1305.0406 SECTION 406, MOTOR VEHICLE-RELATED OCCUPANCIES.

IBC Section ~~406.3~~ is amended to read as follows:

~~406.3.8 Means of egress.~~ Where persons other than parking attendants are permitted, open parking garages shall meet the means of egress requirements of Chapter 10. Where no persons other than parking attendants are permitted, there shall not be less than two 36 inch wide (914 mm) exit stairways.

IBC Section 406.4.5 is amended by adding a new exception to read as follows:

406.4.5 Floor surface. Parking surfaces shall be of concrete or similar noncombustible and nonabsorbent materials.

~~—The area of floor used for parking of automobiles or other vehicles shall be sloped to facilitate the movement of liquids to a drain or toward the main vehicle entry doorway.~~

Exceptions:

1. Asphalts parking surfaces shall be permitted at ground level.
2. Floors of Group S-2 parking garages shall not be required to have a sloped surface.
3. Normally unoccupied portions of non-public parking garages shall not be required to be nonabsorbent.

1305.0407 SECTION 407, GROUP I-2.

IBC Section 407.2.1 is amended to read as follows:

407.2.1 Spaces of unlimited area. ~~In an I-2 occupancy,~~ Spaces constructed as required for corridors shall be permitted to be open to a corridor, only where all the following criteria are met:

1. The spaces are not occupied ~~as care recipient's for patient~~ sleeping rooms, treatment rooms, ~~hazardous or~~ incidental use ~~in accordance with areas as defined in Section 509508.2 or hazardous uses.~~

Formatted: Indent: Left: 0.5"

Formatted: Strikethrough

Comment [PH32]: The 2012 IBC still does not include smoke control in two-story spaces, so the existing post smoke control system must remain in the code for these spaces. This references that system.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Indent: First line: 0.25"

Comment [PH33]: Repeal this 406.3.8 section entirely. Not needed in new IBC

Formatted: Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.44" + Indent at: 0.69"

Formatted: Underline, Font color: Red

Formatted: Underline, Font color: Red

Comment [PH34]: Language is OK. Similar amendment in IRC

Comment [GN35]: New amendment to address school bus garages, DNR or MNSCU buildings not wanting asphalt or concrete.

Formatted: Underline, Font color: Red

Formatted: Underline, Font color: Red

Comment [PH36]: 5/16/12 This amendment is revised to clarify what can be open to a corridor in an I-2. Chapter 10 will have another similar amendment that will apply to all/any occupancy.

2. The open space is protected by an automatic fire detection system installed in accordance with Section 907.

3. The corridors onto which the spaces open, in the same smoke compartment, are protected by an automatic fire detection system installed in accordance with Section 907, or the smoke compartment in which the spaces are located is equipped throughout with quick response sprinklers in accordance with Section 903.3.2.

4. The space is arranged so as not to obstruct access to the required exits.

1305.0408 SECTION 408, GROUP I-3.

~~Subpart 1. Section 408.6. IBC Section 408.6 is amended to read as follows:~~

~~**408.6 Smoke barrier.**—Occupancies in Group I-3 shall have smoke barriers complying with Section 709 to divide every story occupied by residents for sleeping, or any other story having an occupant load of more than five persons, into at least two smoke compartments.~~

~~**Exception:**—Spaces having direct exit to one of the following, provided that the locking arrangement of the doors involved complies with the requirements for doors at the smoke barrier for the use condition involved:~~

~~1. A public way.~~

~~2. A building separated from the resident housing area by a 2-hour fire resistance rated assembly or 50 feet (15,240 mm) of open space.~~

~~3. A secured yard or court having a holding space 50 feet (15,240 mm) from the housing area that provides 6 square feet (0.56 m²) or more of refuge area per occupant including residents, staff and visitors.~~

Subp. ~~2~~1. **Section 408.9408.7.** IBC Section 408 is amended by adding a subsection as follows:

~~**408.9408.7 Security Glazing.** In occupancies in Group I-3, windows and doors in 1-hour fire barriers constructed in accordance with Section 707, 2-hour fire barriers constructed in accordance with Section 707 used for horizontal exits, fire partitions constructed in accordance with Section 708 and smoke barriers constructed in accordance with Section 709 shall be permitted to have security glazing installed provided that the following conditions are met.~~

~~1. Individual panels of glazing in door assemblies shall not exceed 1296 square inches (0.84 m²).~~

~~2. The glazing shall be protected on both sides by an automatic sprinkler system. The sprinkler system shall be designed to, when actuated, wet completely the entire surface of any glazing affected by fire.~~

~~**Exception:** fire partitions or smoke barriers with ¼ inch (6.4 mm) wire glass in a security glazing assembly.~~

Comment [PH37]: Repeal Subpart 1 entirely. No longer needed in 2012 IBC. Renumber all remaining subparts.

Formatted: Indent: First line: 0.25"

Formatted: Indent: Left: 0.25"

Formatted: Indent: Left: 0.25"

Formatted: Indent: Left: 0.25"

Formatted: Font: Not Bold, Font color: Black

Formatted: Font: Not Bold, Underline, Font color: Black

Formatted: Font: Not Bold, Underline, Font color: Black

Formatted: Font: Not Bold, Font color: Black

Formatted: Font: Not Bold, Underline, Font color: Black

Formatted: Indent: Left: 0.25"

~~3. The glazing shall be in a gasketed frame and installed in such a manner that the framing system will deflect without breaking (loading) the glass before the sprinkler system operates.~~

~~4. Obstructions such as curtain rods, drapery ~~transverse~~ rods, curtains, drapes or similar materials shall not be installed between the automatic sprinklers and the glazing.~~

~~5. Security glazing in fire partitions, 1-hour fire barriers enclosing fire command center and smoke barriers shall not be limited to 25 percent of the area of the common wall with any room.~~

~~**408.9.1 Corridors.** In restraint areas of fully sprinklered detention and correction facilities, the area of glazing in one hour corridor walls is not restricted if one of the following conditions is met:~~

~~1. All glazing is approved 1/4 inch thick (6.4 mm) wired glass, has approved 1/4 inch thick (6.4 mm) wired glass in a security glazing assembly, or other approved fire tested glazing material set in steel frames; or~~

~~2. Laminated security glazing may be used if the glass is protected on both sides by a sprinkler system equipped with listed quick response sprinkler heads. The sprinkler system shall be designed to wet the surface of the glass wall when actuated.~~

~~**408.9.2 Other.** When necessary to maintain direct visual supervision by facility staff, laminated security glazing may be used in fire resistive wall and door assemblies, up to a two hour fire protection rating, if all of the following conditions are met:~~

~~1. The fire resistive wall or door assembly is not part of a required fire wall. For vertical exit enclosure, refer to Section 408.3.6;~~

~~2. The glazing is protected on both sides by a sprinkler system equipped with listed quick response sprinklers. The sprinkler system shall completely wet the entire surface of the glass wall when actuated;~~

~~3. The area of the glazing does not exceed 25 percent of the common wall of the area requiring supervision; and~~

~~4. The area of glazing in fire resistive door assemblies is limited to 1,296 square inches (0.836 m²) per light.~~

~~Subp 2. Section 408.9 Windowless buildings. For the purposes of this section, a windowless building or portion of a building is one with nonopenable or readily breakable windows, exterior doors or skylights provided in all resident areas of the exit access with an occupant load greater than 50. Windowless buildings shall be provided with an engineered smoke control system to provide a tenable environment for exiting from the smoke compartment in the area of fire origin in accordance with Section 909 for each windowless smoke compartment.~~

~~**Subp 2. Section 408.9 Windowless buildings.** For the purposes of this section, a windowless building or portion thereof, is one with non openable windows, or windows that are not readily breakable, or a building without exterior doors or skylights provided in all resident areas of the exit access with an occupant load greater than 50. Windowless buildings, or portions thereof,~~

Formatted: Font: Not Bold, Font color: Black

Formatted: Font: Not Bold, Font color: Black

Formatted: Font: Not Bold, Underline, Font color: Black

Comment [GN38]: Tried to incorporate all security glazing into one section.

Formatted: Font: Not Bold, Underline, Font color: Black

Formatted: Indent: First line: 0.25"

Formatted: Indent: First line: 0.25"

Formatted: Indent: First line: 0.25"

Comment [GN39]: New amendment to better qualify the requirement

Formatted: Font: Bold, Underline, Font color: Black

Formatted: Underline, Font color: Black

Comment [B40]: ?

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Comment [B41]: ?

Formatted: Font color: Black

Formatted: Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

shall be provided with a mechanical smoke control system that is capable of providing a tenable environment for exiting the smoke compartment in the area of fire origin in accordance with Section 909 for each windowless smoke compartment.

1305.0414 SECTION 414, HAZARDOUS MATERIALS.

Subpart 1. **Section 414.2.4.** IBC Section 414.2.4 is amended to read as follows:

414.2.4 Fire resistance rating requirements. The required fire resistance rating for fire barrier assemblies shall be in accordance with Table 414.2.2.

Subp. 2. **Section 414.2.6.** IBC Section 414.2 is amended by adding a subsection to read as follows:

414.2.6 Hazardous materials above the third floor in laboratories in Group B, E, and I 2 occupancies. Control areas containing laboratories located above the third floor in Group B, E, or I 2 occupancies may be exempt from the provisions in Sections 414.2.1 through 414.2.4 if all of the following conditions are met:

1. Buildings containing the laboratories are equipped throughout with automatic sprinkler protection installed in accordance with Section 903.3.1.1;
2. Control areas containing laboratories located above the third floor are separated from each other and other portions of the building by a fire barrier having a fire resistance rating of not less than two hours;
3. The maximum amount of hazardous materials in storage and in use in control areas containing laboratories does not exceed ten percent of the maximum allowable quantities listed in Tables 307.1(1) and 307.1(2) with all increases allowed in the footnotes of those tables; and
4. The maximum number of control areas containing laboratories shall not exceed 5 per floor.

1305.0419 [Repealed, 31 SR 1165]

1305.0419, IBC Section 419 Live/Work Units

IBC Section 419 Live/Work Units is deleted in it's entirety

~~1305.0421~~1305.0425 SECTION ~~421~~425, GROUP E OCCUPANCIES.

IBC Chapter 4 is amended by adding a section and subsections to read as follows:

SECTION ~~421~~425

GROUP E OCCUPANCIES

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Comment [GN42]: New amendment to better qualify the requirement for what a windowless building or portion thereof is defined as.

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Comment [PH43]: 5/16/12 This section is a carryover of existing amendments to the limitations and quantities of hazardous materials in a building. No change from existing Rule proposed.

Comment [PH44]: 5/16/12 Section 419 of the code must be completely deleted for coordination purposes with the updated 1341 Rule.

| **421.1425.1 Applicability.** This section applies to Group E school buildings containing uses described in this section. School buildings shall comply with this section and all other applicable provisions of this code, as intended by Minnesota Statutes, section 123B.51, subdivision 7.

| **421.2425.2 Use of school buildings by lower grades.** In addition to the occupancy and construction requirements in this code, this section applies to those special uses and occupancies described in this section.

| **421.2.1425.2.1 School buildings equipped with complete automatic fire sprinkler and fire alarm systems.** Rooms used by preschool, kindergarten, and first and second grade students for classrooms, latchkey, day care, early childhood family education, teen parent, or similar programs may be located on any floor level below the fourth story if the following conditions exist:

1. The building is protected throughout with an approved automatic fire sprinkler system; and
2. The building is protected throughout with an approved automatic fire alarm system having automatic smoke detection devices installed throughout the exit system within every room or area used for purposes other than a classroom or office.

| **421.2.2425.2.2 School buildings equipped with either a complete automatic fire sprinkler system or a fire alarm system.** Rooms shall be located on the story of exit discharge when used for the purposes of classroom, latchkey, day care, early childhood education, teen parent, or similar programs by preschool, kindergarten, or first grade students. Rooms shall be located on the story of exit discharge or one story above when used for any purpose by second grade students.

Rooms occupied by preschool, kindergarten, first, or second grade students, when used for the programs described in this section, may be located on floor levels other than those designated above if one of the following conditions is met:

1. An approved automatic fire sprinkler system is provided throughout the building and the use of the affected room or space is limited to one grade level at a time and exiting is provided from the room or space which is independent from the exiting system used by older students; or
2. A complete approved automatic fire alarm system is installed throughout the building consisting of automatic smoke detection installed throughout the exit system and within all rooms and areas other than classroom and office areas, and the use of the affected room or space is limited to one grade level at a time, and exiting is provided from the room or space which is independent from the exiting system used by older students.

For the purposes of this subpart, pupils from the second grade down are considered one grade level.

| **421.2.3425.2.3 Accessory spaces.** Accessory spaces, including spaces used for gymnasiums, cafeterias, media centers, auditoriums, libraries, and band and choir rooms, used on an occasional basis by preschool, kindergarten, first, and second grade students are permitted to be

located one level above or one level below the story of exit discharge, if the building is protected throughout by an approved automatic sprinkler system or a complete approved corridor smoke detection system.

1305.0500 [Repealed, 19 SR 1340]

1305.0501 SECTION 501, GENERAL.

IBC Section 501.1 is amended to read as follows:

501.1 Scope. The provisions of this chapter control the height and area of structures hereafter erected and additions to existing structures. An existing building plus additions shall comply with the height and area provisions of this chapter.

1305.0507 SECTION 507, UNLIMITED AREA BUILDINGS.

Subpart 1. **IBC Section 507.2.** IBC Section 507.2 is amended to read as follows:

507.2 Nonsprinklered, one story. The area of a one story building of Group F 2 or S 2 occupancy shall not be limited when the building is surrounded and adjoined by public ways or yards not less than 60 feet (18,288 mm) in width.

Subp. 2. **IBC Section 507.3.** The exceptions listed in IBC Section 507.3 are not amended. The first sentence of IBC Section 507.3 is amended to read as follows:

507.3 Sprinklered, one story. The area of a one story above grade plane building of Group B, F, M, or S occupancy or a one story above grade plane Group A 4 building, of other than Type V construction, shall not be limited when the building is provided with an automatic sprinkler system throughout in accordance with Section 903.3.1.1 and is surrounded and adjoined by public ways or yards not less than 60 feet (18,288 mm) in width.

Subp. 3. **IBC Section 507.4.** IBC Section 507.4 is amended to read as follows:

507.4 Two story. The area of a two story above grade plane building of Group B, F, M, or S occupancy shall not be limited when the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, and is surrounded and adjoined by public ways or yards not less than 60 feet (18,288 mm) in width.

Subp. 4. **IBC Section 507.5.** IBC Section 507.5 is amended by adding a subsection to read as follows:

507.5.1 Property lines. Portions of an unlimited area building may be divided by platted property lines without requiring the construction of party walls if the whole building has:

1. Permanent open space on all sides as required by Section 507.2, 507.3, 507.4, or 507.5; and

2. Proper legal agreements recorded with the deed for each of the separate properties. These recorded agreements shall require that the buildings as divided by property lines, be in conformance with the applicable provisions of the Minnesota State Building Code, as if the buildings were a single building on a single piece of property. In addition, the agreement must state that no individual building or property owner may modify any portion of the building in any way that would not be in compliance with the Minnesota State Building Code.

1305.0508 MIXED USE AND OCCUPANCY

IBC Section 508.1 is amended to read as follows:

508.1 General. Each portion of a building shall be individually classified in accordance with Section 302.1. Where a building contains more than one occupancy group, the building or portion thereof shall comply with the applicable provisions of Section 508.2, 508.3 or 508.4, or a combination of these sections.

Exceptions:

1. Occupancies separated in accordance with Section 510.
2. Where required by Table 415.5.2, areas of Group H-1, H-2 and H-3 occupancies shall be located in a *detached building or structure*.
3. ~~Uses within live/work units, complying with Section 419, are not considered separate occupancies.~~

Comment [B45]: See Proposal 1305-7 on website, approved by 1305 Committee.

1305.0600 [Repealed, 19 SR 1340]

1305.0603 SECTION 603 COMBUSTIBLE MATERIALS IN TYPE I AND II CONSTRUCTION

IBC Section 603.1 is amended by adding an item to the numerical list as follows:

26. Wood used in roof construction for equipment support, building or roof system joints, skylight or mechanical equipment curbs, cants, miscellaneous blocking and backing, and for parapet or roof edge construction when not exceeding 24-inches in height above the roof deck.

Comment [GN46]: Needed to address current policy permitted by DLI Plan Review.

1305.0700 [Repealed, 19 SR 1340]

1305.0704 [Repealed, 31 SR 1165]

1305.0707 [Repealed, 31 SR 1165]

1305.0714 [Repealed, 31 SR 1165]

1305.0716 1305.0717 SECTION 716 717, DUCTS AND AIR TRANSFER OPENINGS.

IBC Section ~~716.5.3~~717.5.3 is amended by adding exception 56 as follows:

56. Fire dampers, smoke dampers, and combination fire/smoke dampers are not required in laboratory hood exhaust duct penetrations of shaft enclosures where laboratory ventilation systems are installed in accordance with NFPA 45.

Comment [PH47]: Need to coordinate NFPA 45 requirement with updated 1346 Rule. Make sure proper standard is referenced in both Rules.

1305.0717.6.1 Through penetrations, is amended to read as follows:

IBC Sec. 717.6.1 Through penetrations. In occupancies other than Group I-2 and I-3, a duct constructed of *approved* materials in accordance with the *International Mechanical Code* that penetrates a fire-resistance-rated **floor or** floor/ceiling assembly that connects not more than two *stories* is permitted without a shaft enclosure protection, provided a *listed fire damper* is installed at the floor line or the duct is protected in accordance with Section 714.4. For air transfer openings, see Section 712.1.8.

Exception: 1. A duct is permitted to penetrate three floors or less without a *fire damper* at each floor, provided such duct meets all of the following requirements:

~~a.1.~~ The duct shall be contained and located within the cavity of a wall and shall be constructed of steel having a minimum wall thickness of 0.0187 inches (0.4712 mm) (No. 26 gage).

~~b.2.~~ The duct shall open into only one *dwelling* or *sleeping unit* and the duct system shall be continuous from the unit to the exterior of the building.

~~c.3.~~ The duct shall not exceed 4-inch (102 mm) nominal diameter and the total area of such **ducts** shall not exceed 100 square inches (0.065 m²) in any 100 square feet (9.3 m²) of floor area.

~~d.4.~~ The *annular space* around the duct is protected with materials that prevent the passage of flame and hot gases sufficient to ignite cotton waste where subjected to ASTM E 119 or UL 263 time temperature conditions under a minimum positive pressure differential of 0.01 inch (2.49 Pa) of water at the location of the penetration for the time period equivalent to the *fire-resistance rating* of the construction penetrated.

~~e.5.~~ Grille openings located in a ceiling of a fire-resistance-rated floor/ceiling or roof/ceiling assembly shall be protected with a *listed ceiling radiation damper* installed in accordance with Section 717.6.2.1.

2. In Group I-2 and I-3 occupancies, a duct constructed of *approved* materials in accordance with the *International Mechanical Code* that penetrates a fire-resistance-rated floor or floor/ceiling assembly that connects not more than two *stories* is permitted without a shaft enclosure protection, provided a *listed smoke/fire damper* is installed at the floor line.

Comment [PH48]: 5/18/12 This new amendment was approved by the IBC Advisory Committee

1305.0800 [Repealed, 19 SR 1340]

1305.0900 [Repealed, 19 SR 1340]

1305.0901 SECTION 901, GENERAL

1305.0901, IBC Section 901.6.2, **Fire alarm systems**, is amended by deleting the section in its entirety.

Comment [PH49]: ALL CHAPTER 9 PROVISIONS MUST BE COPIED/DUPLICATED IN AND FROM MN RULE 7511 – IN THEIR CHAPTER 9 PROVISIONS. THEY MUST ALL BE EXACTLY THE SAME !!!

Comment [PH50]: CHECK rule number formatting. None of this is correct !!!!!

Comment [PH51]: Only change was that I added the title of the section for more clarity.

1305.0903 F SECTION 903, AUTOMATIC SPRINKLER SYSTEMS.

Subpart 1. **Scope.** IBC F Section 903.2.7 is amended as follows.

Comment [PH52]: Is this formatted properly ???

Subpart 1. **Repealed, 31 SR 1165**

~~Subp. 1a. **F Section 903.2.7.** IBC F Section 903.2.7 is amended to read as follows:~~

Comment [PH53]: This 1305.0903.7 amendment is to be deleted entirely. The new IBC now requires all group R occupancies to be fully sprinkled, so this is no longer necessary.

~~903.2.7 Group R. An automatic sprinkler system installed in accordance with Section 903.3.1 shall be provided throughout all buildings containing a Group R occupancy where one of the following conditions exists:~~

~~1. The combined area on all floors, including mezzanines, exceeds 9,250 square feet (859.3 m²); or~~

~~2. The Group R fire area is located more than three stories above grade plane.~~

Exceptions:

~~1. Group R-3 single dwelling unit buildings.~~

~~2. Group R-3 or R-4 occupancies containing a facility licensed by the state of Minnesota shall be provided with a fire suppression system as required by the applicable licensing provision or this section, whichever is more restrictive.~~

~~3. Attached garages need not be sprinklered throughout if a dry sprinkler is installed within 5 feet (1524 mm) of the door opening between the garage and attached residence.~~

~~For the purposes of this section, fire walls, party walls, or attached multiple fire resistive exterior walls shall not constitute separate buildings.~~

~~Exception: Fire walls, party walls, or attached multiple fire resistive exterior walls separating other occupancies not accessory to the Group R.~~

~~Subp. 1b. F Section 903.2.12.1. IBC F Section 903.2.12.1 is amended to read:~~

Subpart 2. IBC F Section 903.3.1 is amended as follows:

903.3.1 Standards. Sprinkler systems shall be designed and installed in accordance with Section 903.3.1.1 unless otherwise permitted by Sections 903.3.1.2 and 903.3.1.3 and other chapters of this code, as applicable.

Automatic sprinkler systems installed in state licensed or registered facilities shall be installed in accordance with this code and by the appropriate licensing or registration provisions of the State of Minnesota.

Subpart 2. IBC F Section 903.2.8 Group R is amended by adding a section as follows:

903.2.8 Group R. An automatic sprinkler system installed in accordance with 903.3 shall be provided throughout all buildings with a Group R fire area.

Exceptions:

Comment [PH54]: This section is being added to cover other applicable standards for sprinkling that are or may be mandated by state statute or other state Rules. This section should also be duplicated in the 7511 Rule, the 1311 Rule and the 1305 Rule.

Formatted: Font: Bold, Underline

Formatted: Font: Not Bold, Underline

Comment [GN55]: ???????

1. Detached single-family dwelling less than 4,500 square feet of building area, excluding garages. For the purposes of this section a detached single-family dwelling shall have a minimum fire separation distance of 3 feet.
2. An automatic residential fire sprinkler system shall not be required ~~for~~ if additions or alterations are made to existing buildings that do not have ~~are not already provided with an automatic residential sprinkler system installed.~~

Formatted: Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Comment [GN56]: Inserted per IRC language with some editing and the addition of what constitutes "detached", also think that the 2nd exception belongs in 1311.

903.2.8.1 Group R-3 or R-4 congregate residences. An automatic sprinkler system installed in accordance with Section 903.3.1.3 shall be permitted in Group R-3 or R-4 congregate residences with 16 or fewer residents.

903.2.8.2 State licensed facilities. Group R-3 or R-4 occupancies ~~Single family, two family, and townhouse building~~ containing licensed facilities licensed by the State of Minnesota shall be provided with ~~a fire suppression~~ an automatic sprinkler system as required by the applicable licensing provisions or this section, whichever is more restrictive.

Formatted: Font: Not Bold

Formatted: Strikethrough

Comment [GN57]: Insert per IRC language except switched to more generic "R-3 or R-4."

~~903.2.8.2 Care facilities. An automatic sprinkler system installed in accordance with Section 903.3.1.3 shall be permitted in care facilities with 5 or fewer individuals in a single family dwelling.~~

Formatted: Strikethrough

1305.0903.2.8.3 Residential hospice facilities. An automatic sprinkler system installed in accordance with NFPA 13 shall be provided throughout all buildings with a Group R-3 or Group R-4 fire area containing a residential hospice facility.

Exception: An automatic sprinkler system installed in accordance with Section 903.3.1.2 or 903.3.1.3 shall be allowed, provided that all habitable spaces and closets are sprinklered.

Comment [PH58]: This is a new section added to 1305. It coordinates additional licensing requirements of MDH with and into the IBC.

Subpart 3. IBC F Section 903.2.11.1.3 Basements is amended to read as follows:

Comment [GN59]: This hopefully can go away with the new group R requirement.

1305.0903.2.11.1.3 Basements. Where any portion of the basement is located more than 75 feet (22 860 mm) from openings required by Section 903.2.11.1, the basement shall be equipped throughout with an approved automatic sprinkler system.

Comment [KJM60]: Deleted wall, partitions and obstructions

Comment [PH61]: This new amendment will be added to the IBC as 1305.0903.2.11.1.3 to coordinate with the SFC

Subpart 4. IBC F 903.2.11.4 Ducts conveying hazardous materials is amended as follows:

1305.0903.2.11.4 Ducts conveying hazardous materials. Fire protection for exhaust systems. Where required by the International Mechanical Code, automatic sprinklers shall be provided in ducts conveying flammable or combustible components or having the potential for combustible residue build-up on the inside. Where sprinkler protection is installed, means shall be provided to prevent water accumulation in the duct or the flow of water back to a process where the application or water constitutes a serious life or fire hazard.

Exception: Ducts where the largest cross-section diameter of the duct is less than 75 square inches (480 cm)

Comment [PH62]: This section is being added to coordinate w/the SFC and due to reorganization of the 2012 IBC. The existing 1305.0903.2.12.1 amendment (below) can now also be deleted due to this reorganization and codification.

~~903.2.12.1 Fire protection for exhaust systems. Any portion of an exhaust system utilizing combustible components or having the potential for combustible residue build up on the inside or~~

~~where required by other sections of this code, where the duct cross-sectional area is greater than or equal to 75 square inches (480 cm²), shall be provided with an automatic extinguishing system within the duct and at the duct intake, hood, enclosure, or canopy, or shall be constructed of material listed for use without sprinkler protection. When sprinkler protection is installed, means shall be provided to prevent water accumulation in the duct or the flow of water back to a process where the application of water constitutes a serious life or fire hazard.~~

Comment [PH63]: Delete this 1305 amendment due to reorganization of the 2012 IBC and for coordination with the SFC.

Subp. 2. Repealed, 31 SR 1165

Subp. 3. Repealed, 31 SR 1165

Subp. 3a. F Section 903.3.1.2.1. IBC F Section 903.3.1.2.1 is amended to read as follows:

903.3.1.2.1 Protection of decks and balconies. Decks and balconies greater than 6 feet (1.8 m) above grade, greater than 4 feet (1.2 m) deep, and with an area greater than 40 square feet (3.72 m²) attached to new Group R 1 and R 2 occupancy buildings protected in accordance with Section 903.3.1.2 that are three or more stories in height and with 30 or more units shall be protected with sprinklers under the balcony or deck framing and under attic eaves when both of the following two conditions exist:

1. The building has an unsprinklered attic; and
2. The building has combustible siding.

Subp. 4. F Section 903.3.1. IBC F Section 903.3.1 is amended by adding a section to read as follows:

903.3.1.3 NFPA 13D sprinkler systems. Automatic sprinkler systems installed in one- and two-family dwellings, townhouses, and in Group R-3 and R-4 congregate residences shall be installed throughout in accordance with NFPA 13D, Section P2904 of the 2012 IRC, or other approved equivalent sprinkler system, and the following:

Formatted: Font: Bold, Underline

Comment [PH64]: This new group R language was added 10/3/12 and essentially duplicates Rich L's language that was approved on 10/2/12 by the commish.

Attached garages are required to have one dry head sprinkler, located within five lineal feet of each door installed in the common wall separating the dwelling unit and the attached garage.

Attached covered patios, covered decks, covered porches, and similar structures are required to have automatic sprinklers with a minimum of one dry head for every 20 lineal feet of common wall between the dwelling unit and the covered patios, covered decks, covered porches, and similar structures.

Exception: Attached roofs of covered patios, covered decks, covered porches, and similar structures that do not exceed 40 square feet of floor area.

~~Automatic sprinkler systems installed in one and two family dwellings, Group R 3 and R 4 congregate residences and townhouses shall be permitted to be installed throughout in accordance with NFPA 13D and the following:~~

Formatted: Strikethrough

Comment [PH65]: Do not use this language (stricken). Use the above language that was modeled after Rich L's rev 11 dated 10/2/12.

Formatted: Strikethrough

~~Attached garages are required to have automatic sprinklers with a minimum of one dry head sprinkler, located within five lineal feet of each door installed in the common wall separating the dwelling unit and the attached garage.~~

Formatted: Strikethrough

~~Attached covered patios, covered decks, covered porches, and similar structures are required to have automatic sprinklers with a minimum of one dry head for every 20 lineal feet of common wall between the dwelling unit and the covered patios, covered decks, covered porches, and similar structures.~~

Exception:

~~Attached roofs of covered patios, covered decks, covered porches, and similar structures that do not exceed 40 square feet of floor area.~~

Comment [GN66]: Inserted perIRC language

903.3.1.4 Buildings of undetermined use. When fire sprinkler systems are required in buildings of undetermined use, they shall be designed and installed to have a sprinkler density of not less than that required for an Ordinary Hazard Group 2 use with a minimum design area of 3,000 square feet (279 m²). Use is considered undetermined if not specified at the time a permit is issued. Where a subsequent occupancy requires a system with greater capability, it shall be the responsibility of the owner to upgrade the system to the required density for the new hazard, use or occupancy.

Comment [PH67]: No change to the existing amendment except that this is supposed to all be one paragraph, not broken sentences. Reformat existing Rule as required. This now duplicates the SFC

Subp. 5. **F Section 903.3.1.** IBC F Section 903.3.1 is amended by adding a subsection to read as follows:

903.3.1.5 Special sprinkler design criteria. When fire sprinkler systems are required in areas containing the following uses, they shall be designed and installed to have a sprinkler density of not less than that required for an Ordinary Hazard Group 2 use:

1. Chemistry labs; or
2. Wrestling rooms or gymnastic rooms.

Subp. 5a. **F Section 903.3.1 Standards,** IBC F Section 903.3.1 is amended by adding the following subsections to read as follows:

903.3.1.6 903.3.1.4 Modifications to sprinkler standards. The sprinkler installation standards as referenced in Sections 903.3.1.1, 903.3.1.2, and 903.3.1.3 are modified as follows:

Comment [PH68]: Renumbered and clarification required for all to fit into the 2012 IBC code properly. These are/were existing amendments, but needed to be renumbered for codification purposes only.

903.3.1.6.1 903.3.1.4.1 Hose stream requirements. When, in the opinion of the fire chief, an adequate alternate water supply for hose stream requirements is provided or available, the water supply requirements for the sprinkler system hose stream demands may be modified.

Comment [PH69]: Renumbered to fit into 2012 IBC

Comment [PH70R69]:

Comment [PH71R70]:

903.3.1.6.2 903.3.1.4.2 Elevator shafts and equipment. Sprinkler protection shall not be installed in elevator shafts, elevator pits, or elevator machine rooms.

Comment [PH72]: Check Rule formatting here. The swimming pool section should've been a separate section as shown below. Formatting issue ?? This should be the same as the SFC Rule 7511.

EXCEPTION: Health care occupancies that are licensed by the Minnesota Department of Health and/or participate in Title XVIII (Medicare) and/or Title XIX (Medicaid) of the Social Security Act.

Comment [PH73]: This exception added to coordinate rule and regulation requirements w/SFM and MDH – as well as Federal regs for licensed facilities – which do require sprinklers in elevator shafts, pits and machine rooms for licensing and certification (regardless of state Rules).

903.3.1.6.3 903.3.1.4.3 Swimming pools. Sprinkler protection need not be provided on the ceiling of rooms containing swimming pools when the pool area is used exclusively for swimming purposes and when sprinklers are provided around the perimeter of the pool area.

903.3.1.4.4 Vestibules: Sprinkler protection is not required in vestibules that meet all of the following conditions:

1. The vestibule is 225 square feet or less in floor area.
2. The vestibule is of non-combustible or limited combustible construction.
3. The vestibule has glazing allowing vision into vestibule.
4. The vestibule's only purpose is ingress and egress.
5. The vestibule contains no fueled equipment, flammable or combustible liquids, or furniture. Incidental combustible storage in the vestibule is limited to 5 cubic feet of material.

903.3.1.6.4 903.3.1.5 NFPA 13 modifications. Sections 8.15.8.2 and 8.17.2.5 8.6.4.1.4.2, 8.6.4.1.4.3, 8.14.8.2, and 8.16.2.5 of NFPA 13 are amended revised to read as follows:

~~**8.6.4.1.4.2 Combustible spaces; installation near peak.** Sprinklers under a roof or ceiling in combustible concealed spaces of wood joist or wood truss construction with members 3 feet (0.9 m) or less on center and a slope having a pitch of four in 12 or greater shall be installed so that a row of sprinklers is installed within 12 inches (305 mm) horizontally of the peak and 12 inches (25.4 305 mm) down from the bottom of the top chord member.~~

~~**8.6.4.1.4.3 Combustible spaces; installation along eave.** Sprinklers under a roof or ceiling in combustible concealed spaces of wood joist or wood truss construction with members 3 feet (0.9 m) or less on center and a slope having a pitch of four in 12 or greater shall be installed so that the sprinklers installed along the eave are located not less than 5 feet (1.5 m) from the intersection of the truss chords.~~

~~**8.14.8.2 8.15.8.2 Linen closets and pantries.** Sprinklers are not required in linen closets and pantries within dwelling units that meet the following conditions:~~

1. The area of the space does not exceed 12 square feet (1.1 m²).
2. The least dimension does not exceed 3 feet (0.9 m).
3. The walls and materials are surfaced with noncombustible or limited combustible materials.
4. The closet or pantry contains no mechanical equipment, electrical equipment, or electrical appliances.

~~**8.16.2.5 8.17.2.5 Valves.**~~

~~**8.16.2.5.1 8.17.2.5.1 Fire department connection.** A listed check valve shall be installed in each fire department connection.~~

Formatted: Font: (Default) Times New Roman

Formatted: Indent: Left: 0"

Comment [KJM74]: Added exception. Freezing problem.

9/14/12 PRH – added this new provision per Kevin M./SFM modification to rule.

Formatted: Font: 12 pt

Formatted: Font: (Default) Times New Roman

Formatted: Font: (Default) Times New Roman, 12 pt

Formatted: Font: 12 pt

Comment [PH75]: Due to NFPA 13 updates, these section numbers and references must be changed to coordinate properly.

Comment [PH76]: Delete this provision. It has now been incorporated into the 2010 edition of NFPA 13, so it is no longer needed in 1305 or 7511.

Comment [PH77]: Delete this provision. It has now been incorporated into the 2012 edition of NFPA 13, so it is no longer needed in 1305 or 7511.

Comment [PH78]: This existing amendment must be renumbered as follows to coordinate with NFPA 13 and MN Rule 7511.

Comment [PH79]: Renumber all to coordinate w/7511 and new IBC.

8.16.2.5.1.1 8.17.2.5.1.1 Maximum pipe length. There shall be a maximum of 25 feet (7.6 m) of pipe between the check valve and the fire department connection inlet.

Exception: This maximum shall not apply to the check valve serving a free standing fire department connection.

8.16.2.5.1.2 8.17.2.5.1.2 Check valve location. The check valve shall be located to minimize freezing potential.

Subp. 6. Repealed, 31 SR 1165

Subp. 6a. **F Section 903.3.7** IBC F Section 903.3.7 is amended by adding a subsection to read as follows:

903.3.7 Sprinkler system design pressure safety margin. For new sprinkler systems or additions to existing sprinkler systems, the available water supply shall exceed the sprinkler system demand, including hose stream requirements, by 5 psi (0.34 bars) or more **from the lowest seasonal adjusted pressure.**

Subp. 7. **F Section 903.4.** IBC F Section 903.4 is amended by adding ~~an~~ exception **number 8** to read as follows:

8. For existing sprinkler systems, monitoring is required when the number of sprinklers is 100 or more.

Subp. 8. **F Section 903.4.** IBC F Section 903.4 is amended by adding a section to read as follows:

903.4.4 Valve security. All valves controlling water supplies for automatic sprinklers shall be locked or secured in the open position.

Exception: Valves located in a room or space when access is limited to essential personnel only.

1305.0904 [Repealed, 27 SR 1474]

1305.0905 F SECTION 905, STANDPIPE SYSTEMS.

Subpart 1. **F Section 905.2.** IBC F Section 905.2 is amended by adding a subsection to read as follows:

905.2.1 Modification to standards. In buildings other than high rise that are protected throughout by an automatic sprinkler system installed in accordance with Sections 903.3.1.1 and 903.3.1.2, a Class I or III standpipe system need only meet the pressure requirements for the sprinkler system when such systems comply with Sections 905.2.1.1 through 905.2.1.5:

905.2.1.1 Municipal water supply. A municipal water supply capable of supplying the required standpipe flow rate with a residual pressure not less than 20 psi (1.4 bars) through a fire hydrant

Comment [PH80]: Check proper 1305 number formatting ??? Subparts ???

Comment [PH81]: Language added to coordinate with 7511.

Comment [PH82]: SFM modified existing language for clarification purposes. No real change, but this duplicates the 7511 rule.

shall be provided. A fire hydrant shall be located within 300 feet (91 m) of the building's fire department connection.

905.2.1.2 System testing and pipe size. The standpipe system shall be able to provide the pressure and flow rate required by NFPA 14 when the standpipe system is supported by local fire department apparatus through the fire department connection as verified with hydraulic calculations. The hydraulic calculations are to be performed between the hydraulically most demanding standpipe hose connection and the fire department connection. Pipe sizes shall not be less than the minimum requirements in NFPA 14.

905.2.1.3 Design pressure. A maximum design pressure of 150 psi (10.3 bars) is permitted at the fire department connection when the standpipe is supported by local fire department apparatus.

905.2.1.4 Hose connection. At least one 2 1/2 inch (64 mm) hose connection shall be provided on the exterior of the building at the fire department connection for each 250 gpm (980 L/min) of required standpipe flow.

905.2.1.5 Automatic sprinkler system demand. The automatic sprinkler system demand, including the inside hose stream demand from NFPA 13, is to be provided by the municipal water supply system without requiring fire department pumping into the system.

Subp. 2. **F Section 905.3.2.** IBC F Section 905.3.2 is amended by adding a section to read as follows:

905.3.2.1 Group A exhibition. Class III automatic standpipes shall be provided in Group A 3 Occupancies where the floor area used for exhibition exceeds 12,000 square feet (1115 m²).

Subp. 3. **F Section 905.3.4.** IBC F Sections 905.3.4 and 905.3.4.1 are amended by deleting the sections in their entirety.

Subp. 4. **Repealed, 31 SR 1165**

Subp. 5. **Repealed, 31 SR 1165**

Subp. 6. **F Section 905.3.8.** IBC F Section 905.3 is amended by adding a subsection to read as follows:

905.3.8 905.3.9 Detention and correctional facilities. Regardless of the height of the building or number of stories, every building in a Group I 3 detention and correctional facility, where 50 or more persons are under restraint or security under Occupancy Condition 3, 4 or 5, shall be provided with a Class III automatic wet or semiautomatic dry standpipe system.

Exception: Combined systems meeting the provisions of Section 905.2 may be used.

When acceptable to the fire chief, fire department connections may be located inside all security walls or fences on the property.

Comment [PH83]: Changed section number for proper codification only.

Standpipes shall be located in accordance with Section 905. In addition, standpipes shall be located so that it will not be necessary to extend hose lines through smoke barriers. When located in cell complexes, standpipes may be located in secured pipe chases.

Subp. 6a. **F Section 905.3.9.** IBC F Section 905.3 is amended by adding a subsection to read as follows:

905.3.9 905.3.10 Group R 2 occupancies. Convenience overhaul hose connections. Convenience hose connections are not intended to serve as standpipes in accordance with NFPA 14. Class III wet standpipes shall be installed in Group R 2 occupancies three or more stories in height where any portion of the building's interior area is more than 200 feet (60,960 mm) of travel, vertically or horizontally, from the nearest point of fire department vehicle access. Standpipes required by this section shall be installed in enclosed stairways.

Comment [PH84]: Modified existing amendment to duplicate new 7511 amendment.

In buildings provided with a birdcage design fire sprinkler system, separate standpipes are required with fire department valves on each floor. In buildings utilizing a combined sprinkler/standpipe system, fire department valves are required. Minimum standpipe size shall be not less than 2 ½ inches.

Permanent signage shall be required which reads, "Fire Department Overhaul Hose Connection" at each connection in the building. If a separate standpipe system is provided, a sign shall also be provided at the exterior FD connection.

Subp. 7. **F Section 905.5.1.** IBC F Section 905.5.1 is deleted.

1305.0906 F SECTION 906, Portable Fire Extinguishers.

Comment [PH85]: All new section to 1305 Rule – copied from 7511. Old IBC never had this section in the code. This is for codification purposes between 1305 and 7511.

Subpart 1. **F Section 906.1** IBC Section 906.1 is amended to read:

906.1 Where required. Portable fire extinguishers shall be installed in the following locations:

Comment [KJM86]: Changes recommended by the chapter 9 committee. Deleted 13-R systems, changed janitor to custodial and added size to the storage room requirement

1. In all Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies.

Exception: In all Group A, B and E occupancies equipped throughout with an approved automatic sprinkler system installed in accordance with Sections 903.3.1.1 portable fire extinguishers shall be required only in laundry rooms, boiler and furnace rooms, mechanical and electrical rooms, garages, stages, projection booths, shops, laboratories, kitchens, locker rooms, custodial closets, trash-collection rooms, storage rooms greater than 100 square feet and similar areas.

2. Within 30 feet (9144 mm) of commercial cooking equipment.

3. In areas where flammable or combustible liquids are stored, used or dispensed.

4. Except in Group R-3 occupancies, a portable fire extinguisher shall be located in accordance with Section 3309 while buildings are under construction.

Comment [PH87]: Modified SFM wording. This exempts the requirements from single family code and then references provision from IBC where it is regulated.

5. Where required by the sections indicated in Table 906.1.

~~6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.~~

Comment [PH88]: In the IBC, the work fire must be stricken so the BO is capable of administering this as well.

~~7. R-3 occupancies used as family day care, group family day care, foster care, adult family day services and residential hospices.~~

Comment [KJM89]:

1305.0907 F SECTION 907, FIRE ALARM AND DETECTION SYSTEMS.

~~Subpart 1. **F Section 907.1.3.** IBC F Section 907.1 is amended by adding a subsection to read as follows:~~

Comment [PH90]: 1305.0907, Subpart 1 deleted entirely. This section also deleted entirely by SFM. This coordinates 7511 with 1305. Delete 907.1.3 entirely.

~~**907.1.3 Protection of control units.** In areas that are not continuously occupied, automatic fire detection shall be provided at the location of each new fire alarm control unit, fire alarm notification circuit power extender, and supervising station transmitting equipment to provide notification of fire at that location.~~

~~**Exception:** Additional detection is not required in buildings sprinklered in accordance with Section 903.3.1.1 or 903.3.1.2.~~

~~Subp. 1a. **F Section 907.2.** IBC F Section 907.2 is amended to read as follows:~~

Comment [PH91]: Renumber subpart as required. ???

~~**907.2 Where required in new buildings and occupancies.** An approved manual, automatic, or manual and automatic fire alarm system shall be provided in new buildings and occupancies in accordance with Sections 907.2.1 through 907.2.24 and NFPA 72. For the purposes of Sections 907.2.1 through 907.2.24, fire barrier walls or fire walls shall not define separate buildings. In buildings containing mixed occupancies that are designed as separated uses in accordance with Section ~~508.3.3~~ **508.4**, fire alarm and detection systems need only be installed in those occupancies where required by this section.~~

Comment [PH92]: Renumbered for new IBC codification.

~~**Exception:** In areas protected by an approved, supervised automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, automatic fire detectors required by Section 907.2 need not be provided. Where Section 907.2 requires smoke detectors, such protection shall be installed.~~

~~Subp. 2. **Repealed, 31 SR 1165**~~

~~Subp. ??? **F Section 907.2.1.** IFC Section 907.2.1 is amended, and sections added, to read:~~

Comment [PH93]: Renumber all Subparts ???

~~**907.2.1 Group A, general.** A fire alarm system shall be installed in accordance with Sections 907.2.1 through 907.2.1.3 in Group A occupancies having an occupant load of 300 or more.~~

~~**Exceptions:**~~

~~1. Assembly areas used solely for worship purposes.~~

~~2. A fire alarm system is not required when an approved automatic fire-sprinkler ~~extinguishing~~ system is installed throughout the building.~~

Comment [GN94]: Changed from extinguishing to sprinkling for clarification.

Comment [PH95]: New. To coordinate with SFM 7511

3. ~~Group A occupancy Assembly uses within portions of Group E occupancies are allowed to~~ shall have alarms as required for the Group E occupancy.

Comment [GN96]: Switched since technically there are no group A occupancies in group E's they are all group E.

4. Group A-5 occupancies. Also see Section 907.2.11.

Subp. 3. **F Section 907.2.1.1.** IBC F Section 907.2.1.1 is amended to read as follows:

907.2.1.1 Initiation. Initiation of the fire alarm system shall be by automatic means. Approved automatic fire detectors shall be installed in laundry rooms, boiler and furnace rooms, mechanical and electrical rooms, shops, kitchens, trash collection rooms, storage rooms, and similar areas.

Subp. 4. **F Section 907.2.1.2.** IBC F Section 907.2.1.2 is amended to read as follows:

907.2.1.2 Notification. The required fire alarm system shall activate an audible and visible notification appliance at a constantly attended location within the building for the purposes of initiating emergency action. A presignal feature and positive alarm sequencing in accordance with NFPA 72 are permitted.

Occupant notification shall be by means of voice announcements, either live or prerecorded, initiated by the person in the constantly attended location.

Exception: Where no constantly attended location exists, an automatic fire alarm system providing a general evacuation signal or an approved emergency voice/alarm communications system is permitted.

Subp. 5. **F Section 907.2.1.** IBC F Section 907.2.1 is amended by adding a section to read as follows:

907.2.1.3 System initiation in Group A occupancies with an occupant load of 1,000 or more. Activation of the fire alarm system in Group A occupancies with an occupant load of 1,000 or more shall immediately initiate an approved prerecorded message announcement using an approved emergency voice/alarm communications system in accordance with NFPA 72.

Exception: Where approved, the prerecorded announcement is allowed to be manually deactivated for a period of time, not to exceed ~~3~~ **three** minutes, for the sole purpose of allowing a live voice announcement from an approved constantly attended location.

Comment [PH97]: Change number (3) to word "three."

Subp. 6. **F Section 907.2.2.** IBC F Section 907.2.2 is amended to read as follows:

907.2.2 Group B, general. A fire alarm system shall be installed in accordance with Sections 907.2.2 through 907.2.2.3 in Group B occupancies where:

1. The building has an occupant load of 500 or more persons; or
2. The building has an occupant load of more than 100 persons above or below the lowest level of exit discharge; or

3. The building contains an ~~outpatient clinic~~, ambulatory care facility.

Comment [PH98]: Coordinate with new def in IBC/IFC and per 7511.

When automatic sprinkler systems or automatic fire detectors are installed in ~~outpatient clinics~~, ambulatory care facility, such systems or detectors shall be connected to the building fire alarm system.

Exception: In other than ~~outpatient clinics~~, ambulatory care facility, a fire alarm system is not required when an approved automatic fire extinguishing system is installed throughout the building.

Subp. 7. **F Section 907.2.2.** IBC F Section 907.2.2 is amended by adding a section to read as follows:

907.2.2.1 Initiation. Initiation of the fire alarm system shall be by automatic means. Approved automatic fire detectors shall be provided in boiler and furnace rooms, shops, kitchens, mechanical and electrical rooms, trash collection rooms, storage rooms and similar areas. In ~~outpatient clinics~~, ambulatory care facilities, initiation of the fire alarm system shall also be by manual means.

Subp. 8. **F Section 907.2.2.** IBC F Section 907.2.2 is amended by adding a section to read as follows:

907.2.2.2 Notification. Activation of the fire alarm system shall initiate a general evacuation signal.

Exception: In lieu of audible notification appliances, visible notification appliances shall be permitted to be used in patient care areas.

Subp. 9. **F Section 907.2.2.** IBC F Section 907.2.2 is amended by adding a section to read as follows:

907.2.2.3 ~~Outpatient clinics~~, Ambulatory Care Facilities. Corridors in ~~outpatient clinics~~ ambulatory care facilities and spaces open to the corridors shall be protected by an automatic smoke detection system.

Subp. 10. **F Section 907.2.3.** IBC F Section 907.2.3 is amended to read as follows:

907.2.3 Group E, general. A fire alarm system shall be installed in accordance with Sections 907.2.3 through 907.2.3.3 in Group E occupancies having an occupant load of 50 or more.

Subp. 11. **F Section 907.2.3.** IBC F Section 907.2.3 is amended by adding a section to read as follows:

907.2.3.1 Initiation. Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be provided in laundry rooms, boiler and furnace rooms, mechanical and electrical rooms, shops, laboratories, kitchens, locker rooms, janitors' closets, trash collection rooms, storage rooms, lounges and similar areas.

Exceptions:

1. In buildings protected throughout by an approved, supervised fire sprinkler system, manual fire alarm boxes are only required in the main office and in a custodial area.

2. Where all corridors are protected by an approved automatic fire alarm system having smoke detection with alarm verification, manual fire alarm boxes are only required near exits serving shops, chemistry and physics laboratories, boiler rooms, industrial technology and industrial arts rooms, kitchens, custodian's offices, and main offices.

Subp. 12. **F Section 907.2.3.** IBC F Section 907.2.3 is amended by adding a subsection to read as follows:

907.2.3.2 Travel through adjoining rooms. Where the only means of egress travel from an interior room or rooms having an aggregate occupant load of more than 10 occupants is through an adjoining or intervening room, automatic smoke detectors shall be installed throughout the common atmosphere through which the path of egress travel passes.

Exception: In buildings that are protected throughout by an approved automatic sprinkler system installed in accordance with Section 903.3.1.1, smoke detectors are not required in intervening or adjoining rooms.

Subp. 13. **F Section 907.2.3.** IBC F Section 907.2.3 is amended by adding a section to read as follows:

907.2.3.3 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

Subp. 14. **F Section 907.2.4.** IBC F Section 907.2.4 is amended to read as follows:

907.2.4 Group F, general. A fire alarm system shall be installed in accordance with Sections 907.2.4 through 907.2.4.2 in Group F occupancies that are two or more stories in height and have an occupant load of 500 or more above or below the lowest level of exit discharge.

Exception: A fire alarm system is not required when an approved automatic fire extinguishing system is installed throughout the building.

Subp. 15. **F Section 907.2.4.** IBC F Section 907.2.4 is amended by adding a section to read as follows:

907.2.4.1 Initiation. Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be provided in boiler and furnace rooms, trash collection rooms, kitchens, mechanical and electrical rooms, and similar areas.

Subp. 16. **F Section 907.2.4.** IBC F Section 907.2.4 is amended by adding a section to read as follows:

907.2.4.2 Notification. Activation of the fire alarm system shall initiate a general evacuation signal.

Subp. 17. **F Section 907.2.5.** IBC F Section 907.2.5 is amended to read as follows:

907.2.5 Group H, general. A fire alarm system shall be installed in accordance with Sections 907.2.5 through 907.2.5.2 in Group H-5 occupancies, occupancies used for the manufacture of organic coatings, and, when required by Chapters 60, 62, and 63 of the IFC at 37, 39 and 40, the following locations:

1. Rooms or areas where highly toxic compressed gases are stored or used;
2. Rooms or areas where Class I, II or III organic peroxides are stored; and
3. Liquid and solid oxidizer storage areas.

Subp. 18. **F Section 907.2.5.** IBC F Section 907.2.5 is amended by adding a section to read as follows:

907.2.5.1 Initiation. Initiation of the fire alarm system in Group H-5 Occupancies and in occupancies used for the manufacture of organic coatings shall be by manual means. Initiation of fire alarm systems installed for highly toxic gases, organic peroxides and oxidizers shall be by automatic means, as specified in Chapters 60, 62, and 63 37, 39 and 40 of the 2012 IFC.

Subp. 19. **F Section 907.2.5.** IBC F Section 907.2.5 is amended by adding a section to read as follows:

907.2.5.2 Notification. Activation of the fire alarm system in Group H-5 Occupancies and in occupancies used for the manufacture of organic coatings shall initiate a general evacuation signal. Activation of the automatic detection systems installed for highly toxic gases, organic peroxides, and oxidizers shall sound a local alarm.

Subp. 20. **Repealed, 31 SR 1165**

Subp. 21. **Repealed, 31 SR 1165**

Subp. ????. **F Section 907.2.6.** IFC Section 907.2.6 and all subsections are deleted in their entirety and replaced with the following:

907.2.6 Group I, general. A fire alarm system shall be installed in accordance with Sections 907.2.6 through 907.2.6.5.1 in Group I occupancies.

907.2.6.1 Notification: Activation of the fire alarm system in Group I occupancies shall immediately transmit an alarm to an approved monitoring station in accordance with NFPA 72.

Comment [PH99]: Needed for coordination with the International Fire Code and SFC/7511.

Comment [PH100]: Needed to coordinate with new 2012 IFC chapters and 7511

Comment [PH101]: Renumber all subparts for codification purposes !!!!! This is entirely new to 1305. Done to coordinate w/7511 per the SFM.

Comment [KJM102]: New revised language added in 7511. Same to 1305.

907.2.6.2 Group I-1 occupancies. Initiation of the fire alarm system shall be by manual and automatic means. Automatic smoke detectors shall be provided in ~~waiting areas that are open to corridors.~~

907.2.6.2.1 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

Exceptions:

1. In lieu of audible notification appliances, visible notification appliances shall be allowed to be used in critical care areas.

2. Where occupants are incapable of evacuating themselves because of age, physical/mental disabilities or physical restraint, only the attendants or other personnel required to evacuate occupants from a zone, area, floor or building shall be required to be notified. This notification shall include means to readily identify the zone, area, floor or building in need of evacuation.

907.2.6.3 Group I-2 occupancies. Initiation of the fire alarm system shall be by manual and automatic means. Hospitals, nursing homes (both intermediate care and skilled nursing facilities), board and care homes and detoxification facilities shall be provided with smoke detection throughout the corridor and ~~spaces~~ areas open to the corridors, other than nurse's stations.

Exception:

1. Corridor smoke detection shall not be required where the sleeping room smoke detectors required in 907.2.6.3 are connected to an approved fire alarm system and activate a general evacuation signal.

2. Manual fire alarm boxes shall not be required at exits from patient sleeping areas if located at all nurses' stations or other constantly attended staff locations, provided such fire alarm boxes are visible and continuously accessible and that travel distances horizontally, on the same floor shall not exceed 200 ft to reach a manual fire alarm box.

907.2.6.3.1 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal that is distinctive from audible signals used for other purposes in the same building.

Exceptions:

1. In lieu of audible notification appliances, visible notification appliances shall be allowed to be used in critical care areas.

Formatted: Font color: Red, Strikethrough

Comment [PH103]: Strike out the word "waiting" to match SFM Rule 9/14/12 PRH

Comment [PH104]: We need to coordinate this with an amendment in chapter 10 – with the SFM. This section may not be necessary with the Chapter 10 amendment. ?????

Formatted: Font color: Custom Color(84,141,212), Strikethrough

Comment [PH105]: Strike-out the word "spaces" and replace with the word "areas" – to match the SFM Rule. 9/14/12 PRH

Comment [PH106]: Changed formatting of these 2 exceptions to match SFM Rule. 9/14/12 PRH

Formatted: Indent: First line: 0"

Formatted: Indent: Left: 1", No bullets or numbering

2. Where occupants are incapable of evacuating themselves because of age, physical/mental disabilities or physical restraint, only the attendants or other personnel required to evacuate occupants from a zone, area, floor or building shall be required to be notified. This notification shall include means to readily identify the zone, area, floor or building in need of evacuation.

Comment [PH107]: Corrected numbering of all 4 exceptions to match SFM Rule 9/14/12 PRH

3. Where total evacuation of occupants is impractical due to building configuration, only the occupants in the affected zones shall be initially notified. Provisions shall be made to selectively notify occupants in other zones to afford orderly evacuation of the entire building.

Formatted: Indent: Left: 1", No bullets or numbering

4. Smoke detectors used solely for closing dampers or heating, ventilating, and air conditioning system shutdown shall not be required to activate the building evacuation alarm.

Formatted: Indent: Left: 1", No bullets or numbering

907.2.6.3.2 Patient room smoke detectors. Smoke detectors shall be installed in patient sleeping rooms of hospitals and nursing homes. Such detector's primary power shall be other than battery power. Actuation of such detectors shall cause a visual display on the corridor side of the room where the detector is located and shall cause a distinct audible and visual alarm at the nurse's station attending the room. Such detectors may be part of the facility, fire alarm system, nurse's call system or a standalone system. Integral smoke detectors of automatic door-closing devices on sleeping room doors can meet this requirement if they also cause all the items listed in 907.2.6.3.1.

Comment [GN108]: Deleted since there are patient sleeping room in supervised living facilities, detox centers, etc.

907.2.6.4 Group I-3 occupancies. Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be installed in laundry and soiled linen rooms, boiler and furnace rooms, mechanical and electrical rooms, shops, laboratories, kitchens, locker rooms, janitors' closets, trash-collection rooms, storage rooms, lounges, gift shops, commissaries and similar areas. Actuation of an automatic fire-extinguishing system, a manual fire alarm box or a fire detector shall initiate an approved fire alarm signal, which automatically notifies staff. Presignal systems shall not be used.

907.2.6.4.1 Manual fire alarm boxes. Manual fire alarm boxes are not required to be located in accordance with Section 907.4 where the fire alarm boxes are provided at staff-attended locations having direct supervision over areas where manual fire alarm boxes have been omitted. Manual fire alarm boxes are permitted to be locked in areas occupied by detainees, provided that staff members are present within the subject area and have keys readily available to operate the manual fire alarm boxes.

907.2.6.4.2 Smoke detectors. An approved automatic smoke-detection system shall be installed throughout resident housing areas, including sleeping areas and contiguous day rooms, group activity spaces and other common spaces normally accessible to residents.

Exceptions:

1. Other approved smoke-detection arrangements providing equivalent protection, such as placing detectors in exhaust ducts from cells or behind protective grills, are allowed when necessary to prevent damage or tampering.
2. Smoke detectors are not required in sleeping rooms with four or fewer occupants in smoke compartments that are equipped throughout with an approved automatic sprinkler system.

907.2.6.5 Group I-4 Occupancies. Initiation of the fire alarm system shall be by manual and automatic means. Automatic smoke detectors shall be provided in waiting areas that are open to corridors.

907.2.6.5.1 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

Subp. 22. F Section 907.2.6. IBC F Section 907.2.6 and all subsections are deleted in their entirety and replaced with the following:

907.2.6 Group I, general. A fire alarm system shall be installed in accordance with Sections 907.2.6 through 907.2.6.4.3 in Group I occupancies.

907.2.6.1 Initiation. Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be installed in laundry and soiled linen rooms, boiler and furnace rooms, mechanical and electrical rooms, shops, laboratories, kitchens, locker rooms, janitors' closets, trash collection rooms, storage rooms, lounges, gift shops, and similar areas. Automatic smoke detectors shall be provided in waiting areas that are open to corridors.

Exception: Manual fire alarm boxes in patient sleeping areas of Group I-1 and I-2 occupancies shall not be required at exits if located at all nurses' stations or other constantly attended staff locations, provided such fire alarm boxes are visible and continuously accessible and that travel distances required by Section 907.4.1 are not exceeded.

907.2.6.2 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal. In addition, activation of the fire alarm system shall immediately transmit an alarm to an approved central station or remote station service.

Exceptions:

1. In lieu of audible notification appliances, visible notification appliances shall be allowed to be used in critical care areas.
2. Where occupants are incapable of evacuating themselves because of age, physical/mental disabilities, or physical restraint, only the attendants or other personnel required to evacuate

Formatted: Font color: Custom Color(84,141,212), Strikethrough

Comment [PH109]: Strike-out the word "waiting" to match the SFM Rule. 9/14/12 PRH

Comment [PH110]: Delete this entire section as noted above in new added section per SFM 7511 rule. Renumber all subparts as required !!!!!

~~occupants from a zone, area, floor or building shall be required to be notified. This notification shall include means to readily identify the zone, area, floor or building in need of evacuation.~~

~~**907.2.6.3 Group I-2 Occupancies.** Corridors in hospitals, nursing homes (both intermediate care and skilled nursing facilities), board and care homes and detoxification facilities and spaces open to the corridors shall be protected by an automatic smoke detection system.~~

~~**907.2.6.3.1 Patient room smoke detectors.** Smoke detectors that receive their primary power from the building wiring shall be installed in patient sleeping rooms of hospitals and nursing homes. Actuation of such detectors shall cause a visual display on the corridor side of the room in which the detector is located and shall cause an audible and visual alarm at the nurse's station attending the room.~~

~~**907.2.6.4 Group I-3 Occupancies.** Group I-3 occupancies shall be provided with a fire alarm system installed for alerting staff.~~

~~**907.2.6.4.1 Initiation.** Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be installed in laundry and soiled linen rooms, boiler and furnace rooms, mechanical and electrical rooms, shops, laboratories, kitchens, locker rooms, janitors' closets, trash collection rooms, storage rooms, lounges, gift shops, commissaries and similar areas. Actuation of an automatic fire extinguishing system, a manual fire alarm box or a fire detector shall initiate an approved fire alarm signal, which automatically notifies staff. Presignal systems shall not be used.~~

~~**907.2.6.4.2 Manual fire alarm boxes.** Manual fire alarm boxes are not required to be located in accordance with Section 907.4 where the fire alarm boxes are provided at staff attended locations having direct supervision over areas where manual fire alarm boxes have been omitted.~~

~~Manual fire alarm boxes are permitted to be locked in areas occupied by detainees, provided that staff members are present within the subject area and have keys readily available to operate the manual fire alarm boxes.~~

~~**907.2.6.4.3 Smoke detectors.** An approved automatic smoke detection system shall be installed throughout resident housing areas, including sleeping areas and contiguous day rooms, group activity spaces and other common spaces normally accessible to residents.~~

Exceptions:

~~1. Other approved smoke detection arrangements providing equivalent protection, such as placing detectors in exhaust ducts from cells or behind protective grills, are allowed when necessary to prevent damage or tampering.~~

~~2. Smoke detectors are not required in sleeping rooms with four or fewer occupants in smoke compartments that are equipped throughout with an approved automatic sprinkler system.~~

Subp. 23. **F Section 907.2.7.** IBC F Section 907.2.7 is deleted.

Subp. 24. **F Section 907.2.7.1.** IBC F Section 907.2.7.1 is deleted.

Subp. 25. **F Section 907.2.8.** IBC F Section 907.2.8 is amended to read as follows:

907.2.8 Group R-1, general. A fire alarm system shall be installed in accordance with Sections 907.2.8 through 907.2.8.3 in Group R-1 occupancies.

Exceptions:

1. A fire alarm system is not required in buildings not over two stories in height where all individual guest rooms and contiguous attic and crawl spaces are separated from each other and public or common areas by at least one-hour fire partitions and each guest room has an exit directly to a public way, exit court or yard.
2. Buildings containing five or less guest rooms shall be allowed to be equipped with approved multiple-station smoke detectors installed as required for Group R-3 Occupancies. Installation shall be in accordance with Section 907.2.10.11.

907.2.8.1 Initiation. Initiation of the fire alarm system shall be by automatic means. Approved automatic fire detectors shall be provided in boiler and furnace rooms, shops, laundry rooms, mechanical and electrical rooms, trash collection rooms, storage rooms, gift shops, locker rooms and similar areas. Automatic smoke detectors shall be provided in all common areas and interior corridors serving as required means of egress.

Exceptions:

- ~~1. In buildings protected with an approved automatic fire extinguishing system in accordance with section 903.3.1 or 903.3.1.1, and a manual fire alarm box is provided at a constantly attended location. When a constantly attended location is not provided the manual fire alarm box shall be provided at the main exit, throughout the building and manual activation is provided at a constantly attended location.~~
- ~~2. In buildings protected with an approved automatic fire extinguishing system in accordance with section 903.3.1.1 or 903.3.1.2, manual fire alarm boxes need not be provided at the exits when one is installed at a constantly attended location.~~
2. In buildings protected with an approved automatic fire-extinguishing system in accordance with section 903.3.1.1 or 903.3.1.2, manual fire alarm boxes need not be provided at the exits when one is installed at an approved location.

907.2.8.2 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

907.2.8.3 Guest room smoke alarms, detectors. Guest room smoke detectors required by Section 907.2.10.11 shall not be connected to a fire alarm system.

Exception: Connection of such alarms detectors for annunciation only.

- Comment [PH111]:** New reference for coordination w/new codes.
- Comment [PH112]:** Amend 907.2.8.1 to add a new exception and modify existing exception per SFM 7511 Rule
- Comment [PH113]:** No "S" Only one exception, so no "s" needed 9/14/12 PRH
- Formatted:** No underline
- Formatted:** Left, Indent: Left: 0.5", No bullets or numbering. Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers
- Formatted:** Font: Times New Roman, Strikethrough
- Formatted:** Strikethrough
- Formatted:** Underline, Not Strikethrough
- Formatted:** Strikethrough
- Comment [KJM114]:** Clarification 9/14/12 PRH. Per Kevin M, this provision has changed. No item 1 and 2, just one exception – and modified as colored in purple.
- Formatted:** Not Strikethrough
- Formatted:** Font: (Default) Times New Roman
- Formatted:** Font: (Default) Times New Roman
- Comment [KJM115]:** Clarification. Changed constantly attended to an approved location because the front desk at most hotels are not 100 percent constantly attended, the night person may step away for a moment, and this would be a violation with the previous language.
- Comment [PH116]:** Item 2 was removed, then added back again with minor modifications. This change matches the final draft of the SFM Rule. 9/14/12 PRH
- Formatted:** Font: 12 pt
- Formatted:** Font: (Default) Times New Roman

Subp. 26. **F Section 907.2.9.** IBC F Section 907.2.9 is amended, and subsections added, to read as follows:

907.2.9 Group R 2, general. A fire alarm system shall be installed in accordance with Sections 907.2.9 through 907.2.9.2 in Group R 2 occupancies where:

1. Any guest room or dwelling unit is located ~~three~~ ~~two~~ or more stories above ~~grade; the story containing the lowest level of exit discharge;~~
2. Any guest room or dwelling unit is located more than one story below ~~grade; the highest level of exit discharge of exits serving the dwelling unit;~~
3. The building contains more than 16 dwelling units or guest rooms; or
- ~~4. The building is used as a dormitory, convent, monastery, fraternity, or sorority and has an occupant load of 20 or more.~~
4. The building is used as a dormitory, convent, monastery, fraternity or sorority and has an occupant load of 20 or more.

Exception: A fire alarm system is not required in buildings not over two stories in height where all dwelling units and contiguous attic and crawl spaces are separated from each other and public or common areas by at least one hour fire partitions and each dwelling unit has an exit directly to a public way, exit court or yard.

907.2.9.1 Initiation. Initiation of the fire alarm system shall be by automatic means. Automatic fire detectors shall be provided in boiler and furnace rooms, trash collection rooms, shops, laundry rooms, mechanical and electrical rooms, storage rooms, and similar areas. Automatic smoke detectors shall be provided in all common areas and interior corridors serving as required means of egress.

Exception: System fire and smoke detectors are not required when an approved automatic fire extinguishing system is installed throughout the building.

907.2.9.2 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

907.2.9.3 Dwelling unit smoke ~~alarms, detectors.~~ Dwelling unit smoke ~~alarms detectors~~ required by Section 907.2.~~10~~ ~~11~~ shall not be connected to the building fire alarm system.

Exception: Connection of such ~~alarms detectors~~ for annunciation only.

Subpt ?? F 907.2.9.3 Group R-2 College and university buildings is amended by renumbering the section as follows.:

~~907.2.9.3~~ **907.2.9.4 Group R-2 college and university buildings.** An automatic smoke detection system that activates the occupant notification system in accordance with

Formatted: Font color: Purple, Strikethrough

Formatted: Font color: Purple, Strikethrough

Formatted: Font color: Purple

Formatted: Font color: Purple, Strikethrough

Comment [PH117]: Modifications made to exceptions 1 and 2 per the SFM Rule modification. 9/14/12 PRH

Formatted: Font color: Purple, Strikethrough

Comment [PH118]: Is being deleted because of newly added language in 907.2.9.3 of the IBC (not necessary).

Formatted: Font: (Default) Times New Roman

Formatted: Indent: First line: 0.25"

Comment [PH119]: Item 4 was initially removed by the SFM, but has now been added back in again. 9/14/12 PRH

Formatted: Font: 12 pt

Formatted: Font: (Default) Times New Roman

Comment [PH120]: Changed per SFM 7511

Comment [PH121]: New subpart added for proper coordination of amendments and renumbering of IBC. No change to original IBC code language. Same in 7511.

Comment [KJM122]: Current language in the 2012 IFC

Section 907.5 shall be installed in Group R-2 college and university buildings in the following locations:

IBC Section 907.2.10. IBC Section 907.2.10 is amended to read:

907.2.10 Group R-4, general. A fire alarm system shall be installed in accordance with Sections 907.2.10 through 907.2.10.3 in Group R-4 occupancies.

Exceptions:

1. A fire alarm system is not required in buildings two stories or less in height where all individual sleeping units and contiguous attic and crawl spaces to those units are separated from each other and public or common areas by at least one-hour fire partitions and each sleeping unit room has an exit directly to a public way, exit court or yard.

2. Buildings containing five or less sleeping units shall be allowed to be equipped with approved multiple-station smoke detectors installed as required for Group R-3 occupancies. Installation shall be in accordance with Section 907.2.11.

907.2.10.1 Initiation. Initiation of the fire alarm system shall be by automatic means. Approved automatic fire detectors shall be provided in boiler and furnace rooms, shops, laundry rooms, mechanical and electrical rooms, trash-collection rooms, storage rooms, gift shops, locker rooms and similar areas. Automatic smoke detectors shall be provided in all common areas and interior corridors serving as required means of egress.

Exception:

System fire and smoke detectors are not required when an approved automatic fire-extinguishing system is installed in accordance with section 903.3.1.1, 903.3.1.2 or 903.3.1.3

907.2.10.2 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal.

907.2.10.3 Smoke alarms: Single and multi-station smoke alarms shall be installed in accordance with Section 907.2.11

~~Subp. 26a. F Section 907.2.10.1.4. IBC Section 907.2.10.1 is amended by adding a subsection to read as follows:~~

~~**907.2.10.1.4 Fire station and emergency medical quarters.** Areas used for sleeping in fire stations and emergency medical and ambulance crew quarters shall be provided with single station smoke detectors in accordance with Section 907.2.10.~~

~~Subpt ?? F 907.2.11.3 Interconnection is amended by adding an exception to the section as follows:~~

Comment [KJM123]: Modified language in 2012 to eliminate manual pull stations.

Formatted: Font: (Default) Times New Roman

Formatted: Font: 12 pt

Formatted: Font: (Default) Times New Roman

Comment [PH124]: Added new amendment to match SFM Rule (907.2.10) 9/14/12 PRH

Formatted: Font: 12 pt

Formatted: Font: (Default) Times New Roman

Comment [PH125]: This section is to be deleted entirely as per 7511. Renumber all subparts as required. !!!!!!!!!!!!!!!

Comment [PH126]: This is being added per the SFM 7511 Rule for coordination w/1305.

Exception: Smoke alarms installed in sleeping rooms of Group R-3 buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2, or 903.3.1.3 are not required to be interconnected.

Subp. 27. **F Section 907.2.10.2 907.2.11.4** IBC F Section **907.2.10.2 907.2.11.4** is amended to read as follows:

907.2.10.2 907.2.11.4 Power source. In new construction, required smoke alarms shall receive their primary power from the building wiring where such wiring is served from a commercial source and shall be equipped with a battery backup. Smoke alarms shall emit a signal when the batteries are low. Wiring shall be permanent and without a disconnecting switch other than as required for overcurrent protection.

Exceptions:

1. Smoke alarms are not required to be equipped with battery backup ~~in Group R-1 occupancies~~ where they are connected to an emergency electrical system.

2. Smoke alarms are not required to be equipped with battery backup in Group R 2 occupancies equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.

~~3. Smoke alarms installed in sleeping rooms of group R-3 buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2, or 903.3.1.3 are allowed to be battery-powered.~~

~~Subp. 27a. **F Section 907.2.10.5.** IBC F Section 907.2.10 is amended by adding a subsection to read as follows:~~

~~**907.2.10.5 Smoke alarms in are fault protected circuits.** Smoke alarms receiving their primary power supply from electrical circuits that are protected with are fault circuit interruption must have a backup power supply.~~

Subp. 28. **F Section 907.2.** IBC F Section 907.2 is amended by adding sections to read as follows:

907.2.24 907.2.23 Residential hospices. A fire alarm system shall be installed in accordance with Section ~~907.2.24~~ **907.2.23** in residential hospices. When automatic sprinkler systems or automatic fire detectors are installed, such systems or detectors shall be connected to the building fire alarm system.

907.2.24.1 907.2.23.1 Initiation. Initiation of the fire alarm system shall be by manual and automatic means. Approved automatic fire detectors shall be provided in boiler and furnace rooms, kitchens, laboratories, shops, gift shops, commissaries, laundry and soiled linen rooms, mechanical and electrical rooms, locker rooms, storage rooms, janitors' closets, trash collection rooms, lounges and similar areas. Automatic smoke detectors shall be provided in sleeping rooms, corridors and spaces open to the corridors.

Comment [PH127]: Renumbered for proper codification. A 3rd exception was also added. Renumber all subparts as required !!!

Comment [GN128]: Why just R-1? Why not R-2 and I-1?

Comment [PH129]: Added new exception per SFM Rule 7511

Comment [KJM130]: Gives credit for a complete sprinkler system, Nisja

Comment [PH131]: This section/existing amendment is deleted entirely. It is already covered in IBC 907.2.11.4, so this is not needed. Coordinates w/SFC 7511. Renumber subparts !!!

Comment [PH132]: Section rennumbers to duplicate 7511 Check numbering !!! Is .23 correct, or should this be .24 as originally shown???

Exception: Manual fire alarm boxes are not required at exits if manual fire alarm boxes are located at all nurses' stations or other continuously attended staff locations, provided such fire alarm boxes are visible and continuously accessible and that travel distances required by Section 907.4.1 are not exceeded.

907.2.24.2 907.2.23.2 Notification. Activation of the fire alarm system or automatic sprinkler system shall initiate a general evacuation signal. In addition, the fire alarm system shall be monitored by an approved central station service in accordance with Section 903.4.1.

Exception: In lieu of audible notification appliances, visible notification appliances shall be allowed to be used in sleeping areas.

Subp. 29. **Repealed, 31 SR 1165**

Subpt. ?? F Section 907.3 is amended to read as follows:

907.3 Fire safety functions. Automatic fire detectors utilized for the purpose of performing fire safety functions shall be connected to the building's fire alarm control unit where a fire alarm system is required by Sections 907.2 and chapter 11 are to activate notification appliances in accordance with those sections. ~~Detectors shall, upon actuation, perform the intended function and activate the alarm notification appliances or activate a visible and audible supervisory signal at a constantly attended location.~~ Where automatic fire detectors are installed for other fire safety functions, they shall perform the intended function upon activation. Where automatic detectors are installed for fire safety functions and the building has a fire alarm system, such detectors shall activate supervisory signals at the fire alarm control panel or at a constantly attended location. Where the building does not have a fire alarm system, such detectors shall activate a visual and audible supervisory signal at an approved location, which shall indicate the source of the signal. ~~In buildings not equipped with a fire alarm system, the automatic fire detector shall be powered by normal electrical service and, upon actuation, perform the intended function. The detectors shall be located in accordance with NFPA 72.~~

Subpt. ?? F 907.3 .1 Duct smoke detectors is deleted entirely and replaced with the following:

907.3.1 Air distribution and air-handling systems. Smoke detectors installed to shut down the air distribution or air-handling system shall, upon activation, perform the intended function. Air distribution or air-handling equipment that is part of a smoke-control system shall switch to smoke-control mode upon activation of a detector.

907.3.1.1 Fire alarm system interface. Smoke detectors that are installed in air distribution or air-handling systems for shutdown purposes and that are connected to a fire alarm system shall not sound a general evacuation signal.

Subpt. ?? F 907.3.2 Delayed egress locks is deleted entirely and replaced with the following:

907.3.2 Elevator control functions. Smoke detectors that are installed to control or recall elevators or to control doors for elevators, elevator lobbies or elevator shafts and

Comment [PH133]: All 907.3 sections modified/added pursuant to the 7511 Rule proposals for coordination purposes. Renumber all section subparts accordingly. !!!!!

Comment [KJM134]: Moved from 907.11 (2007) and amended

~~that are connected to a fire alarm system shall not sound a general evacuation signal. Elevator recall and firefighter's emergency operation for elevators shall only be controlled by elevator smoke detectors and shall not initiate upon other building fire detectors or evacuation signals.~~

~~Subpt. ?? F 907.3.3 Elevator emergency operation is deleted entirely and replaced with the following:~~

~~907.3.3 Door hold-open functions. Smoke detectors that are installed to hold open fire doors under nonemergency conditions and that are connected to a fire alarm system shall sound a general evacuation signal when the doors being held open are part of the means of egress corridor or stair system. Door hold-open smoke detectors are not required to activate a visual or audible signal.~~

~~907.3.4 Delayed egress locks. Where delayed egress locks are installed on means of egress doors in accordance with Section 1008.1.9.7, an automatic smoke or heat detection system shall be installed as required by that section.~~

~~Subpt. ??? F Section 907.6.5 Monitoring is amended by deleting the section entirely.~~

~~Subp. 30. F Section 907.9.2. IBC F Section 907.9.2 is amended to read as follows:~~

~~907.9.2 Audible alarms. Audible alarm notification appliances shall be provided and shall sound a distinctive sound that is not to be used for any purpose other than that of a fire alarm. The audible alarm notification appliances shall provide a sound pressure level of 15 decibels (dBA) above the average ambient sound level or 5 dBA above the maximum sound level having a duration of at least 60 seconds, whichever is greater, in every occupied space within the building. The minimum sound pressure levels shall be: 75 dBA in Groups R and I-1 occupancies; 90 dBA in mechanical equipment rooms; and 60 dBA in other occupancies. The maximum sound pressure level for audible alarm notification appliances shall be 110 dBA at the minimum hearing distance from the audible appliance. Where the average ambient noise is greater than 105 dBA, visible alarm notification appliances shall be provided in accordance with NFPA 72 and audible alarm notification appliances shall not be required.~~

~~Exception: Visible alarm notification appliances shall be allowed in lieu of audible alarm notification appliances in critical care areas of Group I-2 occupancies.~~

~~Subp. 31. F Section 907.10. IBC F Section 907.10 is amended, and subsections added, to read as follows:~~

~~907.10 Fire safety functions. Automatic fire detectors required by Section 907.2 are to activate notification appliances in accordance with those sections. Where automatic fire detectors are installed for other fire safety functions, they shall perform the intended function upon activation. Where automatic detectors are installed for fire safety functions and the building has a fire alarm system, such detectors shall activate supervisory signals at the fire alarm control panel or at a constantly attended location. Where the building does not have a fire alarm system, such detectors shall activate a visual and audible supervisory signal at an approved location, which shall indicate the source of the signal.~~

Comment [KJM135]: Same as the 2012 IFC

Comment [PH136]: Added new section 907.3.4 to match SFM Rule 9/14/12 PRH.

Comment [KJM137]: Monitoring of fire alarms. Was found in 907.15 in previous code. No change.

Comment [PH138]: Added per 7511 Rule.

Comment [PH139]: Delete subpart 30 entirely as per 7511 Rule for coordination. Renumber all subparts as required.

Comment [PH140]: Repeal. All section existing 1305.0907.10 amendments are deleted entirely and are relocated in section 907.3 – as per 7511 Rule.

~~907.10.1 Air distribution and air handling systems. Smoke detectors installed to shut down the air distribution or air handling system shall, upon activation, perform the intended function. Air distribution or air handling equipment that is part of a smoke control system shall switch to smoke control mode upon activation of a detector.~~

~~907.10.1.1 Fire alarm system interface. Smoke detectors that are installed in air distribution or air handling systems for shutdown purposes and that are connected to a fire alarm system shall not sound a general evacuation signal.~~

~~907.10.2 Elevator control functions. Smoke detectors that are installed to control or recall elevators or to control doors for elevators, elevator lobbies, or elevator shafts and that are connected to a fire alarm system shall not sound a general evacuation signal. Elevator recall and firefighter's emergency operation for elevators shall only be controlled by elevator smoke detectors and shall not initiate upon other building fire detectors or evacuation signals.~~

~~907.10.3 Door hold open functions. Smoke detectors that are installed to hold open fire doors under nonemergency conditions and that are connected to a fire alarm system shall sound a general evacuation signal when the doors being held open are part of the means of egress corridor or stair system. Door hold open smoke detectors are not required to activate a visual or audible signal.~~

~~Subp. 32. F Section 907.11. IBC F Section 907.11 is deleted.~~

Comment [PH141]: Repeal – not necessary per 7511. Renumber subparts as required!!

~~Subp. 33. F Section 907.14. IBC F Section 907.14 is deleted.~~

Comment [PH142]: Repeal – not necessary per 7511. Renumber all subparts accordingly.

1305.0908 SECTION 908, EMERGENCY ALARM SYSTEMS.

~~Subpt. 1. F Section 908.7 Carbon monoxide alarms is deleted in its entirety.~~

Comment [KJM143]: Not necessary. State Statute covers this.

IBC Sec. 908.7 is amended to read as follows:

908.7 Carbon monoxide alarms. Group I or R occupancies located in a building containing a fuel-burning appliance or in a building which has an attached garage shall be equipped with single-station carbon monoxide alarms. The carbon monoxide alarms shall be:

1. Listed as complying with UL 2034;
2. Be installed and maintained in accordance with NFPA 720 and the manufacturer's instructions; and
3. Within 10 feet of each sleeping unit or sleeping room.

Formatted: Indent: First line: 0.25"

Formatted: Indent: Left: 0.25", Hanging: 0.25"

Formatted: Indent: First line: 0.25"

An open parking garage, as defined in Chapter 2, or an enclosed parking garage ventilated in accordance with Section 404 of the *International Mechanical Code* shall not be considered an attached garage.

Formatted: Font: Italic, Underline

Exception: Sleeping units or dwelling units which do not themselves contain a fuel-burning appliance or have an attached garage, but which are located in a building with a fuel-burning appliance or attached garage, need not be equipped with a single-station carbon monoxide alarms provided that:

Formatted: Font: Bold, Underline

Formatted: Indent: First line: 0.25"

1. The sleeping unit or dwelling unit is located more than one story above or below any story which contains a fuel-burning appliance or an attached garage;

Formatted: Indent: Left: 1"

Formatted: Underline, Strikethrough

1. The sleeping unit or dwelling unit is not connected by duct work or ventilation shafts to any room containing a fuel-burning appliance or to an attached garage; and
2. The building is equipped with a common area carbon monoxide alarm system.

908.7.1 {unchanged}

Comment [GN144]: Needed due to statute & consistent with IRC.

1305.0909 SECTION 909, SMOKE CONTROL SYSTEMS.

Subpart 1. F Section 909.1 Scope and purpose is amended to read as follows:

Comment [PH145]: New section in 1305 to coordinate with 7511. Language is required to be slightly different than 7511, but is derived from their proposal.

909.1 Scope and purpose. This section applies to mechanical or passive smoke control systems when they are required by other provisions of this code. The purpose of this section is to establish minimum requirements for the design, installation and acceptance testing of smoke control systems that are intended to provide a tenable environment for the evacuation or relocation of occupants. These provisions are not intended for the preservation of contents, the timely restoration of operations or for assistance in suppression or overhaul activities. ~~Smoke control systems regulated by this section serve a different purpose than the smoke and heat venting provisions found in Section 910. Mechanical smoke control systems shall not be considered exhaust systems under Chapter 5 of the International Mechanical Code.~~

Subpart 2. F Section 909.4.6 Duration of operation is amended to read as follows:

Comment [PH146]: New section in 1305 to coordinate with 7511.

909.4.6 Duration of operations. All portions of the active or passive smoke control system shall be capable of continued operation after detection of the fire event for a period of not less than either 20 minutes, or 1.5 times the calculated egress time, whichever is less. System design shall be for 20 minutes or 1.5 times the calculated egress time, whichever is less.

Subpart 2a. F Section 909.4. IBC F Section 909.4 is amended by adding a subsection to read as follows:

Comment [PH147]: Renumber subpart as required !!!!! Renumber reference section to coordinate with new IBC format.

909.4.7 Door opening force. With any of the design methods allowed by Section 909, the door opening force, latch release, and set in motion force shall comply with Section 1008.1.2.3 requirements when the system is in smoke control mode.

Comment [GN148]: To be proposed by SFM

Subp. 2. F Section 909.21.22. IBC F Section 909 is amended by adding a subsection to read as follows:

~~909.21.22 High rise and Covered mall smoke exhaust systems. High rise buildings and eCovered mall buildings exceeding 50,000 square feet (4645 m²) in floor area, excluding anchor stores, shall be equipped with a post fire smoke exhaust system installed and maintained in accordance with Section 913.916.~~

Formatted: Strikethrough

Comment [PH149]: Renumber for new IBC/IFC formatting

1305.0910 F SECTION 910, SMOKE AND HEAT VENTS.

Formatted: Strikethrough

Formatted: Font: 12 pt, Strikethrough

Formatted: Strikethrough

IBC F Section 910 is amended to read as follows:

F SECTION 910

SMOKE AND HEAT VENTS

Subpart 1. **F Section 910.1.** IBC F Section 910.1 is amended by adding sections to read as follows:

910.1.1 Required venting method. Required smoke and heat venting shall be accomplished with mechanical smoke exhaust according to Section 910.4.

Exceptions:

1. Calculated engineering design of mechanical smoke exhaust in accordance with Section 910.5 shall be permitted for buildings sprinklered throughout.
2. For nonsprinklered buildings, smoke and heat vents as specified in Section 910.3 shall be permitted.
3. Where approved by the code official, smoke and heat vents as specified in Section 910.3 shall be permitted in sprinklered buildings.

910.1.2 Listing. Smoke and heat vents and mechanical smoke exhaust fans shall be listed for the intended purpose.

910.1.3 Curtain boards. When mechanical smoke exhaust is provided in accordance with Section 910.4 or 910.5, curtain boards are only required at the separation between areas protected with early suppression fast response (ESFR) sprinklers and conventional sprinkler systems.

Subp. 2. **F Section 910.4.** IBC F Section 910.4 is amended to read as follows:

910.4 Mechanical smoke exhaust. Mechanical smoke exhaust shall be in accordance with Sections 910.4.1 through 910.4.6.

Subp. 3. **F Section 910.4.3.** IBC F Section 910.4.3 is amended to read as follows:

910.4.3 Operation. Mechanical smoke exhaust fans shall be ~~automatically-manually~~ activated, ~~upon sprinkler system water flow. A 5 to 10 minute delay shall be provided between the sprinkler water flow signal and activation of the exhaust fans.~~ In addition, individual manual controls of each fan unit shall also be provided.

~~**Exception:** When required by the code official, initiation of mechanical smoke exhaust fans shall be only through manual activation.~~

Subp. 4. **F Section 910.4.5.** IBC F Section 910.4.5 is amended to read as follows:

910.4.5 Supply air. Supply air for exhaust fans shall be sized to provide a minimum of 50 percent of the required exhaust. Air velocity at each supply air opening shall not exceed an average of 200 feet per minute when measured 4 feet (1219 mm) in front of the opening.

Comment [PH150]: Amended to coordinate with 7511.

Openings for supply air shall be uniformly distributed around the periphery of the area served and be located or ducted to a position not more than one-half the storage height above the floor. Supply air openings shall open automatically upon operation of the smoke exhaust system and shall not require a manual action at each supply opening for operation. Supply air openings shall be kept clear of storage or obstructions to airflow for at least four feet (1219 mm) in front of the opening. Supply air openings shall be separated from exhaust fans and exterior combustibles to prevent introduction of smoke into the building.

Subp. 5. **F Section 910.** IBC F Section 910 is amended by ~~deleting section 910.5 and replacing it with the following:~~ ~~adding sections to read as follows:~~

910.5 Calculated engineering design of mechanical smoke exhaust. Calculated engineering design of mechanical smoke exhaust shall be in accordance with Sections 910.5.1 through 910.5.5.

910.5.1 Methodology. Mechanical smoke exhaust systems shall be designed to remove smoke after a fire is extinguished and to assist the fire department during suppression operations or during marginal sprinkler control situations. They are not considered life safety systems and are not designed for occupant safety.

910.5.2 Calculation method. Volumetric flow rate calculations shall demonstrate that the system will provide at least three air changes per hour for the space required to be provided with smoke exhaust. When only a portion of a space is used for high piled storage requiring smoke exhaust, the volume to be extracted shall be based on the ceiling height multiplied by the actual gross floor area for storage.

910.5.3 Operation. Mechanical smoke exhaust fans shall be automatically activated upon sprinkler system water flow. A 5 to 10 minute delay shall be provided between the sprinkler water flow signal and activation of the exhaust fans. In addition, individual manual controls of each fan unit shall also be provided.

Exception: When required by the code official, initiation of mechanical smoke exhaust fans shall be only through manual activation.

910.5.4 Supply air. Supply air for exhaust fans shall be sized to provide a minimum of 50 percent of the required exhaust. Air velocity at each supply air opening shall not exceed an average of 200 feet per minute when measured 4 feet (1219 mm) in front of the opening. Openings for supply air shall be uniformly distributed around the periphery of the area served and be located or ducted to a position not more than one half the storage height above the floor. Supply air openings shall open automatically upon operation of the smoke exhaust system and shall not require a manual action at each supply opening for operation. Supply air openings shall be kept clear of storage or obstructions to airflow for at least 4 feet (1219 mm) in front of the opening. Supply air openings shall be separated from exhaust fans and exterior combustibles to prevent introduction of smoke into the building.

910.5.5 Equipment. Wiring and controls shall be as required in Section 910.4.4. Interlocks shall be as required in Section 910.4.6. Exhaust fans shall be uniformly spaced and each fan shall have a maximum individual capacity of 30,000 cfm (850 m³/min).

910.6 Testing and maintenance. Mechanical smoke exhaust systems shall be tested and maintained as required by Sections 910.6.1 through 910.6.4.

910.6.1 Acceptance testing. Mechanical smoke exhaust systems shall be acceptance tested as required by Sections 909.18.2 1 through 909.18.5 7 and 909.19.

Comment [PH151]: Renumber for proper formatting in new IBC

910.6.1.1 Controls. For testing purposes, each smoke exhaust system equipped for automatic activation shall be put into operation by the actuation of the automatic initiating device. Control sequences shall be verified throughout the system, including verification of override from the firefighter's control panel when systems are equipped for automatic activation.

910.6.2 Special inspections. Special inspections for mechanical smoke exhaust shall be conducted according to Section 909.18.8.

910.6.3 Maintenance. Mechanical smoke exhaust systems, including exhaust fans, supply air openings and controls, shall be maintained and unobstructed.

910.6.4 Operational testing. Operational testing of the smoke exhaust system shall include all equipment such as initiating devices, fans, dampers, controls, and supply air openings. Mechanical smoke exhaust systems shall be operated and tested under each control sequence at least annually.

1305.0912 F SECTION 912, FIRE DEPARTMENT CONNECTIONS.

IBC F Section 912.2 is amended by adding a subsection to read:

912.2.3 Connection height. Newly installed fire department connections shall be located not less than 18 inches (457 mm) and not more than 4 feet (1.2 m) above the level of the adjacent grade or access level.

Comment [GN152]: Waiting for update from the SFM Code Committee,... To be proposed by SFM

~~1305.0913 SECTION 913~~ 1305.0916 SECTION 916, POST FIRE EXHAUST SYSTEM.

IBC Chapter 9 is amended by adding a section and subsections to read as follows:

SECTION ~~913~~916

POST FIRE SMOKE EXHAUST SYSTEM

~~913.1~~916.1 Scope and purpose. This section applies to post fire smoke exhaust systems when they are required by other provisions of this code. The purpose of this section is to establish minimum requirements for the design and installation of smoke exhaust systems that are intended for the timely restoration of operations and overhaul activities once a fire is extinguished.

~~913.2~~916.2 General design requirements. Post fire smoke exhaust systems are not intended or designed as life safety systems and are not required to meet the provisions of Section 909. These systems are permitted to use dedicated equipment, the normal building HVAC system or other

openings and shall have the capability to exhaust smoke from occupied spaces. Smoke removal may be by either mechanical or natural ventilation, but shall be capable of removing cold smoke. Smoke exhaust shall be permitted through elevator shafts. Smoke removed from a space must be discharged to a safe location outside the building and may not be recirculated into the building in accordance with the mechanical code.

913.3916.3 Exhaust capability. The system shall have an air supply and smoke exhaust capability that will provide a minimum of three air changes per hour or remove smoke to less than a 5 percent concentration within one hour of operation. The system need not exhaust from all areas at the same time, but is permitted to be zoned based on the largest fire area served. For the purpose of calculating system size, the height of a compartment shall be considered to run from slab to slab and include the volume above suspended ceilings.

913.4916.4 Operation. The smoke exhaust system shall be operated by manual controls that are readily accessible to the fire department at an approved location and shall incorporate an approved control diagram. When a system is zoned into areas of operation less than the entire building, each zone shall have an individual control. Fire department manual controls of post fire smoke exhaust systems shall have the highest priority of any control point within the building. Smoke exhaust shall not be permitted through any exit enclosure as defined in Section 1002.

913.5916.5 Inspection and testing. Post fire smoke exhaust systems shall be inspected and tested annually.

1305.1000 [Repealed, 19 SR 1340]

1305.1000 [Repealed, 27 SR 1474]

~~1305.1002 SECTION 1002, DEFINITIONS:~~

~~IBC Section 1002.1 is amended by adding or replacing the following definitions:~~

~~**AISLE.** That portion of an exit access that connects an aisle accessway to an exit access doorway, corridor, or an exit.~~

~~**CORRIDOR.** An interior passageway having a length at least three times its width, having walls, partitions, or other obstructions to exit travel over 6 feet (1829 mm) in height on two opposing sides, and having openings from rooms or similar spaces.~~

~~**ROOM.** A space or area bounded by any obstruction over 6 feet in height which at any time encloses more than 80 percent of the perimeter of the area. In computing the unobstructed perimeter, openings less than 3 feet (914 mm) in clear width and less than 6 feet 8 inches (2032 mm) in height shall not be considered. Aisles and corridors shall not be construed to form rooms.~~

1305.1003 [Repealed, 31 SR 1165]

1305.1004 [Repealed, 31 SR 1165]

1305.1008 SECTION 1008, DOORS, GATES, AND TURNSTILES.

Formatted: Indent: First line: 0.25"

Comment [PH153]: These 3 definitions stay in 1305, but are relocated to Chapter 2 due to new code formatting

Comment [GN154]: Moved to Chapter 2

Subpart 1. **Repealed, 31 SR 1165**

Subp. 2. **Repealed, 31 SR 1165**

Subp. 3. **Repealed, 31 SR 1165**

Subp. 4. **IBC Section 1008.1.3.** IBC Section 1008.1.3 is amended by adding a subsection to read as follows:

~~1008.1.3.6 Special egress control devices. Where the clinical needs of the patients require specialized security measures for their safety, door locking arrangements are permitted in Group I-1 occupancies (this includes use groups as described in Group I-1 occupancies that are identified as either Group R-3 or Group R-4 occupancies because of occupant load) and Group I-2 occupancies provided that:~~

Formatted: Font color: Red, Strikethrough

~~1. keys or devices that function like keys are carried by staff at all times;~~

~~2. in at least one egress path, not more than one such arrangement is located;~~

~~3. the building or fire area is protected by an approved automatic sprinkler system in accordance with Section 903.3.1.1 (NFPA 13) and an approved fire alarm system having smoke detection, installed throughout the exit corridor system and areas open to the exit corridor;~~

~~4. locking devices automatically unlock upon activation of any of the following:~~

~~a. automatic sprinkler system;~~

~~b. automatic smoke detection system;~~

~~c. automatic fire alarm system; or~~

~~d. loss of electrical power;~~

~~5. locking devices can be remotely unlocked from an approved location within the secured area;~~

~~6. there is no public assembly space within the secured area;~~

~~7. 24-hour patient supervision is provided within the secured area;~~

~~8. relocking of the locking device is by manual means from an approved location within the secured area;~~

~~9. locking devices are designed to fail in the open position;~~

~~10. special egress control devices are not permitted in buildings of type III B or V B construction, and shall not exceed one story in height when in type III A, IV HT, or type V A construction;~~

~~11. floor levels within the building or portion of the building with the special egress control devices shall be divided into at least two compartments by smoke barriers meeting the requirements of Section 709; and~~

~~12. substitution of the automatic sprinkler system for one hour fire resistance rated construction (pursuant to Table 601, footnote d) is permitted.~~

Comment [GN155]: Now in IBC 1008.1.9.6 under Special Locking arrangement. Amendment not necessary any longer.

Formatted: Font color: Red, Strikethrough

Subp. 5. **IBC Section ~~1008.1.4~~1008.1.5.** IBC Section ~~1008.1.4~~1008.1.5 is amended by modifying exception 5 to read as follows:

Exceptions:

5. Exterior decks, patios, or balconies that are part of Type B dwelling units, have impervious surfaces, and that are not more than two inches (50 mm) below the finished floor level of the adjacent interior space of the dwelling unit.

Subp. 6. **IBC Section ~~1008.1.8.3~~1008.1.9.3.** IBC Section ~~1008.1.8.3~~1008.1.9.3 is amended to read as follows:

~~1008.1.8.3~~1008.1.9.3 **Locks and latches.** Locks and latches shall be permitted to prevent operation of doors where any of the following exists:

1. Places of detention or restraint.

2. In buildings in occupancy Group A having an occupant load of 300 or less, in buildings in occupancy Groups B, F, M, and S, and in churches, the main exterior door or doors are permitted to be equipped with key operated locking devices from the egress side provided:

2.1. The locking device is readily distinguishable as locked.

2.2. A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED. The sign shall be in letters 1 inch (25 mm) high on a contrasting background.

2.3. The use of the key operated locking device is ~~revokable~~revocable by the building official for due cause.

3. Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts has no doorknob or surface mounted hardware.

4. Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt, or security chain, provided such devices are openable from the inside without the use of a key or tool.

5. Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures.

56. Delayed egress locks, installed and maintained in conformance with Section ~~1008.1.8.6~~1008.1.9.7.

67. Special ~~egress control devices~~locking arrangements installed and maintained in conformance with Section ~~1008.1.3.6~~1008.1.9.6.

78. In rooms, other than cells, where occupants are being restrained for safety or security reasons, special ~~locking~~detention arrangements which comply with the requirements of Section ~~1008.1.10~~1008.1.11 are permitted.

Subp. 7. **IBC Section ~~1008.1.8.6~~1008.1.9.7.** IBC Section ~~1008.1.8.6~~1008.1.9.7 is amended to read as follows:

~~1008.1.8.6~~1008.1.9.7 Delayed egress locks. Approved, listed, delayed egress locks shall be permitted to be installed on doors serving any occupancy except Group A and H occupancies and assembly uses within group E occupancies in buildings that are equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 and an approved smoke detection system installed in means of egress system serving the locked area ~~or an approved automatic smoke detection system installed in accordance with Section 907,~~ provided that the doors unlock in accordance with Items 1 through 6 below. A building occupant shall not be required to pass through more than one door equipped with a delayed egress lock before entering an exit. Delayed egress locks shall be maintained and tested in accordance with the IFC.

Comment [GN156]: Now that group A's in E's are considered E's, this amendment clarifies that delayed egress is not appropriate for assembly uses.

Formatted: Strikethrough

Comment [GN157]: Requested by SFM 11/26/2012.

Comment [GN158]: Requested by SFM 11/26/2012

1. The doors unlock upon actuation of the automatic sprinkler system or automatic fire detection system.
2. The doors unlock upon loss of power controlling the lock or lock mechanism.
3. The door locks shall have the capability of being unlocked by a signal from the fire command center.
4. The initiation of an irreversible process which will release the latch in not more than 15 seconds when a force of not more than 15 pounds (67 N) is applied for one second to the release device. Initiation of the irreversible process shall activate an audible signal in the vicinity of the door. Once the door lock has been released by the application of force to the releasing device, relocking shall be by manual means only.

Exception: Where approved, a delay of not more than 30 seconds is permitted.

5. A sign shall be provided on the door located above and within 12 inches (305 mm) of the release device reading: PUSH UNTIL ALARM SOUNDS. DOOR CAN BE OPENED IN 15 30 SECONDS.
6. Emergency lighting shall be provided at the door.

Subp. 7A IBC Section 1008.1.9.6 IBC Section 1008.1.9.6 is amended to read as follows:

1008.1.9.6 Special locking arrangements in Group I-1, I-2, R-3 or R-4. Approved special egress locks shall be permitted in a Group I-1, I-2, R-3 or R-4 occupancy where the clinical needs of persons receiving care require such locking. Special egress locks shall be permitted in such occupancies where the building is equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 ~~or~~ and an approved automatic smoke or heat detection system installed in accordance with Section 907, provided that doors are installed and operated in accordance with Items 1 through 7.

1. The doors unlock upon actuation of the automatic sprinkler system ~~or~~ and automatic fire detection system.
2. The doors unlock upon loss of power controlling the lock or lock mechanism.
3. The door locks shall have the capability of being unlocked by a signal from the fire command center, a nursing station or other approved location.
4. A building occupant shall not be required to pass through more than one door equipped with a special egress lock before entering an exit.
5. The procedures for the operation(s) of the unlocking system shall be described and approved as part of the emergency planning and preparedness required by Chapter 4 of the International Fire Code.
6. All clinical staff shall have the keys, codes or other means necessary to operate the locking devices.
7. Emergency lighting shall be ~~provided~~ provided at the door.
8. 24-hour patient supervision is provided within the secured area.
9. Locking devices are designed to fail in the open position.

10. Floor levels within the building or portion of the building with special locking arrangement shall be divided into at least two compartments by smoke barriers meeting the requirements of Section 709.

Exception: Item 1 through 4 shall not apply to doors to areas where persons, which because of clinical needs, require restraint or containment as part of the function of a ~~psychiatric~~ psychiatric treatment area.

Subp. 8. **IBC Section 1008.1.** IBC Section 1008.1 is amended by adding subsections as follows:

~~1008.1.10~~**1008.1.11 Special lockingdetention arrangements.** Special ~~lockingdetention~~ arrangements meeting the requirements of Sections ~~1008.1.10~~**1008.1.11** through ~~1008.1.10.5~~**1008.1.11.4** are permitted for rooms, other than cells, where the occupants are being restrained for safety or security reasons. The use of Sections ~~1008.1.10~~**1008.1.11** through ~~1008.1.10.5~~**1008.1.11.5** may be revoked by the fire code official or building official for due cause.

~~1008.1.10.1~~**1008.1.11.1 Locking hardware.** Locking devices shall release upon any of the following conditions:

1. Activation of the automatic sprinkler system.
2. Activation of any automatic fire detection device.

Formatted: Font: Bold

Formatted: Underline, Font color: Light Blue

Formatted: Underline

Formatted: Underline, Font color: Light Blue

Formatted: Underline

Formatted: Underline, Font color: Light Blue

Formatted: Underline

Formatted: Underline, Font color: Light Blue

Formatted: Strikethrough

Formatted: Underline, Font color: Light Blue

Formatted: Indent: Left: 0.25"

Formatted: Strikethrough

Formatted: Underline, Font color: Light Blue

Formatted: Indent: Left: 0", Hanging: 0.25"

Formatted: Indent: Left: 0.25"

Formatted: Underline, Font color: Light Blue

Formatted: Indent: Left: 0.25"

Formatted: Font color: Light Blue

Comment [GN159]: New provision in IBC that is similar to current Special Egress control devices. Several changes made to reflect current language.

Comment [GN160]: New term for current provision due to IBC using the term in new provision.

3. Activation of any automatic fire alarm system.
4. Loss of electrical power to the locking device or the fire alarm system.
5. Activation of the fire alarm trouble signal.
6. Operation of a manual switch located in an approved location.

All locking devices shall be designed to fail in the open position following the release of the locking devices for any of the conditions specified above. Relocking of the devices shall be by manual means only at the door.

~~1008.1.10.2~~**1008.1.11.2** **Fire extinguishing system.** When special ~~locking~~**detention** arrangements are used, the room or area being secured shall be protected with quick response sprinklers.

~~1008.1.10.3~~**1008.1.11.3** **Fire alarm and detection.** When special ~~locking~~**detention** arrangements are used, the room or area and spaces between the room or area and an exterior exit door shall be protected with automatic smoke detection connected to the building's fire alarm system. If the walls of the room or area do not extend to the ceiling, automatic smoke detection can be provided in the adjacent room or area, provided that there are no substantial obstructions to delay activation of the smoke detection.

~~1008.1.10.4~~ **Construction.** ~~Rooms or areas containing these special locking arrangements shall be constructed of noncombustible materials having a minimum one-hour fire resistive construction. Doors separating the rooms from other spaces shall swing in the direction of egress travel from the room and have a fire protection rating of not less than 20 minutes. Doors need not be self-closing. The interior finish of the wall and ceiling surfaces must not exceed a Class C.~~

~~1008.1.10.5~~**1008.1.11.4** **Location.** ~~The room or rooms shall be located on a floor that provides direct grade level access when located in buildings or portions thereof consisting of nonrated construction.~~

1305.1009 SECTION 1009, STAIRWAYS AND HANDRAILS.

IBC Section ~~1009.9.1009.13~~ IBC Section ~~1009.9~~1009.13**** is amended to read as follows:

~~1009.9~~**1009.13** **Alternating tread devices.** Alternating tread devices are limited to an element of a means of egress in buildings of Groups F, H, and S from a mezzanine not more than 250 square feet (23 m²) in area and which serves not more than five occupants; in buildings of Group I 3 from a guard tower, observation station, or control room not more than 250 square feet (23 m²) in area and for access to unoccupied roofs. Access to mechanical equipment or appliances on a roof shall be in accordance with Section 1209.3.1 and the Minnesota Mechanical Code.

IBC Section 1009.14 Ships Ladder is amended to read as follows:

Comment [GN161]: Removed per request from John Swanson of SFM.

Formatted: Strikethrough

Comment [GN162]: Requested by SFM 11/26/2012

Formatted: Strikethrough

Comment [PH163]: This new amendment was added at the June 20th ACM – per the committee.

Formatted: Indent: First line: 0.25"

IBC Section 1009.14 Ships Ladders. Ships ladders constructed in accordance with MSBC 1305.1209 shall be permitted to be used as a means of egress component at the following locations:

1. Ships ladders are permitted to be used in Group I-3 occupancies for ~~as a component of a means of egress to and from~~ at control rooms or elevated facility observation stations not more than 250 square feet (23 m²) in floor area. ~~with not more than three occupants and for access to unoccupied roofs.~~

2. Ships ladders are permitted to be used as a component for means of egress at recessed or elevated floors or platforms when the area served has an occupant load of five or less, and the space meets all of the following criteria:

- a) ~~Access to the area served is limited to building facilities staff, maintenance staff, employees, or other authorized personnel;~~
- b) ~~required access to the area served is limited and periodic;~~
- c) ~~the area served is used for building maintenance service functions, or for equipment access or monitoring;~~
- d) ~~the area served is not required to have a second means of egress by other provisions of this code; and,~~
- e) ~~the area served is not classified as a Group H occupancy.~~

3. Ships ladders are permitted to be used for access to unoccupied spaces in accordance with MSBC 1305.1209.

~~Ships ladders shall have a minimum tread depth of 5 inches (127 mm). The tread shall be projected such that the total of the tread depth plus the nosing projection is no less than 8 1/2 inches (216 mm). The maximum riser height shall be 9 1/2 inches (241 mm). Handrails shall be provided on both sides of ships ladders. The minimum clear width at and below the handrails shall be 20 inches (508 mm).~~

1305.1013 SECTION 1013, GUARDS.

Subpart 1. **IBC Section ~~1013.1.1013.2~~ IBC Section ~~1013.11013.2~~** is amended by adding an exception as follows:

Exception:

8. In accordance with the Minnesota Bleacher Safety Act, Minnesota Statutes, section ~~16B.616326B.112~~, guards are not required on bleachers 55 inches or less in height.

Subp. 2. **IBC Section ~~1013.2.1013.3~~ IBC Section ~~1013.21013.3~~** is amended by modifying exception ~~24~~ to read as follows:

2. The guard height in assembly seating areas shall be in accordance with Section ~~1025.141028.14~~ and the Minnesota Bleacher Safety Act, Minnesota Statutes, section ~~16B.616.326B.112~~

Subp. 3. IBC Section 1013.8 Window sills, is amended to read as follows:

1013.8 Window sills. In Occupancy groups R-2, ~~and R-3, one- and two- family, and multiple-family dwellings, and townhouses,~~ where the ~~lowest part of the opening of the sill portion of an operable window is located more than 72 inches (1829 mm) above the finished grade or other surface below,~~ the lowest part of the clear opening of the window opening shall be at a height not less than 36 inches (915 mm) above the finished floor surface of the room in which the window is located. ~~Operable sections of windows shall not permit openings that allow passage of a 4-inch-diameter (102 mm) sphere where such openings are located within 36 24 inches (915 610 mm) of the finished floor.~~

Exceptions:

1. Operable windows where the lowest part sill portion of the opening is located more than 75 feet (22,860 mm) above the finished grade or other surface below and that are provided with window fall prevention devices that comply with ASTM F 2006.
2. Windows whose openings will not allow a 4-inch-diameter (102 mm) sphere to pass through the opening when the window is in its largest opened position.
3. Openings that are provided with window fall prevention devices that comply with ASTM F 2090.
4. Windows that are provided with window opening control devices that comply with Section 1013.8.1.
5. Replacement windows for occupancy groups R-2, R-3, one-and two-family, multi-family dwellings, and townhouses located on or below the third story above grade plane are exempt from Section 1013.8.

1013.8.1 Window opening control devices. Window opening control devices shall comply with ASTM F 2090. The window opening control device, after operation to release the control device allowing the window to fully open, shall not reduce the minimum net clear opening area of the window unit to less than the area required by Section 1029.2.

~~1305.1014~~1305.1017 SECTION ~~1014~~1017, **EXIT ACCESS AISLES.**

IBC Section ~~1014.4~~1017 and all subsections are deleted in their entirety and replaced with the following:

~~1014.4~~1017.1 Aisles and aisle accessways. Aisles and aisle accessways serving as a portion of the exit access in the means of egress system shall comply with the requirements of this section. Aisles and aisle accessways shall be provided from all occupied portions of the exit access. Aisles and aisle accessways serving assembly areas, other than seating at tables, shall comply with Section ~~1025~~1028. Aisles and aisle accessways serving reviewing stands, grandstands, and bleachers shall comply with Section ~~1024~~1028.

~~1014.4~~1017.2 Width determination. Where tables or counters are served by fixed seats, the width of the aisle or aisle accessway shall be measured from the back of the seat. Where seating is located at a table or counter and is adjacent to an aisle or aisle accessway, the measurement of required clear width of the aisle or aisle accessway shall be made to a line 19 inches (483 mm) measured perpendicular to and away from and running parallel to the edge of the table or

- Formatted: Underline, Strikethrough
- Formatted: Underline, Strikethrough
- Formatted: Underline, Strikethrough
- Formatted: Underline, Not Strikethrough
- Formatted: Underline, Not Strikethrough
- Formatted: Underline, Not Strikethrough
- Comment [B164]: See proposal 1305-6 on website, approved by 1305 committee.
- Formatted: Underline, Strikethrough
- Formatted: Underline, Strikethrough
- Formatted: Underline, Strikethrough
- Formatted: Underline, Not Strikethrough
- Formatted: Underline, Strikethrough
- Formatted: Underline, Strikethrough

Comment [PH165]: 5/25/12 Beth wrote this in. What happened to item #5 in the exceptions – from what was approved by our committee?????

Comment [PH166]: New language added/modified per latest revision (11) by Rich L on 10/3/12

Formatted: Font: Bold, Underline

counter. In the case of other side boundaries for aisle or aisle accessways, the clear width shall be measured to walls, tread edges, or other obstructions.

The required width of the aisles and aisle accessways shall be unobstructed.

Exception: Doors, when fully opened, and handrails shall not reduce the required width by more than 7 inches (178 mm). Doors in any position shall not reduce the required width by more than one half. Other nonstructural projections such as trim and similar decorative features are permitted to project into the required width 1.5 inches (38 mm) from each side.

~~1014.4.1.1~~1017.2.1 Minimum aisle accessway width. Aisle accessways not required to be accessible by Chapter 11 shall provide a minimum of 12 inches (305 mm) of width, plus 0.5 inches (12.7 mm) of width for each additional one foot (305 mm), or fraction thereof, beyond 12 feet (3658 mm) of aisle accessway length.

Exception: Portions of an aisle accessway having a length not exceeding six feet and used by a total of not more than four persons.

~~1014.4.1.2~~1017.2.2 Minimum aisle width. The minimum clear width shall be determined by Section 1005.1 for the occupant load served, but shall not be less than 36 inches (914 mm).

Exception: Nonpublic aisles serving less than 50 people, and are not required to be accessible by Chapter 11, need not exceed 28 inches (711 mm) in width.

~~1014.4.2~~1017.3. Length.

~~1014.4.2.1~~1017.3.1 Aisle accessway. The length of travel along the aisle accessway shall not exceed 30 feet (9144 mm) to an aisle or exit access doorway.

~~1014.4.2.2~~1017.3.2 Aisle. The length of travel along an aisle or combination aisle accessway and aisle to a point where a person has a choice of two or more paths of egress travel to separate exits or exit access doorways shall not exceed that permitted by Section 1014.3 for common path of egress travel.

1305.1015 SECTION 1015, EXIT AND EXIT ACCESS DOORWAYS.

IBC Section 1015.1 is amended to read as follows:

1015.1 Exit or exit access doorways required from spaces. Two exits or exit access doorways from any space shall be provided where one of the following conditions exists:

1. The occupant load of the space exceeds the values in Table 1015.1.

Exception:

1. In Groups R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of ~~4~~620 where the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.

Formatted: Indent: First line: 0.25"

Formatted: Numbered + Level: 1 +
Numbering Style: 1, 2, 3, ... + Start at: 1 +
Alignment: Left + Aligned at: 0.75" + Indent
at: 1"

2. Care suites in Group I-2 occupancies complying with Section 407.4.3.

2. The common path of egress travel exceeds the limitations of Section 1014.3.

3. Where required by Sections 1015.3, 1015.4, ~~and 1015.5~~, and 1015.6

4. When located in buildings used for educational purposes, laboratories and prep rooms that exceed 500 square feet in area and contain hazardous materials.

~~Exception: Group I-2 occupancies shall comply with Section 1014.2.2.~~

~~Where a building contains mixed occupancies, each individual occupancy shall comply with the applicable requirements for that occupancy. Where applicable, cumulative occupant loads from adjacent occupancies shall be considered in accordance with the provisions provisions of Section 1004.1~~

Formatted: Font: Not Bold

Formatted: Indent: Left: 0"

Table 1015.1 is unchanged.

~~1305.1019 NUMBER OF EXITS AND CONTINUITY.~~

~~Subpart 1. IBC Section 1019.1. IBC Section 1019.1 is amended to read as follows:~~

~~**1019.1 Minimum number of exits.** Occupants within rooms and spaces shall be provided with and have access to the minimum number of approved independent exits as required by Section 1015.1. Occupants on every story, in every basement, and in every building shall be provided with and have access to the minimum number of approved independent exits as required by Table 1019.1, except as modified in Section 1019.2. For the purposes of this chapter, occupied roofs shall be provided with exits as required for stories. The required number of exits from any story, basement, or individual space shall be maintained until arrival at grade or the public way. Table 1019.1 is unchanged.~~

~~Subp. 2. IBC Section 1019.1.3. IBC Section 1019.1 is amended by adding a subsection to read as follows:~~

~~**1019.1.3 Press box roof access.** The means of egress from occupied press box roofs shall comply with the provisions of this chapter. Occupied press box roofs shall be provided with guards in accordance with Section 1013.~~

~~**Exception:** Press box roofs used as camera, video, or security platforms or similar uses having an occupant load of nine or less shall have access to not less than one means of egress. The means of egress is permitted to be by way of a roof hatch or scuttle and ships ladder as required by Section 1209.3.~~

~~Subp. 3. IBC Section 1019.2. IBC Section 1019.2 is amended to read as follows:~~

~~**1019.2 Buildings or stories with one exit.** Only one exit shall be required in buildings or stories as described below:~~

~~1. Buildings or stories described in Table 1019.2, provided that the building has not more than one level below the first story above grade plane.~~

~~2. Buildings or stories of a Group R-3 occupancy.~~

~~3. Single level buildings with the occupied space at the level of exit discharge provided that the story or space complies with Section 1015.1 as a space with one means of egress.~~

~~Subp. 4. IBC Table 1019.2. IBC Table 1019.2 is amended to read as follows:~~

~~Table 1019.2
Buildings or Stories with One Exit~~

Occupancy	Maximum Height of Building Above Grade Plane	Maximum Occupants (or Dwelling Units) per Floor (with One Exit) and Travel Distance
A, B^d, E^e, F, M, U	1 story	49 occupants and 75 feet travel distance
H-2, H-3	1 story	3 occupants and 25 feet travel distance
H-4, H-5, I, R	1 story	10 occupants and 75 feet travel distance
S^a	1 story	29 occupants and 100 feet travel distance
B^b, F, M, S^a	2 stories	30 occupants and 75 feet travel distance
R-2	2 stories^e	3 dwelling units and 50 feet travel distance

~~Footnotes unchanged.~~

Comment [GN167]: Now covered in the IBC, but very confusing compared to our amendment.

1305.1018 SECTION 1018 CORRIDORS

1305.1018, IBC Table 1018.1 is amended as follows:

<u>OCCUPANCY</u>	<u>OCCUPANT LOAD SERVED BY CORRIDOR</u>	<u>REQUIRED FIRE-RESISTANCE RATING (hours)</u>	
		<u>Without sprinkler system</u>	<u>With sprinkler system^c</u>
<u>H-1, H-2, H-3</u>	<u>All</u>	<u>Not Permitted</u>	<u>1</u>
<u>H-4, H-5</u>	<u>Greater than 30</u>	<u>Not Permitted</u>	<u>1</u>

<u>A, B, E, F, M, S, U</u>	<u>Greater than 30</u>	<u>1</u>	<u>0</u>
<u>R-1, R-2</u>	<u>Greater than 10</u>	<u>Not Permitted</u>	<u>0.5</u>
<u>R-3, R-4</u>	<u>All</u>	<u>0</u>	<u>0</u>
<u>I-2^a, I-4</u>	<u>All</u>	<u>Not Permitted</u>	<u>0</u>
<u>I-1, I-3</u>	<u>All</u>	<u>Not Permitted</u>	<u>1^b</u>

1305.1018.6, IBC Section 1018.6 Corridor Continuity, is amended to read as follows:

IBC Section 1018.6 Corridor continuity. Fire-resistance-rated *corridors* shall be continuous from the point of entry to an *exit*, and shall not be interrupted by intervening rooms. When the path of egress travel within a fire-resistance-rated *corridor* to the exit includes travel along unenclosed *exit access stairways* or *ramps*, the fire resistance-rating shall be continuous for the length of the *stairway* or *ramp* and for the length of the connecting *corridor* on the adjacent floors leading to the exit.

Exceptions: 1. Foyers, lobbies or reception rooms constructed as required for corridors shall not be construed as intervening rooms so long as the aggregate area of such spaces does not exceed 1000 sq.ft. per floor.

2. Spaces constructed as required for corridors shall be permitted to be open to a corridor, only where all the following criteria are met:

a. The spaces are not occupied as a *dwelling units, sleeping units, incidental use or hazardous uses.*

b. The open space and corridor is protected by an *automatic smoke detection system* that initiates alarm notification devices in all normally occupied spaces that utilize the corridor for their *means of egress.*

c. The space is arranged so as not to obstruct access to the required *exits.*

d.* The space is not within a nonsprinklered group R occupancy.

Comment [PH168]: 5/18/16 This new amendment was approved by the advisory committee

Comment [PH169]: 5/18/12 This part of the exception will only be added if group R occupancies will not be sprinkled. Waiting for info ?????

1305.1022 SECTION 1022, INTERIOR EXIT STAIRWAYS AND RAMPS

1305.1022.5, IBC Section 1022.5 Penetrations, is amended to read as follows:

1022.5 Penetrations. Penetrations into and openings through *interior exit stairways* and *ramps* are prohibited except for required *exit* doors, equipment and ductwork necessary for independent ventilation or pressurization, sprinkler piping, standpipes, electrical raceway for fire department communications systems and electrical raceway serving the *interior exit stairway* or *ramp* and terminating at a steel box not exceeding 16 square inches (0.010m²). Such penetrations shall be protected in accordance with Section 714. There shall be no penetrations or communicating openings, whether protected or not, between adjacent *interior exit stairways* and *ramps*.

Exception: Membrane penetrations shall be permitted on the outside of the *interior exit stairway* and *ramp*. Such penetrations shall be protected in accordance with Section 714.3.2.

Comment [PH170]: This new amendment was approved by the IBC Advisory Committee

1305.1023 SECTION 1023 EXIT PASSAGEWAYS

1305.1023.6, IBC Section 1023.6 Penetrations, is amended to read as follows:

1023.6 Penetrations.

Penetrations into and openings through an *exit passageway* are prohibited except for required *exit doors, equipment and ductwork necessary for independent pressurization, sprinkler piping, standpipes, electrical raceway for fire department communication and electrical raceway serving the exit passageway and terminating at a steel box not exceeding 16 square inches (0.010m2).* Such penetrations shall be protected in accordance with Section 714. There shall be no penetrations or communicating openings, whether protected or not, between adjacent *exit passageways.*

~~Exception: Membrane penetrations shall be permitted on the outside of the exit passageway. Such penetrations shall be protected in accordance with Section 714.3.2.~~

Comment [B171]: See proposal 1305-5 on website, approved by 1305 committee.

~~1305.1025~~ **1305.1028 SECTION 1025.1028, ASSEMBLY.**

IBC Section 1025.1.1.1028.1.1. IBC Section ~~1025.1.1~~1028.1.1 is amended to read as follows:

~~1025.1.1~~1028.1.1 Bleachers, grandstands, and folding and telescopic seating, that are not building elements, shall comply with International Code Council (ICC) 300, with the following amendments to ICC 300:

Comment [PH172]: Changed to duplicate 2012 IBC language changes. All ICC 300 provisions verified to comply with 2012 edition.

- a. ICC 300 Section 404.5 is amended by adding an exception as follows:

Exception: Aisles shall not be required to be more than 66 inches (1.676 mm) in width when the following are satisfied:

- 1. the seating area served by such aisles is composed entirely of bleachers;
- 2. the row to row dimension is 28 inches (71 cm) or less; and
- 3. front egress is not limited.

- b. ICC 300 Section 405.1 is amended to read as follows:

Section 405.1 Aisles. The minimum width of aisles shall be in accordance with Section 404.5, but not less than that required by this section. An aisle is not required in seating facilities where all of the following conditions exist:

- 1. Seats are without backrest.
- 2. The rise from row to row does not exceed 6 inches (152 mm) per row.

Exception: Bleachers 55 inches or less in height.

- 3. The row to row spacing does not exceed 28 inches (711 mm) unless the seat boards and footboards are ~~not at~~ the same elevation.

Comment [GN174]: Correction from last code.

4. The number of rows does not exceed 16 rows in height.
5. The first seat board is not more than 12 inches (305 mm) above the ground floor or a cross aisle.

Exception: Bleachers 55 inches or less in height.

6. Seat boards have a continuous flat surface.
 7. Seat boards provide a walking surface with a minimum width of 11 inches (279 mm).
 8. Egress from seating is not restricted by rails, guards, or other obstructions.
- c. ICC 300 Section 405.6 is amended by adding an exception as follows:

3. Aisles serving bleachers in compliance with Section 404.5.

d. ICC 300 Section 408.1 ~~item 1~~ is amended by adding ~~an~~ **second** exception as follows:

Comment [GN175]: Missed from last code

(First exception is numbered as 1.)

2. In accordance with the Minnesota Bleacher Safety Act, Minnesota Statutes, section ~~16B.616326B.112~~:

- (a) bleachers must have vertical perimeter guards or other approved guards that address climbability and are designed to prevent accidents; and
- (b) guards are not required on bleachers 55 inches (1397 mm) and less in height.

e. ICC 300 Section 408.3 is amended to read as follows:

408.3 Guard design. Guards and their attachment shall be designed to resist the loads indicated in Section 303. Bleachers must have vertical perimeter guards or other approved guards that address climbability and are designed to prevent accidents, in accordance with the Minnesota Bleacher Safety Act, Minnesota Statutes, section ~~16B.616326B.112~~.

f. ICC 300 Chapter 5 is deleted and replaced with the following:

All bleachers or bleacher open spaces over 55 inches (1397 mm) above grade or the floor below, and all bleacher guardrails, if any part of the guardrail is over 30 inches (762 mm) above grade or the floor below, must be certified to conform with the safety requirements contained in Minnesota Statutes, section ~~16B.616326B.112~~.

~~1305. 1026 SECTION 1026, EMERGENCY ESCAPE AND RESCUE.~~

~~IBC Section 1026.1 is amended to read as follows:~~

Formatted: Indent: First line: 0"

~~**1026.1 General.** In addition to the means of egress required by this chapter, provisions shall be made for emergency escape and rescue in Group R as applicable in Section 101.2 and Group I-1 occupancies. Basements and sleeping rooms below the fourth story above grade plane shall have~~

~~at least one exterior emergency escape and rescue opening in accordance with this section. Where basements contain one or more sleeping rooms, emergency egress and rescue openings shall be required in each sleeping room, but shall not be required in adjoining areas of the basement. Such opening shall open directly into a public way, public alley, or to a yard or court that opens to a public way.~~

Comment [PH176]: This section of the code was deleted and changed to section 1029 in the newly formatted 2012 IBC. It was therefore, deleted entirely.

Exceptions:

Formatted: Indent: Left: 0"

~~1. In other than Group R-3 occupancies as applicable in Section 101.2, buildings equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.~~

Formatted: Indent: Left: 0"

~~2. In other than Group R-3 occupancies as applicable in Section 101.2, sleeping rooms provided with a door to a fire resistance rated corridor having access to two remote exits in opposite directions.~~

~~3. The emergency escape and rescue opening is permitted to open onto a balcony within an atrium in accordance with the requirements of Section 404, provided the balcony provides access to an exit and the dwelling unit or sleeping unit has a means of egress that is not open to the atrium.~~

~~4. High rise buildings in accordance with Section 403.~~

~~5. Emergency escape and rescue openings are not required from basements or sleeping rooms which have an exit door or exit access door that opens directly into a public way, or to a yard, court, or exterior exit balcony that opens to a public way.~~

Comment [PH177]: Window replacement provisions to be added once worked out in existing building code. All window replacement provisions to be the same in 1305, 1309, 7511 and 1307 Rules.

Comment [GN178]: This will need to be revisited in the event that ALL group R.

Comment [PH179]: This was revised 10/3/12 to essentially duplicate REV 11 by Rich L. Note that the IBC/IFC and IEBC do not use the term "sill" as the IRC does, so there is no need to have a definition of that term or to use that word in this amendment.

~~6. Basements without habitable spaces and having no more than 200 square feet (18.6 m²) in floor area shall not be required to have emergency escape windows.~~

Formatted: Font: Bold

Formatted: Indent: First line: 0.25"

Formatted: Font: 12 pt

Formatted: Justified, Right: -0.44", Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5"

Formatted: Font: 12 pt, No underline

Formatted: Font: 12 pt

Formatted: Justified, Right: -0.44"

Formatted: Justified, Numbered + Level: 1 + Numbering Style: 1, 2, 3, ... + Start at: 1 + Alignment: Left + Aligned at: 0.25" + Indent at: 0.5", Adjust space between Latin and Asian text, Adjust space between Asian text and numbers

1305.1029 SECTION 1029 EMERGENCY ESCAPE AND RESCUE

IBC Section 1029 is amended by adding the following subsection to read as follows:

1305.1029.6 Replacement windows. Replacement windows shall be exempt from the minimum size and maximum height requirements of Sections 1029.2, 1029.2.1, and 1029.3 if the replacement window meets the following conditions:

- The replacement window is the manufacturer's largest standard size window that will fit within the existing frame or existing rough opening. The replacement window shall be permitted to be of the same operating style as the existing window or a style that provides for an equal or greater window opening area than the existing window;
- Building uses that are required to be licensed or registered by the State of Minnesota shall have emergency escape and rescue replacement windows installed to comply with the

requirements of the agency that licenses or registers the use, or the provisions of part 1305.1029.6, whichever is more restrictive.

Formatted: Font: Not Bold, No underline

1305.1101 SECTION 1101, GENERAL.

IBC Section 1101.1 is amended to read as follows:

1101.1 General. Buildings or portions of buildings shall be accessible to persons with disabilities as required by Minnesota Rules, chapter 1341. Refer to Minnesota Rules, chapter 1341, the Minnesota Accessibility Code, for the complete application of IBC Chapter 11.

1305.1200 [Repealed, 19 SR 1340]

1305.1202 [Repealed, 31 SR 1165]

1305.1203 SECTION 1203, VENTILATION.

IBC Section 1203.1 is amended to read as follows:

1203.1 General. Buildings shall be provided with natural ventilation in accordance with Section 1203.4 or mechanical ventilation in accordance with Minnesota Rules, chapter 1346.

Exceptions:

1. Buildings or portions thereof that are not intended for normal human occupancy, or where the primary purpose is not associated with human comfort.
2. Group U occupancies.

Where the air infiltration rate in a dwelling unit is less than 5 air changes per hour when tested with a blower door at a pressure 0.2 inch w.c. (50 Pa) in accordance with Section 402.4.1.2 of the International Energy Conservation Code, the dwelling unit shall be ventilated by mechanical means in accordance with Minnesota Rules, chapter 1346.

Comment [PH180]: Was added in the 2012 IBC as per the new Energy and Mechanical Code – for coordination ?????

1305.1204 [Repealed, 31 SR 1165]

1305.1207 [Repealed, 31 SR 1165]

1305.1209 SECTION 1209, ACCESS TO UNOCCUPIED SPACES.

IBC Section 1209.3 is amended, and subsections added, to read as follows:

1209.3 Mechanical equipment and appliance access. Access to mechanical equipment and appliances installed in underfloor areas, in attic spaces, and on roofs or elevated structures shall be in accordance with this section and the Minnesota Mechanical Code.

1209.3.1 Mechanical equipment and appliances on roofs or elevated structures. Where mechanical equipment or appliances requiring periodic inspection, service, or maintenance are installed on roofs or elevated structures, a permanent stair shall be provided for access.

Exception: A portable ladder may be used for dwellings, replacement equipment on existing buildings, and exterior roof access points not exceeding 16 feet (4.9 m) above grade, unless the building official determines that the unique shape of the roof does not allow safe access with a portable ladder.

The permanent stair shall be as required by relevant safety regulations, but shall not be less than the following:

1. The stair shall be installed at an angle of not more than 60 degrees measured from the horizontal plane.

2. The stair shall have flat treads at least six inches (152 mm) deep and a clear width of at least 18 inches (457 mm) with equally spaced risers at least 10.5 inches (267 mm) high and not exceeding 14 inches (356 mm).

3. The stair shall have intermediate landings not exceeding 18 feet (5.5 m) vertically.

4. Continuous handrails shall be installed on both sides of the stair.

5. Interior stairs shall terminate at the ~~under side~~underside of the roof at a hatch or scuttle of at least eight square feet (0.74m²) with a minimum dimension of 20 inches (508 mm).

6. When a roof access hatch or scuttle is located within ten feet (3.0 m) of a roof edge, a guard shall be installed in accordance with this code.

7. Exterior stairs shall terminate at the roof access point or at a level landing of at least eight square feet (0.74m²) with a minimum dimension of 20 inches (508 mm). The landing shall have a guard installed in accordance with IMC Section 304.9.

1209.3.1.1 Permanent ladders. Where a change in roof elevation greater than 30 inches (762 mm) but not exceeding 16 feet (4.9 m) exists, a permanent ladder shall be provided. The ladder may be vertical and shall be as required by relevant safety regulations, but shall not be less than the following:

1. Width shall be at least 16 inches (406 mm).

2. Rung spacing shall be a maximum of 14 inches (356 mm).

3. Toe space shall be at least six inches (152 mm).

4. Side railings shall extend at least 30 inches (762 mm) above the roof or parapet wall.

1305.1210 SECTION 1210, SURROUNDING MATERIALS.

IBC Section 1210.1 is amended to read as follows:

~~1210.1 Floors.~~ **1210.2.1 Floors and wall bases.** In other than dwelling units, toilet, bathing and shower, and bathing room floors finish material shall have a smooth, hard, nonabsorbent surface, such as portland cement, concrete, ceramic tile, sheet vinyl, or other approved floor covering material. The intersections of such floors with walls shall have a smooth hard nonabsorbent vertical base that extends upward onto the walls at least 54 inches (127 mm).

Comment [PH181]: Carryover of existing amendment with new 2012 IBC language.

1305.1300 [Repealed, 19 SR 1340]

1305.1350 [Repealed, 19 SR 1340]

1305.1355 [Repealed, 11 SR 1405]

1305.1370 [Repealed, 19 SR 1340]

1305.1400 [Repealed, 19 SR 1340]

1305.1403 PERFORMANCE REQUIREMENTS.

~~1305.1403.5. Section 1403.5 Vertical and Lateral Flame Propagation, is deleted entirely.~~

~~1403.5 Vertical and Lateral Flame Propagation. Exterior walls on buildings of Type I, II, III or IV construction that are greater than 40 feet (12 192 mm) in height above grade plane and contain a combustible water resistive barrier shall be tested in accordance with and comply with the acceptance criteria of NFPA 285.~~

Formatted: Strikethrough

Comment [PH182]: This new amendment has been approved by the IBC Advisory Committee. This entire section is to be deleted.

Formatted: Strikethrough

Formatted: Strikethrough

1305.1404 [Repealed, 31 SR 1165]

1305.1405 SECTION 1405, INSTALLATION OF WALL COVERINGS.

Subpart 1. Section ~~1405.3.2~~ **1405.4.2.** IBC Section ~~1405.3.2~~ **1405.4.2** is amended to read as follows:

~~1405.3.2~~ **1405.4.2 Masonry.** Flashing and weepholes in anchored veneer shall be located above finished ground level above the foundation wall or slab, and other points of support, including structural floors, shelf angles and lintels where anchored veneers are designed in accordance with Section ~~1405.5.~~ 1405.4.6.

Comment [PH183]: General IBC language modification and new reference to reformatted code section (an existing amendment).

Subp. 2. **Repealed, 31 SR 1165**

1305.1500 [Repealed, 19 SR 1340]

1305.1502 SECTION 1502, DEFINITIONS.

~~IBC Section 1502.1 is amended by modifying the definition of "Roof Covering" to read as follows:~~

~~**ROOF COVERING.** The covering applied to the roof deck for weather resistance, fire classification or appearance. Roof covering materials consist of two basic types: (1) roofing systems, and (2) prepared materials.~~

Comment [PH184]: Moved to IBC Chapter 2 where all definition are now found – due to code reformat.

1305.1503 SECTION 1503, WEATHER PROTECTION.

Subpart 1. **IBC Section 1503.4.** IBC Section 1503.4 is amended to read as follows:

1503.4 Roof drainage. Design and installation of roof drainage systems shall comply with Minnesota Rules, chapter 4715, Minnesota Plumbing Code, and the following provisions:

1. Where required. All roofs shall drain into a separate storm sewer system or to an approved place of disposal. For one and two family dwellings, and where approved, storm water is permitted to discharge onto flat areas, such as streets or lawns, provided that the storm water flows away from the building.

2. Roof design. Roofs shall be designed for the maximum possible depth of water that will pond thereon as determined by the relative levels of roof deck and overflow weirs, scuppers, edges, or serviceable drains in combination with the deflected structural elements. In determining the maximum possible depth of water, all primary roof drainage means shall be assumed to be blocked.

3. Secondary drainage required. Secondary (emergency) roof drains or scuppers shall be provided where the roof perimeter construction extends above the roof in such a manner that water will be entrapped if the primary drains allow buildup for any reason.

4. Separate systems required. Secondary (emergency) roof drain systems shall have piping and point of discharge separate from the primary system. Discharge shall be above grade in a location which would normally be observed by the building occupants or maintenance personnel.

5. Sizing of secondary drains. Secondary (emergency) roof drain systems shall be sized in accordance with the Minnesota State Plumbing Code. Scuppers shall be sized to prevent the depth of ponding water from exceeding that for which the roof was designed as determined by this code. Scuppers shall not have an opening dimension of less than 4 inches (102 mm). The flow through the primary system shall not be considered when sizing the secondary roof drainage system.

Comment [PH185]: CCLD Plumbing Unit should also review all for coordination with Plumbing Code

Subp. 2. **IBC Section 1503.4.1.** IBC Section 1503.4.1 is deleted in its entirety.

~~1305.1505 FIRE CLASSIFICATION:~~

~~IBC Table 1505.1 is amended by deleting footnote "a" from the table.~~

Comment [GN186]: Footnote referencing

1305.1506 [Repealed, 27 SR 1474]

1305.1507 SECTION 1507, REQUIREMENTS FOR ROOF COVERINGS.

Subpart 1. **Repealed, 31 SR 1165**

Subp. 2. **Repealed, 31 SR 1165**

Subp. 3. **Repealed, 31 SR 1165**

Subp. 4. **Repealed, 31 SR 1165**

Subp. 5. **Section 1507.10.1.** IBC Section 1507.10.1 is amended to read as follows:

1507.10.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, built-up roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage, except for coal-tar built-up roofs that shall have a design slope of a minimum one-eighth unit vertical in 12 units horizontal (1-percent slope).

Subp. 6. **Section 1507.11.1.** IBC Section 1507.11.1 is amended to read as follows:

1507.11.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, modified bitumen membrane roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage.

Subp. 7. **Section 1507.12.1.** IBC Section 1507.12.1 is amended to read as follows:

1507.12.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, thermoset single-ply membrane roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage.

Subp. 8. **Section 1507.13.1.** IBC Section 1507.13.1 is amended to read as follows:

1507.13.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, thermoplastic single-ply membrane roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage.

Subp. 9. **Section 1507.14.1.** IBC Section 1507.14.1 is amended to read as follows:

1507.14.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, sprayed polyurethane foam roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage.

Subp. 10. **Section 1507.15.1.** IBC Section 1507.15.1 is amended to read as follows:

1507.15.1 Slope. Unless designed for water accumulation in accordance with Section 1611.2, liquid-applied roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope).

1305.1509 SECTION 1509, ROOFTOP STRUCTURES.

IBC Section ~~1509.2~~1509.2.3 is amended to read as follows:

~~1509.2 Penthouses~~**1509.2.3 Use limitations.** A penthouse or other projection above the roof in structures of other than Type I construction shall not exceed 28 feet (8534 mm) above the roof where used as an enclosure for tanks or for elevators that run to the roof and in all other cases shall not extend more than 18 feet (5486 mm) above the roof. The aggregate area of penthouses and other rooftop structures shall not exceed one third the area of the supporting roof. A ~~p~~Penthouse, bulkhead, or any other similar projection above the roof shall not be used for purposes other than shelter of mechanical or electrical equipment, tanks, or ~~shelter of~~ vertical shaft openings in the roof assembly.

Exception: Accessory uses necessary for the maintenance of building systems shall be permitted when the penthouse is sprinkled in accordance with section 903.1.1.

~~Provisions such as louvers, louver blades, or flashing shall be made to protect the mechanical equipment and the building interior from the elements. Penthouses or bulkheads used for purposes other than permitted by this section shall conform to the requirements of this code for an additional story. The restrictions of this section shall not prohibit the placing of wood flagpoles or similar structures on the roof of any building.~~

Comment [GN187]: IBC now uses 18 feet.

1305.1510 SECTION 1510, REROOFING.

IBC Section 1510.5 is amended to read as follows:

1510.5 Reinstallation of materials. Existing slate, clay or cement tile shall be permitted for reinstallation, except that damaged, cracked or broken slate or tile shall not be reinstalled. Existing vent flashing, metal edging, drain outlets, collars and metal counterflashings shall not be reinstalled where rusted, damaged or deteriorated. Aggregate surfacing materials shall not be reinstalled unless such aggregate complies with the gradation requirements of ASTM C-33 Standard Specification for Concrete Aggregate.

1305.1590 [Repealed, 19 SR 1340]

1305.1600 [Repealed, 19 SR 1340]

1305.1604 [Repealed, 31 SR1165]

1305.1607 SECTION 1607, LIVE LOADS.

Subpart 1. **Repealed, 31 SR 1165**

Subp. 2. **Section 1607.1342.2.** IBC Section 1607.1342.2 is amended to read as follows:

1607.1342.2 Vertical impact force. The maximum wheel loads of the crane shall be increased by the percentages shown below to determine the induced vertical impact or vibration force. Impact load shall be applied to one hoist system at a time for multiple hoist or bridge systems.

Monorails, underhung bridge cranes and pendant operated top running bridge cranes:

15 percent minimum for hoist lift speeds of less than 30 feet per minute.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Percentage equivalent to 0.5 times the hoist lift speed, for lift speeds of 30 to 100 feet per minute.

50 percent maximum for hoist lift speeds greater than 100 feet per minute.

50 percent for magnetic pickup or vacuum lift type systems.

No impact load is required for hand chain (non-powered) hoists.

Cab operated or remotely operated top running bridge cranes:

25 percent minimum.

Subp. 3. **Section 1607.1342.3.** IBC Section 1607.1342.3 is amended to read as follows:

1607.1342.3 Lateral force.

Top running powered bridge cranes. The lateral force on top running crane runway beams with powered trolleys shall be calculated as 20 percent of the sum of the rated capacity of the crane and the weight of the hoist and trolley. The lateral force shall be assumed to act horizontally at the traction surface of a runway beam, in either direction perpendicular to the beam, and shall be distributed according to the lateral stiffness of the runway beam and supporting structure. The runway beams shall be designed for the lateral and torsional loads, as well as for the maximum lateral deflection limit of Span/800.

Monorails and underhung bridge cranes.

The bridge girder, underhung bridge crane runway beam and monorails shall be designed with sufficient strength and rigidity to prevent detrimental lateral deflection.

The lateral deflection should not exceed span/800 based on 5 percent of maximum wheel load(s) without vertical impact factor.

1305.1608 SECTION 1608, SNOW LOADS.

Subpart 1. **Section 1608.2.** IBC Section 1608.2 is amended to read as follows:

1608.2 Ground snow loads. The ground snow loads to be used in determining the design snow loads for buildings and other structures are given in Minnesota Rules, chapter 1303.

Subp. 2. **Figure 1608.2.** IBC Figure 1608.2 on GROUND SNOW LOADS, pg, FOR THE UNITED STATES (PSF) is deleted.

Subp. 3. **Repealed, 31 SR 1165**

1305.1614 [Renumbered 1305.1616]

1305.1616 [Renumbered 1305.1618]

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

1305.1616 [Repealed, 27 SR 1474]

1305.1618 [Repealed, 27 SR 1474]

1305.1623 [Renumbered 1305.1625]

1305.1625 [Repealed, 27 SR 1474]

1305.1700 [Repealed, 19 SR 1340]

1305.1701 [Repealed, 27 SR 1474]

1305.1702 [Repealed.] SECTION 1702, DEFINITIONS.

Formatted: Strikethrough

The definition of "approved agency" in IBC Section 1702.1 is amended to read as follows:

~~APPROVED AGENCY. An established and recognized agency regularly engaged in conducting tests or furnishing inspection services, when such agency has been approved. The structural engineer of record, that engineer's employee or that engineer's agent may conduct tests or furnish inspection services for types of work for which the engineer, employee, or agent is qualified.~~

1305.1705~~1704~~ SECTION 1705~~1704~~, REQUIRED VERIFICATION AND INSPECTION SPECIAL INSPECTIONS.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Subpart 1. Repealed, 31 SR 1165

Subp. 2. Table 1705.34.4. IBC Table 1705.34.4 is amended as follows:

Formatted: Strikethrough

Formatted: Strikethrough

A. Add "X^{cb}" to the "Periodic" column, row "76. Inspection of concrete and shotcrete placement for proper application techniques."

Formatted: Superscript

Formatted: Strikethrough

B. Add footnote "cb." to read as follows:

Formatted: Strikethrough

Formatted: Strikethrough

cb. Exception: Periodic verification and inspection is permitted, upon approval of inspection can be periodic when acceptable to the structural engineer of record and the building official.

Formatted: Strikethrough

Formatted: Strikethrough

Subp. 3. Repealed, 31 SR 1165

Subp. 4. Table 1704.5.1. IBC Table 1704.5.1, is amended as follows:

Formatted: Strikethrough

A. Add "X^b" to the "Periodically during task listed" column, row "4. Grout placement shall be verified to ensure compliance with code and construction document provisions."

B. Add footnote "b." to read as follows:

b. ~~Exception: Inspection can be periodic when acceptable to the structural engineer of record and the building official.~~

Subp. 4. Section 1705.4 Masonry construction. Add the following sentence to the end of the section:

“Periodic verification and inspection of grout placement is permitted, upon approval of the structural engineer of record and the building official.”

1305.1750 [Repealed, 19 SR 1340]

1305.1775 [Repealed, 19 SR 1340]

1305.1790 [Repealed, 15 SR 74]

1305.1795 [Repealed, 19 SR 1340]

1305.1800 [Repealed, 19 SR 1340]

1305.1805 SECTION 1805, FOOTINGS AND FOUNDATIONS.

Subpart 1. **Repealed, 31 SR 1165**

Subp. 2. **Repealed, 31 SR 1165**

Subp. 3. **Repealed, 31 SR 1165**

Subp. 4. **IBC Section 1805.2. [Repealed, 1]** ~~IBC Section 1805.2 is amended to read as follows:~~

Formatted: Strikethrough

~~**1805.2 Depth of footings.** The minimum depth of footings below the undisturbed ground surface shall be in accordance with Minnesota Rules, part 1303.1600. Where applicable, the depth of footings shall also conform to Sections 1805.2.1 through 1805.2.3.~~

Subp. 5. **IBC Section 1809.5.2.1.** IBC Section 1809.5.2.1 is amended to read as follows:

Formatted: Strikethrough

~~**1809.5.2.1 Frost protection.** Except where otherwise protected from frost, foundations, walls, piers, and other permanent supports of buildings and structures shall be protected from frost by one or more of the following methods:~~

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

1. Extending below the frost line specified ~~The minimum allowable footing depth shall be in accordance with Minnesota Rules, part 1303.1600;~~

Formatted: Strikethrough

Formatted: Strikethrough

2. Constructing in accordance with ASCE 32; or

3. Erecting on solid rock.

Exception: Freestanding buildings meeting ~~all of the following conditions shall not be required to be protected:~~

Formatted: Strikethrough

Formatted: Strikethrough

1. ~~Constructing in accordance with chapter 1303, Classified in Occupancy Category I in accordance with Section 1604.5;~~

Formatted: Strikethrough

2. ~~Area of 600 square feet (56 m²) or less for light frame construction or 400 square feet (37 m²) or less for other than light frame; and~~

3. ~~Eave height of 10 feet (3,048 mm) or less.~~

~~Shallow foundations~~ Footings shall not bear on frozen soil, ~~unless such frozen condition is of a permanent character.~~

Formatted: Strikethrough

Formatted: Strikethrough

1305.1806 [Repealed, 31 SR 1165]

~~1305.1807~~ ~~1305.1805~~ **SECTION** ~~1807~~ ~~1805~~, **DAMPPROOFING AND WATERPROOFING.**

IBC Section ~~1807.4.3~~ ~~1805.4.3~~ is amended to read as follows:

Comment [PH188]: Change of numbering due reformat of 2012 IBC. Existing amendment stays as is without change.

~~1807.4.3~~ ~~1805.4.3~~ **Drain discharge.** The floor base and foundation perimeter drain shall discharge by gravity or mechanical means into a trapped area drain, sump, dry well, or other approved location above the ground.

1305.1900 [Repealed, 19 SR 1340]

~~1305.1907 [Repealed, SECTION 1907, DETAILS OF REINFORCEMENT.~~

Formatted: Strikethrough

IBC Section ~~1907.7.5~~ is amended to read as follows:

~~1907.7.5 Corrosive environments.~~ In corrosive environments or other severe exposure conditions, the amount of concrete protection shall be suitably increased, and denseness and nonporosity of protecting concrete shall be considered, or other protection shall be provided. In corrosive environments of parking garages and parking ramps, industrial buildings, or similar environments, a minimum concrete cover of reinforcement steel must be two inches (50.8 mm) for top surfaces and three quarter inch (19.05 mm) for bottom surfaces. All bonded reinforcement steel located within the depth of the slab must be epoxy coated in conformance with the applicable standards referenced in ACI 318 Sections 3.5.3.7 and 3.5.3.8.

1305.1918 [Repealed, 27 SR 1474]

1305.1928 [Repealed, 27 SR 1474]

1305.2000 [Repealed, 19 SR 1340]

1305.2050 [Repealed, 19 SR 1340]

1305.2100 [Repealed, 15 SR 74]

1305.2109 [Repealed, SECTION 2109, EMPIRICAL DESIGN OF MASONRY.]

Formatted: Strikethrough

IBC Table 2109.4.1 is amended to read as follows:

**TABLE 2109.4.1
WALL LATERAL SUPPORT REQUIREMENTS**

Construction	Maximum Wall Length to Thickness or Wall Height to Thickness
Bearing walls	
Solid units or fully grouted	20
All others	18
Nonbearing walls	
Exterior	18
Interior	28

1305.2200 [Repealed, 19 SR 1340]

1305.2300 [Repealed, 19 SR 1340]

1305.2304 [Repealed, 31 SR 1165]

1305.2308 SECTION 2308, CONVENTIONAL LIGHT FRAME CONSTRUCTION.

Subpart 1. **IBC Figure 2308.9.3.** The table to IBC Figure 2308.9.3, Basic Components of the Lateral Bracing System, is amended to read as follows:

Wind Speed	Maximum Wall Spacing (Feet)	Required Bracketing Length^b
90 mph	35'0"	Table 2308.9.3.(1) and Section 2308.9.3

(IBC Figure 2308.9.3 is changed to reflect amendments in table.)

Subp. 2. **IBC Table 2308.9.3(1).** IBC Table 2308.9.3(1), Braced Wall Panels, is amended to read as follows:

TABLE 2308.9.3(1)
BRACED WALL PANELS^a

Wind Speed	Condition	Construction Methods ^{b,c}								Braced Panel Location and Length ^d
		1	2	3	4	5	6	7	8	
	One story, top of two or three story	X	X	X	X	X	X	X	X	Located in accordance with section 2308.9.3 and not more than 25 feet on center
90 mph	First story of two story or second story of three story	X	X	X	X	X	X	X	X	
	First story of three story	X	X	X	X ^e	X	X	X	X	

For SI: 1 inch = 25.4 mm, 1 foot = 304.8 mm

^aThis table specifies minimum requirements for braced panels that form interior or exterior braced wall lines.

^bSee Section 2308.9.3 for full description.

^cSee Sections 2308.9.3.1 and 2308.9.3.2 for alternative braced panel requirements.

^dBuilding length is the dimension parallel to the braced wall length.

^eGypsum wallboard applied to framing supports that are spaced at 16 inches on center.

1305.2320 [Repealed, 27 SR 1474]

1305.2326 [Renumbered 1305.2320]

1305.2400 [Repealed, 15 SR 74]

1305.2500 [Repealed, 19 SR 1340]

1305.2510 SECTION 2510 LATHING AND FURRING FOR CEMENT PLASTER (STUCCO)

IBC Section 2510.6 is amended as follows:

2510.6 Water-resistive barriers. *Water-resistive barriers shall be installed as required in Section 1404.2 and, where applied over wood-based sheathing, shall include a water resistive vapor-permeable barrier with a performance at least equivalent to two layers of Grade D paper. The individual layers shall be installed independently such that each layer provides a separate continuous plane and any flashing (installed in accordance with Section 1405.4) intended to drain to the water resistive barrier is directed between the layers.*

Comment [GN189]: To be proposed by Dan Kelsey's structural committee.

Comment [B190R189]: Section is unchanged from previous amendment per Dan Kelsey.

Formatted: Indent: First line: 0.25"

Comment [B191]: See proposal 1305-8 on website, approved by 1305 committee.

Exception: where the *water-resistive barrier* that is applied over wood-based sheathing has a water resistance equal or greater than that of 60-minute Grade D paper and is separated from the stucco by an intervening, substantially nonwater-absorbing layer or drainage space.

1305.2600 [Repealed, 19 SR 1340]

1305.2603 SECTION 2603 FOAM PLASTIC INSULATION.

IBC Section 2603.4.1.13 is amended to read as follows:

2603.4.1.13 Type V construction. Foam plastic spray applied to a sill plate and header of Type V construction is subject to all of the following:

1. The maximum thickness of the foam plastic shall be 5 1/2 inches (82.6 mm).
2. The foam plastic shall have a flame spread index of 25 or less and an accompanying smoke developed index of 450 or less when tested in accordance with ASTM E84.

IBC Section 2603.5.5 is revised by adding exception number two and renumbering the exceptions as follows:

IBC Section 2603.5.5 Vertical and lateral fire propagation. The exterior wall assembly shall be tested in accordance with and comply with the acceptance criteria of NFPA 285.

Exceptions:

1. One-story buildings complying with Section 2603.4.1.4.
2. In other than high rise buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, foam plastic insulation may be installed in compliance with the following conditions:
 - a) The foam plastic insulation shall be applied between a continuous masonry or non-combustible exterior wall sheathing on the building side and a continuous non-combustible substrate or fire resistant treated plywood barrier on the exterior side of the foam plastic insulation.
 - b) Foam insulation shall be limited to a maximum of 3" thickness.
 - c) Wall claddings permitted by this code may be applied to the outside of the exterior substrate barrier.
 - d) Continuous fire blocking shall be provided around all opening head, jamb and sill conditions between continuous masonry or non-combustible exterior wall sheathing on the building side and a continuous substrate barrier on the exterior side of the foam plastic insulation.
 - e) Continuous horizontal metal furring, minimum 16 gauge without perforations, shall be provided at each floor, in line with the slab edge containment fire stopping creating a fire break spanning between the masonry or non-combustible wall sheathing on the building side and a non-combustible substrate barrier on the exterior side of the foam plastic insulation.

Formatted: Font: Not Italic, Underline, Font color: Black

Formatted: Underline, Font color: Black

Comment [PH192]: This provision was approved at the June 20th ACM.

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

Formatted: Underline, Font color: Black

Formatted: Font color: Black

1305.2700 [Repealed, 19 SR 1340]

1305.2702 SECTION 2702, EMERGENCY AND STANDBY POWER SYSTEMS.

IBC Section 2702.1 is amended to read as follows:

2702.1 Installation. Emergency and standby power systems shall be installed in accordance with Minnesota Rules, chapter 1315.

1305.2800 [Repealed, 19 SR 1340]

1305.2900 [Repealed, 19 SR 1340]

1305.2902 SECTION 2902, MINIMUM PLUMBING FACILITIES.

Subpart 1. **Section 2902.1.** IBC Section 2902.1 is amended to read as follows:

2902.1 Minimum number of fixtures. Plumbing fixtures shall be provided for the type of occupancy and in the minimum number shown in Table 2902.1. Types of occupancies not shown in Table 2902.1 shall be considered individually by the building official. The number of occupants shall be determined by this code. Occupancy classification shall be determined in accordance with Chapter 3.

Exception: When approved by the building official, buildings or structures that are normally unoccupied, such as picnic shelters, amphitheaters, small transit stop stations, cold storage buildings, utility sheds, warming houses, kiosks, concession stands and similar structures, need not be provided with restroom facilities.

Subp. 1a. **Section ~~2902.1.1~~2902.1.2.** IBC Section ~~2902.1.1~~2902.1.2 is amended to read as follows:

~~2902.1.1~~2902.1.2 Unisex toilet and Family or assisted-assisted-use toilet and bath fixtures. Fixtures located within ~~unisex~~family or ~~assisted~~assisted-use toilet and bathing rooms complying with Minnesota Rules, chapter 1341, are permitted to be included in determining the minimum required number of fixtures for either the male or female occupants.

Comment [GN193]: PC term for unisex.

Subp. 2. **Table 2902.1.**

A. The body of IBC Table 2902.1 is amended as follows:

1. Add footnote "eh" to the A 5 Use Group "Stadiums, amusement parks, bleachers, and grandstands for outdoor sporting events and activities" description of the table.
2. Add footnotes "f," "gi," and "hj" to the "Drinking Fountains" heading in the table.
3. Add footnote "ik" to the "Water Closets" heading in the table.

B. The footnotes to IBC Table 2902.1 are amended, and footnotes added, to read as follows:

a. The fixtures shown are based on one fixture being the minimum required for the number of persons indicated or any fraction of the number of persons indicated. The number of occupants shall be determined by this code.

b. Toilet facilities for employees shall be separate from facilities for inmates or ~~patients~~ ~~care recipients~~.

Comment [GN194]: New IBC term for patients.

c. A single occupant toilet room with one water closet and one lavatory serving not more than two adjacent patient rooms shall be permitted where such room is provided with direct access from each patient room and with provisions for privacy.

d. The occupant load for seasonal outdoor seating and entertainment areas shall be included when determining the minimum number of facilities required.

~~eh~~. Permanent facilities located either on site or available in an adjacent building or portable temporary facilities available on site during times when the stadium or grandstand is in use may be used.

f. A drinking fountain shall not be required ~~for in buildings or tenant spaces having~~ an occupant load less than 50.

Comment [GN195]: IBC now has exception however it is for 15 or less.

~~gi~~. Where water is served in restaurants, drinking fountains shall not be required.

~~hj~~. Water or other beverages available through free or fee based serving or dispensers may be substituted for up to 50 percent of the required number of drinking fountains.

~~ik~~. In each bathroom or toilet room, urinals shall not be substituted for more than 67 percent of the required water closets.

Subp. 3. **Section 2902.2.** IBC Section 2902.2 is amended to read as follows:

2902.2 Separate facilities. Where plumbing fixtures are required, separate facilities shall be provided for each sex.

Exceptions:

1. Separate facilities shall not be required for dwelling units and sleeping units.

2. Separate facilities shall not be required in structures or tenant spaces with a total occupant load, including both employees and customers, of ~~15~~ ~~20~~ or less.

Comment [PH196]: Per June 20th ACM

Formatted: Font color: Red, Strikethrough

3. Separate facilities shall not be required in mercantile occupancies in which the maximum occupant load is ~~50~~ ~~100~~ or less.

Comment [GN197]: IBC Changed from 50 to 100.

~~4. Separate facilities shall not be required in Group B occupancies not exceeding 2,000 gross square feet (185.8 m²) of floor area. When using this exception, the individual unisex restroom, family or assisted use toilet facility shall have not less than one watercloset, one urinal, and one lavatory.~~

Formatted: Font color: Red, Strikethrough

Comment [PH198]: Delete exception number 4 entirely (per June 20th ACM)

Formatted: Font color: Red, Strikethrough

Comment [GN199]: PC word for unisex.

Formatted: Font color: Red, Strikethrough

Formatted: Font color: Red, Strikethrough

Subp. 4. **Section 2902.** IBC Section 2902 is amended by adding a subsection to read as follows:

2902.6 Controlled access to required facilities. Sanitation facilities required by this chapter may have controlled access, but in all cases shall be maintained available for utilization by those employees, customers, or patrons used to calculate the minimum required facilities.

1305.3000 [Repealed, 15 SR 74]

1305.3001 [Repealed, 27 SR 1474]

1305.3030 CHAPTER 30, ELEVATORS AND CONVEYING SYSTEMS.

IBC Chapter 30 is deleted and replaced with the following:

CHAPTER 30

ELEVATORS AND CONVEYING SYSTEMS

The design, construction, installation, operation, alteration, and repair of elevators and related devices shall be in accordance with Minnesota Rules, chapter 1307. Refer to Minnesota Rules, chapter 1307, the Minnesota Elevator Code, for the complete application of IBC Chapter 30.

1305.3100 [Repealed, 15 SR 74]

1305.3109 SECTION 3109, SWIMMING POOL ENCLOSURES.

~~IBC Section 3109 Swimming Pool Enclosures and Safety Devices is deleted in its entirety.~~

Comment [PH200]: Modified directive for clarity purposes. Provision/requirements do not change.

1305.3112 SECTION 3112, WINDOW CLEANING BUILDING ANCHORS

Comment [PH201]: Added new window cleaning building anchor amendment per Legislative directive to CCLD per MN Statute.

~~IBC Chapter 31 is amended by adding a new section as follows:~~

3112 WINDOW CLEANING BUILDING ANCHORS

~~**3112.1 General.** Building anchors for window cleaning safety shall be provided for buildings four or more stories above grade plane. Building anchors for window cleaning safety shall be designed, installed and located in accordance with the design criteria of ASI/IWCA I-14.1 2001.~~

Comment [PH202]: Do not use crossed out language. This language was modified as shown in the following submittal.

Exceptions:

- ~~1. Buildings without windows.~~
- ~~2. Existing buildings undergoing reconstruction, alteration or repair that does not include the exposure of primary structural roof components.~~

The commissioner of the Minnesota Department of Labor and Industry may waive all or a portion of the requirements for existing buildings if the installation of the dedicated anchorages would not result in significant safety improvements due to limits on the size of the project, or other factors as determined by the commissioner.

1305.3112 WINDOW CLEANING BUILDING ANCHORS

Comment [PH203]: Use this language !!!

IBC Chapter 31 is amended by adding a new section

IBC Sec. 3112.1 General. Building anchors for window cleaning safety shall be provided for buildings four or more stories above grade plane. Building anchors for window cleaning safety shall be designed, installed and located in accordance with the design criteria of ASI/IWCA I-14.1-2001.

Exceptions:

1. Buildings without windows.
2. Existing buildings undergoing reconstruction, alteration or repair that does not include the exposure of primary structural roof components.
3. The commissioner of the Minnesota Department of Labor and Industry may waive all or a portion of the requirements for existing buildings if the installation of the dedicated anchorages would not result in significant safety improvements due to limits on the size of the project, or other factors as determined by the commissioner.

1305.3200 [Repealed, 15 SR 74]

1305.3300 [Repealed, 15 SR 74]

1305.3302 SECTION 3302, CONSTRUCTION SAFEGUARDS.

IBC Section 3302 is amended by adding a subsection to read as follows:

~~3302.33302.4~~ Construction barriers. Where construction, remodeling, or demolition is taking place involving the use of cutting and welding, temporary heating with open flames, or flammable liquid fueled equipment, such areas shall be separated from occupied areas of a building by materials that will resist the spread of fire and smoke as specified for draftstopping materials in Section ~~717.3.4~~718.3.1.

1305.3305 SECTION 3305, SANITARY.

IBC Section 3305 is deleted.

1305.3400 [Repealed, 19 SR 1340]

1305.3401 CHAPTER 34, EXISTING STRUCTURES.

IBC Chapter 34 is deleted and replaced with the following:

CHAPTER 34
EXISTING STRUCTURES

The standards for a change of occupancy, alteration, and repair of existing buildings and structures with historical significance, shall be in accordance with Minnesota Rules, chapter 1311. Refer to Minnesota Rules, chapter 1311, the Minnesota Building Conservation Code, for the complete application of provisions for existing structures.

1305.3500 CHAPTER 35, REFERENCED STANDARDS.

IBC Chapter 35 is amended by modifying a referenced standard and adding a new reference standard as follows:

NFPA 45 20042011 Standard on Fire Protection for Laboratories Using Chemicals

ANSI/IWCA I-14.1-2001, STANDARD FOR WINDOW CLEANING

1305.3600 [Repealed, 15 SR 74]

1305.3700 [Repealed, 15 SR 74]

1305.3800 [Repealed, 19 SR 1340]

1305.3850 [Repealed, 11 SR 1405]

1305.3860 [Repealed, 19 SR 1340]

1305.3900 [Repealed, 19 SR 1340]

1305.3970 [Repealed, 11 SR 1405]

1305.4000 [Repealed by amendment, 9 SR 1557]

1305.4100 [Repealed, 19 SR 1340]

1305.4200 [Repealed, 15 SR 74]

1305.4300 [Repealed, 11 SR 1405]

1305.4313 [Repealed, 27 SR 1474]

1305.4332 [Repealed, 27 SR 1474]

1305.4415 [Repealed, 27 SR 1474]

Formatted: Font: Bold, Underline

Comment [PH204]: This standard was added as a result of the new window cleaning provision added in IBC Chapter 31 (section 3112).

Formatted: Font: (Default) Times New Roman, Bold, Underline

Formatted: Font: (Default) Times New Roman, Underline

Formatted: Font: (Default) Times New Roman, 12 pt, Not Bold, Underline

Formatted: Font: Not Bold, Underline

Formatted: Left, Don't adjust space between Latin and Asian text, Don't adjust space between Asian text and numbers

Formatted: Font: (Default) Times New Roman, 12 pt, Not Bold, Underline

1305.4416 [Repealed, 27 SR 1474]
1305.4429 [Repealed, 27 SR 1474]
1305.4500 [Repealed, 15 SR 74]
1305.4600 [Repealed, 19 SR 1340]
1305.4700 [Repealed, 19 SR 1340]
1305.4800 [Repealed, 19 SR 1340]
1305.4850 [Repealed, 19 SR 1340]
1305.4900 [Repealed, 15 SR 74]
1305.5000 [Repealed, 11 SR 1405]
1305.5100 [Repealed, 11 SR 1405; 19 SR 1340]
1305.5101 [Renumbered 1307.0010]
1305.5102 [Renumbered 1307.0015]
1305.5103 [Renumbered 1307.0020]
1305.5104 [Renumbered 1307.0025]
1305.5105 [Renumbered 1307.0030]
1305.5106 [Renumbered 1307.0035]
1305.5107 [Renumbered 1307.0040]
1305.5108 [Renumbered 1307.0045]
1305.5109 [Renumbered 1307.0050]
1305.5110 [Renumbered 1307.0055]
1305.5111 [Renumbered 1307.0060]
1305.5112 [Renumbered 1307.0065]
1305.5114 [Renumbered 1307.0070]
1305.5115 [Renumbered 1307.0075]

1305.5116 [Renumbered 1307.0080]
1305.5117 [Renumbered 1307.0085]
1305.5118 [Renumbered 1307.0090]
1305.5200 [Repealed, 19 SR 1340]
1305.5300 [Repealed, 15 SR 74]
1305.5310 [Repealed, 15 SR 74]
1305.5320 [Repealed, 19 SR 1340]
1305.5340 [Repealed, 19 SR 1340]
1305.5360 [Repealed, 19 SR 1340]
1305.5380 [Repealed, 19 SR 1340]
1305.5385 [Repealed, 19 SR 1340]
1305.5400 [Repealed, 19 SR 1340]
1305.5500 [Repealed, 15 SR 74]
1305.5700 [Repealed, 19 SR 1340]
1305.5710 [Repealed, 19 SR 1340]
1305.5720 [Repealed, 19 SR 1340]
1305.5730 [Repealed, 19 SR 1340]
1305.5740 [Repealed, 19 SR 1340]
1305.5750 [Repealed, 19 SR 1340]
1305.5800 [Repealed, 15 SR 74]
1305.5900 [Repealed, 19 SR 1340]
1305.5910 [Repealed, 11 SR 1405]
1305.6000 [Repealed, 19 SR 1340]
1305.6200 [Repealed, 19 SR 1340]

1305.6250 [Repealed, 19 SR 1340]
1305.6260 [Repealed, 11 SR 1405]
1305.6270 [Repealed, 11 SR 1405]
1305.6280 [Repealed, 19 SR 1340]
1305.6300 [Repealed, 19 SR 1340]
1305.6400 [Repealed by amendment, 9 SR 1557]
1305.6425 [Repealed, 19 SR 1340]
1305.6430 [Repealed, 19 SR 1340]
1305.6500 [Repealed by amendment, 9 SR 1557]
1305.6525 [Repealed, 19 SR 1340]
1305.6550 [Repealed, 15 SR 74]
1305.6600 [Repealed, 15 SR 74]
1305.6700 [Repealed, 19 SR 1340]
1305.6800 [Repealed, 19 SR 1340]
1305.6900 [Repealed, 15 SR 74]
1305.6901 [Repealed, 19 SR 1340]
1305.6902 [Repealed, 19 SR 1340]
1305.6905 [Repealed, 19 SR 1340]
1305.6910 [Repealed, 19 SR 1340]
1305.6920 [Repealed, 19 SR 1340]
1305.7000 [Repealed, 27 SR 1474]
1305.7100 [Repealed, 27 SR 1474]
Minn. Rules repealed, etc. in chapter 1305
1305.0010 [Repealed, 27 SR 1474]

1305.0020 [Repealed, 27 SR 1474]
1305.0100 [Repealed, 19 SR 1340]
1305.0102 [Repealed, 27 SR 1474]
1305.0103 [Repealed, 27 SR 1474]
1305.0105 [Repealed, 27 SR 1474]
1305.0106 [Repealed, 27 SR 1474]
1305.0107 [Repealed, 27 SR 1474]
1305.0108 [Repealed, 27 SR 1474]
1305.0109 [Repealed, 27 SR 1474]
1305.0150 [Repealed, 19 SR 1340]
1305.0200 [Repealed, 19 SR 1340]
1305.0300 [Repealed, 15 SR 74]
1305.0301 [Repealed, 27 SR 1474]
1305.0305 [Repealed, 27 SR 1474]
1305.0308 [Repealed, 27 SR 1474]
1305.0400 [Repealed, 19 SR 1340]
1305.0405 [Repealed, 27 SR 1474]
1305.0500 [Repealed, 19 SR 1340]
1305.0600 [Repealed, 19 SR 1340]
1305.0700 [Repealed, 19 SR 1340]
1305.0800 [Repealed, 19 SR 1340]
1305.0900 [Repealed, 19 SR 1340]
1305.0904 [Repealed, 27 SR 1474]
1305.1000 [Repealed, 19 SR 1340]

1305.1000 [Repealed, 27 SR 1474]

1305.1004 [Renumbered 1305.1000, subpart 1]
1305.1009 [Renumbered 1305.1000, subps 3 and 4]
1305.1019 [Renumbered 1305.1000, subp 5]

1305.1100 [Repealed, 19 SR 1340]

1305.1200 [Repealed, 19 SR 1340]

1305.1300 [Repealed, 19 SR 1340]

1305.1350 [Repealed, 19 SR 1340]

1305.1355 [Repealed, 11 SR 1405]

1305.1370 [Repealed, 19 SR 1340]

1305.1400 [Repealed, 19 SR 1340]

1305.1500 [Repealed, 19 SR 1340]

1305.1506 [Repealed, 27 SR 1474]

1305.1590 [Repealed, 19 SR 1340]

1305.1600 [Repealed, 19 SR 1340]

1305.1614 [Renumbered 1305.1616]

1305.1616 [Renumbered 1305.1618]
1305.1616 [Repealed, 27 SR 1474]

1305.1618 [Repealed, 27 SR 1474]

1305.1623 [Renumbered 1305.1625]

1305.1625 [Repealed, 27 SR 1474]

1305.1700 [Repealed, 19 SR 1340]

1305.1701 [Repealed, 27 SR 1474]

1305.1750 [Repealed, 19 SR 1340]

1305.1775 [Repealed, 19 SR 1340]

1305.1790 [Repealed, 15 SR 74]

1305.1795 [Repealed, 19 SR 1340]
1305.1800 [Repealed, 19 SR 1340]
1305.1900 [Repealed, 19 SR 1340]
1305.1918 [Repealed, 27 SR 1474]
1305.1928 [Repealed, 27 SR 1474]
1305.2000 [Repealed, 19 SR 1340]
1305.2050 [Repealed, 19 SR 1340]
1305.2100 [Repealed, 15 SR 74]
1305.2200 [Repealed, 19 SR 1340]
1305.2300 [Repealed, 19 SR 1340]
1305.2320 [Repealed, 27 SR 1474]
1305.2326 [Renumbered 1305.2320]
1305.2400 [Repealed, 15 SR 74]
1305.2500 [Repealed, 19 SR 1340]
1305.2600 [Repealed, 19 SR 1340]
1305.2700 [Repealed, 19 SR 1340]
1305.2800 [Repealed, 19 SR 1340]
1305.2900 [Repealed, 19 SR 1340]
1305.3000 [Repealed, 15 SR 74]
1305.3001 [Repealed, 27 SR 1474]
1305.3100 [Repealed, 15 SR 74]
1305.3200 [Repealed, 15 SR 74]
1305.3300 [Repealed, 15 SR 74]
1305.3400 [Repealed, 19 SR 1340]


1305.3500 [Repealed, 11 SR 1405]
1305.3600 [Repealed, 15 SR 74]

1305.3700 [Repealed, 15 SR 74]

1305.3800 [Repealed, 19 SR 1340]

1305.3850 [Repealed, 11 SR 1405]
1305.3860 [Repealed, 19 SR 1340]
1305.3900 [Repealed, 19 SR 1340]
1305.3970 [Repealed, 11 SR 1405]
1305.4000 [Repealed by amendment, 9 SR 1557]
1305.4100 [Repealed, 19 SR 1340]
1305.4200 [Repealed, 15 SR 74]
1305.4300 [Repealed, 11 SR 1405]
1305.4313 [Repealed, 27 SR 1474]
1305.4332 [Repealed, 27 SR 1474]
1305.4415 [Repealed, 27 SR 1474]
1305.4416 [Repealed, 27 SR 1474]
1305.4429 [Repealed, 27 SR 1474]
1305.4500 [Repealed, 15 SR 74]
1305.4600 [Repealed, 19 SR 1340]
1305.4700 [Repealed, 19 SR 1340]
1305.4800 [Repealed, 19 SR 1340]
1305.4850 [Repealed, 19 SR 1340]
1305.4900 [Repealed, 15 SR 74]
1305.5000 [Repealed, 11 SR 1405]

1305.5100 [Repealed, 11 SR 1405; 19 SR 1340]
1305.5101 [Renumbered 1307.0010]
1305.5102 [Renumbered 1307.0015]
1305.5103 [Renumbered 1307.0020]
1305.5104 [Renumbered 1307.0025]
1305.5105 [Renumbered 1307.0030]
1305.5106 [Renumbered 1307.0035]
1305.5107 [Renumbered 1307.0040]
1305.5108 [Renumbered 1307.0045]
1305.5109 [Renumbered 1307.0050]
1305.5110 [Renumbered 1307.0055]
1305.5111 [Renumbered 1307.0060]
1305.5112 [Renumbered 1307.0065]
1305.5114 [Renumbered 1307.0070]
1305.5115 [Renumbered 1307.0075]
1305.5116 [Renumbered 1307.0080]
1305.5117 [Renumbered 1307.0085]
1305.5118 [Renumbered 1307.0090]
1305.5200 [Repealed, 19 SR 1340]
1305.5300 [Repealed, 15 SR 74]
1305.5310 [Repealed, 15 SR 74]
1305.5320 [Repealed, 19 SR 1340]
1305.5340 [Repealed, 19 SR 1340]
1305.5360 [Repealed, 19 SR 1340]



1305.5380 [Repealed, 19 SR 1340]
1305.5385 [Repealed, 19 SR 1340]
1305.5400 [Repealed, 19 SR 1340]
1305.5500 [Repealed, 15 SR 74]
1305.5700 [Repealed, 19 SR 1340]
1305.5710 [Repealed, 19 SR 1340]
1305.5720 [Repealed, 19 SR 1340]
1305.5730 [Repealed, 19 SR 1340]
1305.5740 [Repealed, 19 SR 1340]
1305.5750 [Repealed, 19 SR 1340]
1305.5800 [Repealed, 15 SR 74]
1305.5900 [Repealed, 19 SR 1340]
1305.5910 [Repealed, 11 SR 1405]
1305.6000 [Repealed, 19 SR 1340]
1305.6200 [Repealed, 19 SR 1340]
1305.6250 [Repealed, 19 SR 1340]
1305.6260 [Repealed, 11 SR 1405]
1305.6270 [Repealed, 11 SR 1405]
1305.6280 [Repealed, 19 SR 1340]
1305.6300 [Repealed, 19 SR 1340]
1305.6400 [Repealed by amendment, 9 SR 1557]
1305.6425 [Repealed, 19 SR 1340]
1305.6430 [Repealed, 19 SR 1340]
1305.6500 [Repealed by amendment, 9 SR 1557]

1305.6525 [Repealed, 19 SR 1340]

1305.6550 [Repealed, 15 SR 74]

1305.6600 [Repealed, 15 SR 74]

1305.6700 [Repealed, 19 SR 1340]

1305.6800 [Repealed, 19 SR 1340]

1305.6900 [Repealed, 15 SR 74]

1305.6901 [Repealed, 19 SR 1340]

1305.6902 [Repealed, 19 SR 1340]

1305.6905 [Repealed, 19 SR 1340]

1305.6910 [Repealed, 19 SR 1340]

1305.6920 [Repealed, 19 SR 1340]

1305.7000 [Repealed, 27 SR 1474]

1305.7100 [Repealed, 27 SR 1474]

