

To Be Completed by TAG Leads											TAG Meeting Results				
Item Number	2024 IEBC Chapter	2024 IEBC Code Section	2021 IEBC Code Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
								N - None, L - Low, M-Med, H-High					Y or N	Y or N	
3-9	3	303	303.1; 303.1.1		Storm Shelters (Moved) General; Construction		2021 Relocates Storm Shelters from Chapter 11 (Additions) to Chapter 3 (All Compliance Methods). Revised language.	N	N	Discuss and coordinate with 1305 Ch 4. Amendment needed to specify counties where applicable. Add Mower County to list.	AM*	AM	Y		Discuss and coordinate with 1305 Ch 4. Amendment needed to specify counties where applicable. Add Mower County to list. <i>Revise in rule writing for consistency with 1305 TAG CCP_21.2.</i>
7-15.1	7	705.4			Reinstallation of Materials					Consider mirror 1305/IBC 1512.4 (Currently 1305.1511.5).	AM	AM	Y		Consensus to amend the section to match the 1305 amendment (1305.1511.5) <i>1305 TAG supported carry over amendment, no revisions.</i>
8-23	8	Table 804.5.1.1(1) & Table 804.5.1.1 (2)	Table 804.4.1.1(1)	Table 805.3.1.1(1)	L2 Means of Egress, Stories with One Exit or Access to One Exit for R-2 Occupancies		2021 changes footnote a - "non-sprinklered" to "without an approved automatic sprinkler system". In 2024, increases to 3rd story, 125 feet, etc. Similar changes in 2024 IBC.	H	M	Further research on origin and impact of changes needed.	AM	AM	Y		<ul style="list-style-type: none"> • <i>Revise title of Table 804.5.1.1 (1) to "Stories and Occupiable Roofs with one Exit or Access to One Exit for R-2 Occupancies"</i> • <i>Revise title of Table 805.5.1.1 (2) to "Stories and Occupiable Roofs with One Exit or Access to One Exit for Other Occupancies."</i> • <i>For consistency with 1305 CCP_126: Revise third column header to read "MAXIMUM NUMBER OF DWELLING OR SLEEPING UNITS" and first line third column to read "4 dwelling or sleeping units".</i> • <i>Revise Table 804.5.1.1 (1) Maximum Exit Travel Distance for Basement, first, second, or third story above grade plane and occupiable roofs over the first or second floor above grade plan to 125 75 feet.</i> • <i>Discuss with TAG per email from ICC. Propose revise Table 804.5.1.1 (1) footnote 'a' to read: "Buildings classified as Group R-2 equipped without throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 of the Minnesota Fire Code and provided with emergency escape and rescue openings in accordance with Section 1031 of the Minnesota Building Code shall be permitted a maximum travel distance of 125 feet."</i>
9-13	9	Section 908			L3 Emergency Responder Communications Enhancement System Coverage		New in 2024. 908.1 Emergency responder communication enhancement system coverage. The existing building shall undergo an evaluation of the emergency responder communication signal strength and coverage area within the entire building in accordance with Sections 908.1.1 and 908.1.2. Exception: Where it is determined by the fire code official that the emergency responder communication enhancement system (ERCES) is not needed. 908.1.1 Evaluation. The evaluation shall determine the current signal strength and coverage capabilities of the public safety communication systems utilized by the jurisdiction, measured at the exterior of the building. 908.1.2 Compliance. The evaluation report shall be submitted for approval by the fire code official and the frequency license holder. Where the coverage area, signal strength or DAQ does not comply with Section 510 of the International Fire Code, the existing building shall be provided with ERCES coverage. The fire code official is authorized to establish the timeframe for such installation or modification.	H	M	Follow fire code lead - TAG generally likes the idea of removing specific language to reference fire code, but question remains whether U of M could enforce this because in fire code it will be in an appendix. Also coordinate with 7511 and 1305.	AM				Tabled until coordination with 1305 and 7511, then return to 1311 TAG at final meeting. <i>12/10/24 Proposed rule language, coordinated with SMF: 908.1 Emergency responder communications enhancement system coverage. An approved in-building emergency responder communications enhancement system (ERCES) for emergency responders shall be provided as required in jurisdictions where Appendix Q of the Minnesota State Fire Code has been adopted via ordinance or where otherwise required by law or ordinance in accordance with MR 7511.0510.1 and 7511.0510.2.</i>

Recommendations: A - Accept Model Code AM - Amend Model Code D - Delete MN Amendment R - Reject WD - CCP Withdrawn

15-1	15	Section 15			Construction Safeguards					AM (D)	AM (D)	Y		Coordinate with 1305. 1305 TAG supported accepting 2024 IBC Chapter 33 except, on advice of legal counsel, not accepting Section 3302 Owner's Responsibility for Fire Protection .
Other Code Change Proposals														
CCP-9.2	10	Tables 1011.5; 1011.6; 1011.7			Change of Occupancy Hazard Categories (Tables)	Proposed revision to footnotes for previously accepted code change proposal. Consistent with footnote proposal for CCP-18.	L			AM				
CCP-15		5 & 10			Change of Occupancy - State Licensed Facilities	506.1.2 - Change of occupancy to a state licensed facility from an IRC building shall be classified to a 1305/IBC classification and comply with IEBC 1001.2.2.1. 1011 - Change of occupancy to a state licensed facility from an IRC building shall be classified to a 1305/IBC classification and comply with IEBC 1002 through 1011.	H	N	If accepted, renumber following subsection in Ch 5.	AM				
CCP-16		1011.5.6		1011.4.1 Ex. 7	Emergency Escape and Rescue Openings	Language is updated to provide clarity that emergency escape and rescue opening are required when any change in occupancy occurs, regardless of the means of egress hazard level. Minimum opening dimensions for emergency escape and rescue openings are adjusted to align with Minnesota Rules 7511, the Minnesota Fire Code.	H	N		AM				
CCP-17	5			Table 1311.0506.1	Life Safety and Fire Risk Table	Proposal moves IRC-2 to same relative hazard as IRC-1 abd IRC-3. Also revises footnote.	M	L		AM				
CCP-18	5	506.5			Prescriptive Change of Occupancy; Fire Sprinkler System in I-4	Proposal requires sprinklers in the are where change of use to I-4 occurs.	H	M	If accepted, renumber following subsections.	AM				
CCP-19	10	1008.2; 1008.3			Change of Occupancy, Ventilation and Heating	Adds compliance for heating and ensures ventilation provided.	M			AM				