

2024 IRC - 1309 TAG REVIEW WORKSHEET															
To be completed by Chair										To be completed by TAG members					
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments		
					Y or N		N=None, L=Low M=Med, H=High					Y or N			
1309 Administrative Provisions (Ch. 1)															
1	1309.0010 subp. 1	NA	NA	adoption of the 2024 IRC	Y	text changes: change references to the 2018 IRC to 2024 IRC. Change copyright 2017 to 2024.	N	N	Accept update to references		A	Y			
2	1309.0010 subp. 1a	NA	NA	deleted appendices	Y	this rule deletes all IRC appendices except Sound Transmission and Tiny Houses. The 2024 IRC makes the following changes to Appendix designations: the 2020 MRC Appendix K is changed in the 2024 IRC to Appendix BG; 2020 MRC Appendix Q is changed in the 2024 IRC to Appendix BB.	N	N	Accept -keep the existing MN. rule text and amend text to update 2020 MRC appendices designations to new 2024 appendices designations		A	Y	Will have opportunity to review appendicies at later time.		
3	1309.0010 subp. 2	NA	NA	mandatory chapters	Y	text changes: 2018 IRC is changed to 2024 IRC. Chapters 12 thru 24 are added to the Manditory Chapters. Appendix K is changed to Appendix BG, Appendix Q is changed to Appendix BB.	N	N	Accept - keep exisitng text making changes to update references		A	Y			
4	1309.0010 subp. 3	NA	NA	replacement chatpers	Y	text changes: all references to 2018 IRC are changed to 2024 IRC. Item C is deleted as the menttioned chapter is now a mandatory chapter. Items D and E are renumber to C and D respectively. Item E reference to R314 is chaged to R310 and R315 is changed to R311 as those sections have been renumbered in the 2024 IRC.	N	N	Accept - keep exisitng text making changes to update references		A	Y			
5	1309.0020 subp. 1	NA	NA	references to other codes	Y	text change: reference to the 2018 IRC is changed to 2024 IRC.	N	N	Accept - keep exisitng text making changes to update references		A	Y			
6	1309.0100 subp. 2 exception	NA	NA	existing buildings exception	Y	reference to section R308 is changed to R324 as the Glazing section has been renumbered in the 2024 IRC.	N	N	Accept - keep existing text making changes to update references		A	Y			
7	1309.0100 subp. 3 Transient use	NA	NA	transient use buildings	Y	Buildings constructed for transient use and required to be licensed by any Minnesota statute 326B state-agency shall be constructed in accordance with the requirements for Group R occupancies located in Minnesota Rules, chapter 1305.	N	N	Accept - make text changes to specifically reference 326B statutes rather than any agency's requirements.		A	y	Keeps licensing with DLI & 326B		
1309 Ch. 2 - Definitions															
1	Chapter 2 - User Notes	Chapter 2 - User Notes	Chapter 2 - User Notes	Code Development Reminder	N	2020: <i>See page iv for explanation.</i> Actual information shown on page vi. 2021/2024: Code development committees listed in User Notes	N	N	A		A	Y			
2	R201.4	R201.4	R201.4	Terms not defined	Y	2020: Where terms are not defined through the methods authorized by this chapter, the MerriamWebster Collegiate Dictionary, available at www.m-w.com, shall be considered as providing ordinarily accepted meanings. The dictionary is incorporated by reference, is subject to frequent change, and is available through the Minitex interlibrary loan system. 2021/2024: Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies.	H	H	AM - Keep 2020		A	Y	follow Ch. 1300 and other code chapterscontext that pertains		

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
3	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Above-Grade Wall.	N/A	N/A	Energy		A	Y	keep as written allow 1322 to address
4	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Access (To). That which enables a device, an appliance or equipment to be reached by ready access or by a means that first requires the removal or movement of a panel, door or similar obstruction. 2024: [RB] Access (To). That which enables a device, an appliance or equipment to be reached by ready access or by a means that first requires the removal or movement of a panel, door or similar obstruction. For the definition applicable in Chapter 11, see Section N1101.6. For the definition applicable in Chapter 24, see Section G2403.	L	L	Referenced sections to track. For remainder of worksheet - 2024 listed if only change is reference to other sections.		A	Y	keep as written allow other TAGs to address
5	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Accessory Structure. A structure that is accessory to and incidental to that of the dwelling(s) and that is located on the same lot. 2024: [RB] Accessory Structure. A structure that is accessory to and incidental to that of the dwelling(s) or townhouse(s) and that is located on the same lot.	L	L	A		A	Y	
6	Section R202	Section R202	Section R202	Definitions	N	2024 : [RB] Addition. An extension or increase in floor area, number of stories or height of a building or structure. For the definition applicable in Chapter 11, see Section N1101.6.	L	L	Referenced sections to track.		A	Y	
7	N/A	N/A	Section R202	Definitions	N	2024: [MP] Air, Exhaust. Air, Makeup. Air, Outdoor. Air, Transfer.	N/A	N/A	Plbg/Mech		A	Y	Keep as written; ALIGN with energy TAG for openings created by Mechanical MECH TAG: accept as written
8	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Air Admittance Valve.	N/A	N/A	Plbg/Mech		AM to DELET	Y	Let 4714 define
9	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Air Barrier.	N/A	N/A	Energy		A	Y	accept as written and let Energy TAG take over
10	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Air Break (Drainage System). Air Circulation, Forced.	N/A	N/A	Plbg/Mech		AM TABLE	y	DELETE: Air Break TABLE : Pending MECH TAG to define Air Circulation MECH TAG: accept as written
11	N/A	N/A	Section R202	Definitions	N	2024: [MP] Air Conditioner, Gas-Fired. Air Conditioning.	N/A	N/A	Plbg/Mech		A	Y	Chris: no conflict with 1346 definition
12	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Air Gap, Drainage System. Air Gap, Water-Distribution System. Air-Conditioning System.	N/A	N/A	Plbg/Mech		AM to DELET Accept 2nd 1/2	Y	DELETE all except Air Conditioning System definition which is Accepted as written
13	N/A	N/A	Section R202	Definitions	N	2024: [MP] Air-Handling Unit.	N/A	N/A	Plbg/Mech		A	Y	accept as written and let Energy TAG take over
14	Section R202	Section R202	Section R202	Definitions	N	2024 : [RB] Air-Impermeable Insulation. An insulation having an air permanence equal to or less than 0.02 L/s-m2 at 75 Pa pressure differential as tested in accordance with ASTM E283 or E2178. For the definition applicable in Chapter 11, see Section N1101.6.	L	L	Referenced sections to track.		A	Y	Accept as written Steve Shold: 1322 and other TAGs will review

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
15	Section R202	Section R202	Section R202	Definitions	N	2024: [RB] Alteration. Any construction, retrofit or renovation to an existing structure other than repair or addition that requires a permit. Also, a change in a building, electrical, gas, mechanical or plumbing system that involves an extension, addition or change to the arrangement, type or purpose of the original installation that requires a permit. For the definition applicable in Chapter 11, see Section N1101.6. For the definition applicable in Chapter 24, see Section G2403.	L	L	Referenced sections to track.		A	Y	Accept as written
16	N/A	N/A	Section R202	Definitions	N	2024: [MP] Anodeless Riser.	N/A	N/A	Plbg/Mech		A	Y	Accept as written
17	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Antisiphon.	N/A	N/A	Plbg/Mech		AM to Delete	Y	4714 will define and provide code
18	Section R202	Section R202	Section R202	Definitions	N	2020: [MP] Appliance. A device or apparatus that is manufactured and designed to utilize energy. 2024: [MP] Appliance. A device or apparatus that is manufactured and designed to utilize energy and for which this code provides specific requirements. For the definition applicable in Chapter 24, see Section G2403.	L	L	A Referenced sections to track.		A	Y	accept as written
19	N/A	N/A	Section R202	Definitions	N	2024: [MP] Appliance, Automatically Controlled. Appliance, Fan-Assisted Combustion. Appliance, Unvented. Appliance, Vented.	N/A	N/A	Plbg/Mech		A	Y	Accept as written
20	Section R202	Section R202	Section R202	Definitions	Y	2020: [RB] Approved. “Approved” means approval by the building official, pursuant to the Minnesota State Building Code, by reason of: a. inspection, investigation, or testing; b. accepted principles; c. computer simulations; d. research reports; or e. testing performed by either a licensed engineer or by a locally or nationally recognized testing laboratory. 2021: [RB] Approved. Acceptable to the building official. 2024: [RB] Approved. Acceptable to the building official. For the definition applicable in Chapter 24, see Section G2403.	H	H	AM - Keep 2020		AM	Y	Keep Minnesota Amendment keeps Mn. Clarity as in other chapters
21	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Approved Agency. An established and recognized agency that is regularly engaged in conducting tests, furnishing inspection services or furnishing product certification, and has been approved by the building official. 2024: [RB] Approved Agency. An established and recognized organization that is regularly engaged in conducting tests, furnishing inspection services or furnishing product evaluation or certification where such organization has been approved. For the definition applicable in Chapter 24, see Section G2403.	H	H	A Referenced sections to track.		A	Y	Accept as written
22	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RB] Approved Source. An independent person, firm or corporation, approved by the building official, who is competent and experienced in the application of engineering principles to materials, methods or systems analyses. For the definition applicable in Chapter 11, see Section N1101.6.	H	H	A Referenced sections to track.		A	Y	TABLE: 1305 may change and will let us know Adopt 1305 language

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
23	N/A	N/A	Section R202	Definitions	N	2024: [MP] Atmospheric Pressure.	N/A	N/A	Plbg/Mech		A	Y	Accept as written, Refers to Ch. 24 which is now an Adopted Chapter
24	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Automatic.	N/A	N/A	Energy		A	Y	Accept as written, Refers to Ch. 24 which is now an Adopted Chapter
25	N/A	N/A	Section R202	Definitions	N	2024: [MP] Automatic Ignition. Automatic Shutoff Control.	N/A	N/A	Plbg/Mech		A	Y	Accept as written, Refers to Ch. 24 which is now an Adopted Chapter
26	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Backflow, Drainage. Backflow, Water Distribution. Backflow Preventer. Backflow Preventer, Reduced-Pressure-Zone Type. Backpressure, Low Head. Backsiphonage. Backwater Valve.	N/A	N/A	Plbg/Mech		AM to delete	Y	Delete and defer to 4714 Plbg. Code
27	N/A	Section R202	N/A	Definitions	N	2021: [MP] Balanced Ventilation	N/A	N/A	Plbg/Mech		N/A	Y	appeared in 21 IRC and disappeared in 24
28	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Balanced Ventilation System.	N/A	N/A	Plbg/Mech		A	Y	accept as written but verify if 1322 TAG concurs 2/25/25 1322: accept as written
29	N/A	N/A	Section R202	Definitions	N	2024: [MP] Barometric Draft Regulator.	N/A	N/A	Plbg/Mech		A	Y	references to new adopted Chapters
30	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Basic Wind Speed. Three-second gust speed at 33 feet (10 058 mm) above the ground in Exposure C (see Section R301.2.1) as given in Figure R301.2(5)A. 2024: [RB] Basic Wind Speed. Three-second gust speed at 33 feet (10 058 mm) above the ground in Exposure C (see Section R301.2.1) as given in Figure R301.2(2)	H	H	A		A	Y	RENUMBERED ONLY
31	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Bathroom Group. Bend.	N/A	N/A	Plbg/Mech		AM to delete	Y	defer to 4714
32	N/A	N/A	Section R202	Definitions	N	2024: [RE] Biodiesel Blend.	N/A	N/A	Energy		A	Y	references new adopted chapters
33	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Boiler.	N/A	N/A	Plbg/Mech		A	Y	Pending consideration with Mech. TAG MECH TAG: accept as written
34	N/A	N/A	Section R202	Definitions	N	2024: [MP] Boiler, Low-Pressure.	N/A	N/A	Plbg/Mech		A	Y	references new adopted chapters
35	Section R202	N/A	N/A	Definitions	N	2020: [RB] Battery System, Stationary Storage. A rechargeable energy storage system consisting of electrochemical storage batteries, battery chargers, controls and associated electrical equipment designed to provide electrical power to a building. The system is typically used to provide standby or emergency power, an uninterruptable power supply, load shedding, load sharing or similar capabilities.	M	M	A		N/A	Y	Not in 24 IRC Electrical Code will address
36	N/A	N/A	Section R202	Definitions	N	2024: [MP] Bonding Jumper. Brazing.	N/A	N/A	Plbg/Mech		A	Y	

To be completed by Chair										To be completed by TAG members			
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
38	Section R202	Section R202	Section R202	Definitions	N	2020: [RB] Building. Any one- or two-family dwelling or portion thereof, including townhouses, used or intended to be used for human habitation, for living, sleeping, cooking or eating purposes, or any combination thereof, or any accessory structure. 2021/2024: [RB] Building. Any one- or two-family dwelling or townhouse , or portion thereof, used or intended to be used for human habitation, for living, sleeping, cooking or eating purposes, or any combination thereof, or any accessory structure. For the definition applicable in Chapter 11, see Section N1101.6.	L	L	A Referenced sections to track.		A	Y	Accept as written
39	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Building, Existing. Existing building is a building erected prior to the adoption of this code, or one for which a legal building permit has been issued. 2024: [RB] Existing Building. Existing building is a ...	M	M	A		A	Y	Accept as written
40	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Building Drain.	N/A	N/A	Plbg/Mech		AM to delete	Y	defer to 4714
41	Section R202	Section R202	Section R202	Definitions	N	2020/2021/ 2024 : [RB] Building Official. The officer or other designated authority charged with the administration and enforcement of this code, or a duly authorized representative. For the definition applicable in Chapter 11, see Section N1101.6.	L	L	A Referenced sections to track.		A	Y	accept as written
42	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Building Sewer.	N/A	N/A	Plbg/Mech		AM to delete	Y	defer to 4714
43	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Building Site. Building Thermal Envelope.	N/A	N/A	Energy		A	Y	references Ch. 11
44	Section R202	Section R202	N/A	Definitions	N	2020/2021: [RB] Building-Integrated Photovoltaic Product. A building product that incorporates photovoltaic modules and functions as a component of the building envelope.	L	L	Replaced by item # 69 48		N/A	Y	See line item #48
45	N/A	N/A	Section R202	Definitions	N	2024: [RB] Building-Integrated Photovoltaic (BIPV) Roof Covering. A BIPV system that also functions as a roof covering. Coverings include, but are not limited to, shingles, tiles and roof panels.	L	L	A		A	Y	
46	Section R202	Section R202	N/A	Definitions	N	2020/2021: [RB] Building-Integrated Photovoltaic Roof Panel (BIPV Roof Panel). A photovoltaic panel that functions as a component of the building envelope.	L	L	Replaced by item # 68 47		N/A	Y	
47	Section R202	Section R202	Section R202	Definitions	N	2024: [RB] Building-Integrated Photovoltaic (BIPV) Roof Panel. A photovoltaic panel that functions as a component of the building envelope.	L	L	A		A	Y	Accept as written
48	N/A	N/A	Section R202	Definitions	N	2024: [RB] Building-Integrated Photovoltaic (BIPV) System. A building system that incorporates photovoltaic modules and functions as an integral part of the building envelope, such as roof assemblies and roof coverings, exterior wall envelopes and exterior wall coverings, and fenestration.	L	L	A		A	Y	this item replaced line item #48
49	N/A	N/A	Section R202	Definitions	N	2024: [MP] Burner.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
50	N/A	N/A	Section R202	Definitions	N	2024: [RE] Cavity Insulation.	N/A	N/A	Energy				

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
51	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Cement Plaster. A mixture of Portland or blended cement, Portland cement or blended cement and hydrated lime, masonry cement or plastic cement and aggregate and other approved materials as specified in this code.	L	L	A		N/A	y	
52	Section R202	Section R202	Section R202	Definitions	N	2020/2021/ 2024 : [MP] Chimney. A primary vertical structure containing one or more flues, for the purpose of carrying gaseous products of combustion and air from a fuel-burning appliance to the outside atmosphere. For the definition applicable in Chapter 24, see Section G2403. Factory-built chimney. For the definition applicable in Chapter 24, see Section G2403. Masonry chimney. For the definition applicable in Chapter 24, see Section G2403.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
53	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Chimney Connector. Chimney Types. Circuit Vent. Circulating Hot Water System. Cleanout.	N/A	N/A	Plbg/Mech		A	Y	Accept: Chimney connector, circulating Hot Water system. Delete: Circuit Vent., Cleanout. TABLE: Chimney types, pending MECH TAG review MECH TAG: accept as written
54	N/A	N/A	Section R202	Definitions	N	2024: [MP] Clearance. Clothes Dryer.	N/A	N/A	Plbg/Mech		A	Y	
55	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Climate Zone.	N/A	N/A	Energy		A	Y	references Ch. 11
56	Section R202	N/A	Section R202	Definitions	Y	2020: Code. For purposes of this chapter, “the code” or “this code” means the Minnesota Residential Code, Minnesota Rules, Chapter 1309. 2024: [MP] Code. For the definition applicable in Chapter 24, see Section G2403.	H	H	AM - Keep 2020		AM	Y	amend to keep 2020 definition may need CCP? NO CCP nedded STAFF will address
57	N/A	N/A	Section R202	Definitions	N	2024: [MP] Code Official.	N/A	N/A	Plbg/Mech		A	Y	does not conflict with MN B.O. definition
58	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Collection Pipe. Combination Waste and Vent System.	N/A	N/A	Plbg/Mech		AM to delete	Y	defer to 4714
59	N/A	N/A	Section R202	Definitions	N	2024: [MP] Combustible Assembly.	N/A	N/A	Plbg/Mech		A	Y	
60	Section R202	Section R202	Section R202	Definitions	N	2020/2021/ 2024 : [RB] Combustible Material. Any material not defined as noncombustible. For the definition applicable in Chapter 24, see Section G2403.	M	M	A Referenced sections to track.		A	Y	
61	N/A	N/A	Section R202	Definitions	N	2024: [MP] Combustion. Combustion Chamber. Combustion Products. Concealed Location. Concealed Piping. Connector, Appliance (Fuel). Connector, Chimney or Vent.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
62	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Combustion Air. Common Vent. Condensate. Condensing Appliance.	N/A	N/A	Plbg/Mech		A	Y	Delete: Common vent TABLE: the rest pending MECH TAG MECH TAG: accept as written
63	N/A	N/A	Section R202	Definitions	N	2024: [RE] Common Areas. Conditioned Floor Area. Conditioned Space.							

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
64	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Construction Documents. Written, graphic and pictorial documents prepared or assembled for describing the design, location and physical characteristics of the elements of a project necessary for obtaining a building permit. Construction drawings shall be drawn to an appropriate scale. For the definition applicable in Chapter 11, see Section N1101.6.	H	H	A Referenced sections to track.		A	Y	
65	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Contamination. Continuous Waste. Control, Limit. Control, Primary Safety. Convector.	N/A	N/A	Plbg/Mech		A	Y	Delete: Contamination. Continuous Waste TABLE: Control, Limit. Control, Primary Safety. Convector. MECH TAG: accept as written
66	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Continuous Air Barrier. Continuous Insulation (ci).	N/A	N/A	Energy		A	Y	references Ch. 11
67	N/A	N/A	Section R202	Definitions	N	2024: [RE] Continuous Pilot.	N/A	N/A	Energy		A	Y	references Ch. 11
68	N/A	N/A	Section R202	Definitions	N	2024: [MP] Control. Conversion Burner. Copper Alloy.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
69	Section R202	Section R202	Section R202	Definitions	Y	2020: [RB] Crawl Space. Areas or rooms with less than 6 feet 4 inches (1931 mm) ceiling height measured to the finished floor or grade below. 2021/2024: [RB] Crawl Space. An underfloor space that is not a basement.	H	H	AM - Keep 2020		A	Y	Pending review of R313 & R408 1309 TAG: CONSENSUS to keep MN amendment
70	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Crawl Space Wall. Curtain Wall.	N/A	N/A	Energy		A	Y	references Ch. 11
71	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RB] Cripple Wall Clear Height. The vertical height of a cripple wall from the top of the foundation to the underside of floor framing above.	M	M	A		A	Y	
72	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Cross Connection. Damper, Volume.	N/A	N/A	Plbg/Mech		A	Y	Delete: Cross connection TABLE: Damper, Volume for MECH TAG MECH TAG: accept as written
73	N/A	N/A	Section R202	Definitions	N	2024: [MP] Cubic Foot. Damper. Decorative Appliance, Vented. Decorative Appliances For Installation In Vented Fireplaces.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
74	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Decorative Glass. A carved, leaded or Dalle glass or glazing material with a purpose that is decorative or artistic, not functional; with coloring, texture or other design qualities or components that cannot be removed without destroying the glazing material; and with a surface, or assembly into which it is incorporated, that is divided into segments. 2024: [RB] Decorative Glazing . A carved, leaded or Dalle glass or glazing material with a purpose that is decorative or artistic, not functional; with coloring, texture or other design qualities or components that cannot be removed without destroying the glazing material; and with a surface, or assembly into which it is incorporated, that is divided into segments.	L	L	A		A	Y	
75	N/A	N/A	Section R202										

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
77	N/A	N/A	Section R202	Definitions	N	2024: [RE] Demand Response Signal. Demand Responsive Control.	N/A	N/A	Energy		A	Y	references Ch. 11
78	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [MP] Design Professional. See “Registered design professional.” 2024:[RB] Design Professional. See “Registered design professional.”	L	L	A		A	Y	
79	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Developed Length. Dilution Air. Direct System. Direct-Vent Appliance. Draft. Draft Hood. Draft Regulator. Drain. Drainage Fitting. Drain-Back System.	N/A	N/A	Plbg/Mech		A	Y	Accept: Dilution Air. Direct System. Direct-Vent Appliance. Draft. Draft Hood. Draft Regulator Delete: Developed Length,Drain. Drainage Fitting TABLE: Drain-Back System, pending MECH TAG review MECH TAG: accept as written
80	N/A	N/A	Section R202	Definitions	N	2024: [RE] Dimmer. Distribution System Efficiency (DSE). Duct Airflow Balancing. Ductwork.	N/A	N/A	Energy		A	Y	References Ch. 11
81	N/A	N/A	Section R202	Definitions	N	2024: [MP] Drip. Duct Furnace. Duct System.	N/A	N/A	Plbg/Mech		A	Y	references Ch. 24
82	Section R202	Section R202	Section R202	Definitions	Y	2020: [RB] Dwelling. SINGLE-FAMILY. Any building that contains one dwelling unit used, intended, or designed to be built, used, rented, leased, let or hired out to be occupied, or occupied for living purposes. TWO-FAMILY. Any building that contains two separate dwelling units with separation either horizontal or vertical on one lot that is used, intended, or designed to be built, used, rented, leased, let or hired out to be occupied, or occupied for living purposes. TOWNHOUSE. A single-family dwelling unit constructed in a group of two or more attached units in which each unit extends from the foundation to the roof and having open space on at least two sides of each unit. Each single-family dwelling unit shall be considered to be a separate building. Separate building service utilities shall be provided to each single-family dwelling unit when required by other chapters of the State Building Code. 2021/2024: [RB] Dwelling. Any building that contains one or two dwelling units used, intended, or designed to be built, used, rented, leased, let or hired out to be occupied, or that are occupied for living purposes.	H	H	AM - Keep 2020		A		TABLE to coordinate definitions with Ch 1300 and Ch. 1305 pending their TAG reviews. 2/25/25 Keep MN Amendment Staff will coordinate 1300 and 1305 changes.
83	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Dwelling Unit. A single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation. For the definition applicable in Chapter 11, see Section N1101.6. For the definition applicable in Chapter 24, see Section G2403.	L	L	A Referenced sections to track.		A	Y	
84	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] DWV. Effective Opening. Elbow	N/A	N/A	Plbg/Mech		AM DELETE	Y	

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
85	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Emergency Escape and Rescue Opening. An operable exterior window, door or other similar device that provides for a means of escape and access for rescue in the event of an emergency. (See also “Grade floor emergency escape and rescue opening.”)	H	L	A		A	Y	
86	N/A	N/A	Section R202	Definitions	N	2024: [RE] Emittance. Enclosed Reflective Air Space. Energy Rating Index (ERI).	N/A	N/A	Energy		A	Y	
87	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Energy Analysis. Energy Cost. Energy Simulation Tool.	N/A	N/A	Energy		A	Y	
88	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RB] Energy Storage Systems (ESS). One device or multiple devices, assembled together, capable of storing electrical energy to be supplied at a future time.	M	M	A		A	Y	
89	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Equipment. Equivalent Length. Essentially Nontoxic Transfer Fluids. Essentially Toxic Transfer Fluids. Evaporative Cooler. Excess Air. Exhaust Hood, Full Opening. Existing Installations.	N/A	N/A	Plbg/Mech		DELETE - Equivalent Length Existing Installation	Y	
90	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] ERI Reference Design.	N/A	N/A	Energy		A	Y	
91	N/A	N/A	Section R202	Definitions	N	2024: [MP] Excess Flow Valve (EFV). Exterior Masonry Chimney.	N/A	N/A	Plbg/Mech		A	Y	
92	N/A	N/A	Section R202	Definitions	N	2024: [RB] Existing Building. Existing building is a building erected prior to the adoption of this code, or one for which a legal building permit has been issued. For the definition applicable in Chapter 11, see Section N1101.6.	M	M	A		A	Y	check with 1311 TAG to compare definitions Delete: Adoption, Effective Date 2/25/25 accept as written; 1311 does not address 1309 buildings
93	N/A	N/A	Section R202	Definitions	N	2024: [RB] Exterior Soffit. A material or assembly of materials applied on the underside of exterior overhangs and attached carport and porch ceilings.	L	L	A		A	Y	
94	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RB] Exterior Wall. An above-grade wall that defines the exterior boundaries of a building. Includes between-floor spandrels, peripheral edges of floors, roof and basement knee walls, dormer walls, gable end walls, gable end roof trusses , walls enclosing a mansard roof and basement walls with an average below-grade wall area that is less than 50 percent of the total opaque and nonopaque area of that enclosing side. For the definition applicable in Chapter 11, see Section N1101.6.	M	H	A		A	Y	
95	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Exterior Wall Covering. A material or assembly of materials applied on the exterior side of exterior walls for the purpose of providing a weather-resistive barrier, insulation or for aesthetics, including but not limited to, veneers, siding, exterior insulation and finish systems, architectural trim and embellishments such as cornices., soffits, and fascias.	L	L	A		A	Y	
96	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Factory-Made Air Duct.	N/A	N/A	Plbg/Mech		A	Y	

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
97	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RE] Fenestration. Products classified as either vertical fenestration or skylights and sloped glazing, installed in such a manner as to preserve the weather-resistant barrier of the wall or roof in which they are installed. Fenestration includes products with glass or other transparent or translucent materials. For the definition applicable in Chapter 11, see Section N1101.6.	L	L	A Referenced sections to track.		A	Y	
98	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RE] Fenestration, Vertical. Windows that are fixed or movable, opaque doors, glazed doors, glazed block and combination opaque and glazed doors installed in a wall at less than 15-degrees (0.26 rad) from vertical. For the definition applicable in Chapter 11, see Section N1101.6 under "Fenestration."	L	L	A Referenced sections to track.		A	Y	
99	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Fenestration Product, Site-Built.	N/A	N/A	Energy		A	Y	
100	N/A	N/A	Section R202	Definitions	N	2024: [RE] F-Factor (Thermal Transmittance).	N/A	N/A	Energy		A	Y	
101	Section R202	Section R202	Section R202	Definitions	N	2020/2021/2024: [RB] Fire Separation Distance. The distance measured from the building face to one of the following: 1.To the closest interior lot line. 2.To the centerline of a street, an alley or public way. 3.To an imaginary line between two buildings or townhouse unts on the lot. The distance shall be measured at a right angle from the face of the wall.	M	M	A		A	Y	
102	Section R202	Section R202	Section R202	Definitions	N	2020/2024: [RB] Fireplace. An assembly consisting of a hearth and fire chamber of noncombustible material and provided with a chimney, for use with solid fuels. For the definition applicable in Chapter 24, see Section G2403. Factory-built fireplace. A listed and labeled fireplace and chimney system composed of factory-made components, and assembled in the field in accordance with manufacturer’s instructions and the conditions of the listing. For the definition applicable in Chapter 24, see Section G2403. Masonry fireplace. A field-constructed fireplace composed of solid masonry units, bricks, stones or concrete. For the definition applicable in Chapter 24, see Section G2403. 2021: [RB] Fireplace. An assembly consisting of a hearth and fire chamber of noncombustible material and provided with a chimney, for use with solid fuels.	M	M	A Referenced sections to track.		A	Y	
103	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Fireplace Stove.	N/A	N/A	Plbg/Mech		A	Y	

To be completed by Chair											To be completed by TAG members		
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
104	Section R202	Section R202	Section R202	Definitions	N	2020: [RB] Fire-Retardant-Treated Wood. Pressure-treated lumber and plywood that exhibit reduced surface burning characteristics and resist propagation of fire. Other means during manufacture. A process where the wood raw material is treated with a fire-retardant formulation while undergoing creation as a finished product. Pressure process. A process for treating wood using an initial vacuum followed by the introduction of pressure above atmospheric. 2021: [RB] Fire-Retardant-Treated Wood. Wood products that, when impregnated with chemicals by a pressure process or other means during manufacture, exhibit reduced surface burning characteristics and resist propagation of fire. Other means during manufacture. A process where the wood raw material is treated with a fire-retardant formulation while undergoing creation as a finished product. Pressure process. A process for treating wood using an initial vacuum followed by the introduction of pressure above atmospheric. 2024: [RB] Fire-Retardant-Treated Wood. Wood products that, when impregnated with chemicals by a pressure process or other means during manufacture, exhibit reduced surface burning characteristics and resist propagation of fire.	M	L	A		A	Y	
105	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Fixture. Fixture Branch, Drainage. Fixture Branch, Water-Supply. Fixture Drain. Fixture Fitting. Fixture Group, Main. Fixture Supply. Fixture Unit, Drainage (d.f.u.). Fixture Unit, Water-Supply (w.s.f.u.).	N/A	N/A	Plbg/Mech		AM - DELETE	Y	ALL IN 4714
106	N/A	N/A	Section R202	Definitions	N	2024: [MP] Flame Safeguard.	N/A	N/A	Plbg/Mech		A	Y	
107	Section R202	N/A	N/A	Definitions	Y	2020: Flashing. Approved corrosion-resistive material provided in such a manner as to deflect and resist entry of water into the construction assembly.	M	H	AM - Keep 2020		REJECT	Y	Repeal the amendment 703.4 handles it
108	N/A	N/A	Section R202	Definitions	N	2024: [MP] Flashback Arrestor Check Valve. Flood Hazard Area.	N/A	N/A	Plbg/Mech		A	Y	
109	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Flexible Air Connector. Flood-Level Rim.	N/A	N/A	Plbg/Mech		A AM	Y	DELETE: Flood-Level Rim, IN 4714
110	Section R202	N/A	N/A	Definitions	Y	2020: Floor Area. The calculated square footage of the floor within the inside perimeter of the exterior walls of the building under consideration without deduction for hallways, stairways, closets, the thickness of interior walls, columns, or other features.	L	M	AM - Keep 2020		A - POLL	Y	members discussed, poll to Reject or Keep poll consensus to keep
111	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Floor Drain. Floor Furnace. Flow Pressure. Flue, Appliance. Flue Collar. Flue Gases. Flush Valve. Flushometer Tank. Flushometer Valve.	N/A	N/A	Plbg/Mech		A AM	Y	Accept: Floor Furnace,Flue, Appliance. Flue Collar. Flue Gases. Delete: Floor Drain.Flush Valve. Flushometer Tank. Flushometer Valve.
112	N/A	N/A	Section R202	Definitions	N	2024: [MP] Flue Liner (Lining).	N/A	N/A	Plbg/Mech		A	Y	

<

To be completed by Chair										To be completed by TAG members			
Item No.	2020 Minnesota Code Section	2021 IRC Code Section	2024 IRC Code Section	Subject	Current MN Amend	Description of Change	Safety & Health Value	Cost Impact	Recommendation A - Accept R - Reject AM - Amend or Comments		Recommendation A - Accept R - Reject AM - Amend	TAG Group Consensus	Comments
					Y or N		N=None, L=Low M=Med, H=High					Y or N	
133	Section R202	Section R202	Section R202	Definitions	N	2020/2021: [RB] Impact Protective System. Construction that has been shown by testing to withstand the impact of test missiles and that is applied, attached, or locked over exterior glazing. 2024: [RB] Impact Protective System. Impact protective systems are defined as follows: 1. Construction that has been shown by testing to withstand the impact of test missiles and that is applied, attached, or locked over exterior glazing. 2. For storm shelters, an assembly or device, subject to static or cyclic pressure and impact testing as detailed in ICC 500, installed to protect an opening in the storm shelter envelope.	H	M	A		A	Y	
134	N/A	Section R202	Section R202	Definitions	N	2021/2024: [MP] Indirect System. Indirect Waste Pipe. Individual Sewage Disposal System. Individual Vent. Individual Water Supply.	N/A	N/A	Plbg/Mech		Accept Delete	Y	Accept: Indirect System Delete: Indirect Waste Pipe. Individual Sewage Disposal System. Individual Vent. Individual Water Supply
135	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RE] Infiltration.	N/A	N/A	Energy		A	Y	
136	N/A	N/A	Section R202	Definitions	N	2024: [MP] Infrared Radiant Heater.	N/A	N/A	Plbg/Mech		A	Y	
137	Section R202	Section R202	Section R202	Definitions	N	2020: [RB] Insulating Sheathing. An insulating board having a thermal resistance of not less than R-2 of the core material. 2021/2024: [RB] Insulating Sheathing. A rigid panel or board insulation material having a thermal resistance of not less than R-2 of the core material with properties suitable for use on walls, floors, roofs or foundations. For the definition applicable in Chapter 11, see Section N1101.6.	M	M	A Referenced sections to track.		A	Y	
138	N/A	N/A	Section R202	Definitions	N	2024: [RE] Intermittent Ignition. Interrupted Ignition. Knee Wall.	N/A	N/A	Energy		A	Y	
139	N/A	Section R202	Section R202	Definitions	N	2021/2024: [RB] Intermodal Shipping Container. A six-sided steel unit originally constructed as a general cargo container used for the transport of goods and materials.	M	M	A		A	Y	ACCEPT as written; 1305 deals with this; Ch 3 will deal with this.
140	Section R202	N/A	N/A	Definitions	Y	2020: Kick-Out Flashing. Flashing used to divert water where the lower portion of a sloped roof stops within the plane of an intersecting wall cladding.	M	H	AM - Keep 2020		AM	Y	KEEP MN AMENDMENT
141	Section R202	Section R202	Section R202	Definitions	N	2020: [RB] Kitchen. Kitchen shall mean an area used, or designated to be used, for the preparation of food. 2021/2024: [RB] Kitchen. Kitchen shall mean An area used, or designated to be used, for the preparation of food.	L	L	A		A	Y	

