

Residential Code (1309) TAG

Meeting #15 Notes

Date: 6/17/2025

Meeting Location: DLI – Washington Room/Webex Event

Call to order: 9:01 a.m.

Attendance:

TAG Members Attending:

Terence Olson (DLI), Jesse Szykulski (DLI), Kyle Thrapp, Greg Olson, Chris Rosival (DLI), Nathan Weber, Curtis (CJ) Johnson.

TAG Members Not Attending:

Lisa Hartwig, Steve Kartak

Guests Attending:

Amanda Spuckler (DLI), Mackenzie Johnson (DLI), Don Sivigny (DLI), Nick Erickson, Greg Metz (DLI),

Guests Attending on-line:

Mike Barden, Steve Shold (DLI), Adam Barthel, Chad Payment (DLI), Eric Fowler, Eric Lacey, Joshua Harmon, Peter Kulczyk, Ron Nuttall, Shawn Wetterlin.

Code Change Proposal Review:

- The TAG reviewed a CCP for R401.5 that adds a new section to address excavations near foundations. The TAG consensus is to accept the code change proposal with a friendly amendment to address both public and private property.

Worksheet Review:

The TAG reviewed the worksheet at this meeting. Starting with chapter 6, line 69 and ending with chapter 7, line 19.

Chapter 7:

- Worksheet Line 3, section R702.7, vapor retarders. The TAG consensus is to delete the Minnesota amendment that modifies this section and accept the model code language as written.
- Worksheet lines 17, 18, and 19, section R703.2, water resistive barriers. The TAG consensus is to modify the current Minnesota amendment to include the model code language and as well as the current Minnesota requirement that the water-resistive barrier material be to the underside of the rafter or truss top chord." The TAG also recommended deleting the exception in the current rule.

Next Meeting:

Date: 7/1/2025

Time: 9:00 a.m.

Location: DLI – Washington Room

Meeting Adjourned: 10:50 a.m.

Prepared by:

Terence Olson