

1.1 **Department of Labor and Industry**

1.2 **Adopted Permanent Rules Adopting Changes to the Elevator and Related Devices**  
1.3 **Code**

1.4 **1307.0020 CODES ADOPTED BY REFERENCE.**

1.5 Subpart 1. **Incorporation by reference.** The following are incorporated by reference,  
1.6 are not subject to frequent change, are available in the office of the commissioner of labor  
1.7 and industry, and are made part of the Minnesota State Building Code as amended in this  
1.8 chapter:

1.9 A. ASME A17.1/CSA B44-2016 Safety Code for Elevators and Escalators;

1.10 B. ASME A17.3-2015 Safety Code for Existing Elevators and Escalators;

1.11 C. ASME A17.5-2014 Elevator and Escalator Electrical Equipment;

1.12 D. ASME A17.7/CSA B44.7-2007 Performance-Based Safety Codes for Elevators  
1.13 and Escalators;

1.14 E. ASME A18.1-2017 Safety Standard for Platform Lifts and Stairway Chairlifts;

1.15 F. ASME A90.1-2015 Safety Standard for Belt Manlifts;

1.16 G. ASME B20.1-2015 Safety Standard for Conveyors and Related Equipment as  
1.17 published by the American Society of Mechanical Engineers, United Engineering Center,  
1.18 345 East 47th Street, New York, New York 10017.

1.19 Subp. 2. [Repealed, 23 SR 2051]

1.20 Subp. 3. **Emergency personnel.** ASME A17.4-2015 Guide for Emergency Personnel  
1.21 is the reference document for emergency personnel.

1.22 Subp. 4. **Building Code elevator and conveying systems provisions.** Chapter 30 of  
1.23 the 2018 International Building Code is incorporated by reference, as amended in Minnesota  
1.24 Rules, chapter 1305, the Minnesota Building Code.

2.1 **1307.0027 DEFINITIONS.**

2.2 *[For text of subparts 1 and 1a, see Minnesota Rules]*

2.3 Subp. 2. **ASME A17.1/CSA B44-2016.** "ASME A17.1/CSA B44-2016" means the  
2.4 ASME A17.1/CSA B44-2016, Safety Code for Elevators and Escalators.

2.5 Subp. 3. **ASME A17.3-2015.** "ASME A17.3-2015" means the ASME A17.3-2015  
2.6 Safety Code for Existing Elevators and Escalators (and related equipment).

2.7 Subp. 4. **ASME A17.5-2014.** "ASME A17.5-2014" means the ASME A17.5-2014  
2.8 Elevators and Escalators Electrical Equipment.

2.9 Subp. 4a. **ASME A17.7/CSA B44.7-2007.** "ASME A17.7/CSA B44.7-2007" means  
2.10 the ASME A17.7/CSA B44.7-2007 Performance-Based Safety Codes for Elevators and  
2.11 Escalators.

2.12 Subp. 5. **ASME A18.1-2017.** "ASME A18.1-2017" means the ASME A18.1-2017  
2.13 Safety Standard for Platform Lifts and Stairway Chairlifts.

2.14 Subp. 6. **ASME A90.1-2015.** "ASME A90.1-2015" means the ASME A90.1-2015  
2.15 Safety Standard for Belt Manlifts.

2.16 Subp. 7. **ASME B20.1-2015.** "ASME B20.1-2015" means the ASME B20.1-2015  
2.17 Safety Standard for Conveyors and Related Equipment.

2.18 *[For text of subparts 8 to 11, see Minnesota Rules]*

2.19 Subp. 12. **Dormant elevator, dormant dumbwaiter, or dormant escalator.** "Dormant  
2.20 elevator," "dormant dumbwaiter," or "dormant escalator" means an installation placed out  
2.21 of service as specified in ASME A17.1/CSA B44-2016, 8.11.1.4.

2.22 Subp. 13. **Endless belt lift.** "Endless belt lift" means belt manlifts and is governed by  
2.23 ASME A90.1-2015 Safety Standard for Belt Manlifts.

3.1 Subp. 14. **Existing installation.** "Existing installation" means that, before March 31,  
3.2 2020:

3.3 *[For text of items A and B, see Minnesota Rules]*

3.4 *[For text of subparts 15 to 17, see Minnesota Rules]*

3.5 Subp. 18. **Vertical reciprocating conveyor.** "Vertical reciprocating conveyor" means  
3.6 a vertical device for moving material only that is not designed to carry passengers or an  
3.7 operator, and that is governed by ASME B20.1-2015, Safety Standard for Conveyors and  
3.8 Related Equipment.

3.9 **1307.0030 PERMITS.**

3.10 Subpart 1. **Permits required.** It is unlawful for any person, firm, or corporation to  
3.11 hereafter install any new passenger elevators, freight elevators, handpowered elevators,  
3.12 moving walks, escalators, dumbwaiters, wheelchair lifts, endless belt lifts, vertical  
3.13 reciprocating conveyors, stage and orchestra lifts, or any other related device, or make  
3.14 alterations or repairs to or remove any existing of the same without having first obtained a  
3.15 permit for the work from the authority having jurisdiction. Alterations, modifications, and  
3.16 practical difficulties will be done in keeping with the rules of the Department of Labor and  
3.17 Industry.

3.18 Permits for repairs are required by the Department of Labor and Industry for the  
3.19 following ASME A17.1/CSA B44-2016 sections: 8.6.2.3 repair of speed governors; 8.6.2.4  
3.20 repair of releasing carrier; 8.6.3.3 suspension means fastenings and hitch plates; 8.6.3.4  
3.21 replacement of governor rope; 8.6.3.6 replacement of speed governor; 8.6.3.9 replacement  
3.22 of releasing carrier; and 8.6.3.10 replacement of hydraulic jack plunger; cylinder, tanks,  
3.23 valve, and anticreep leveling device.

3.24 *[For text of subparts 2 and 3, see Minnesota Rules]*

4.1 Subp. 4. **Certificate of operation required.** It is unlawful to operate equipment  
4.2 governed by ASME A17.1/CSA B44-2016, ASME A17.3-2015, and ASME A90.1-2015  
4.3 without a current Certificate of Operation issued by the authority having jurisdiction. The  
4.4 certificate will be issued upon payment of prescribed fees and the presentation of a valid  
4.5 inspection report indicating that the conveyance is safe and that the inspections and tests  
4.6 have been performed according to this code. A certificate will not be issued when the  
4.7 conveyance is posted as unsafe.

4.8 Subp. 5. **Application for certificate of operation.** Application for a certificate of  
4.9 operation shall be made by the owner, or an authorized representative, for equipment  
4.10 governed by ASME A17.1/CSA B44-2016, ASME A17.3-2015, and ASME A90.1-2015.  
4.11 The application shall be accompanied by an inspection report. Fees for the Certificate of  
4.12 Operation shall be as specified by the administrative authority.

4.13 **1307.0035 INSPECTION, TESTS, AND APPROVALS.**

4.14 *[For text of subpart 1, see Minnesota Rules]*

4.15 Subp. 2. **Inspections and tests.** No person, firm, or corporation may put into service  
4.16 any installation covered by this chapter whether the installation is newly installed, relocated,  
4.17 or altered materially, without the installation being inspected and approved by the authority  
4.18 having jurisdiction. The installer of any equipment included in this chapter must request  
4.19 inspections by notifying the authority having jurisdiction to schedule a date and time for  
4.20 inspection. The authority having jurisdiction shall require tests as described in the applicable  
4.21 ASME Code to prove the safe operation of the installation.

4.22 Subp. 3. **Approval.** A certificate or letter of approval shall be issued by the authority  
4.23 having jurisdiction for equipment governed by ASME A17.1/CSA B44-2016, ASME  
4.24 A17.3-2015, ASME A90.1-2015, and ASME B20.1-2015 when the entire installation is  
4.25 completed in conformity with this code.

5.1 *[For text of subpart 4, see Minnesota Rules]*

5.2 **1307.0047 SPECIAL PROVISIONS.**

5.3 Subpart 1. **Scope.** The special provisions in this part apply to the design, construction,  
5.4 and installation of equipment governed by ASME A17.1/CSA B44-2016 and ASME  
5.5 A17.3-2015.

5.6 Subp. 2. **Chairlifts.** Inclined stairway chairlifts shall only be installed within a private  
5.7 residence or as approved in accordance with Minnesota Statutes, section 471.471. The  
5.8 installation shall be in accordance with ASME A18.1-2017.

5.9 *[For text of subpart 3, see Minnesota Rules]*

5.10 Subp. 4. **Rooftop elevators.** Passenger and freight elevators are permitted at rooftops  
5.11 when conditioned space or rooftop elevators meeting ASME A17.1/CSA B44-2016 5.6 are  
5.12 provided.

5.13 *[For text of subparts 5 to 7, see Minnesota Rules]*

5.14 Subp. 8. [See repealer.]

5.15 Subp. 9. **All work required for compliance with ASME A17.1/CSA B44-2016**  
5.16 **8.6.5.8 Bulkhead Material Transfer Device.** Elevators shall not be converted to a material  
5.17 transfer device (vertical reciprocating conveyor) without meeting the requirements of ASME  
5.18 A17.1/CSA B44-2016 8.6.5.8, Safety Bulkhead. A material transfer device shall comply  
5.19 with ASME B20.1-2015.

5.20 Subp. 10. [See repealer.]

5.21 Subp. 11. [See repealer.]

5.22 Subp. 12. [See repealer.]

5.23 Subp. 13. [See repealer.]

6.1 Subp. 14. [See repealer.]

6.2 Subp. 15. **ASME A17.3-2015 2.2.4 Temperature control.** Machine rooms shall be  
6.3 provided with natural or mechanical means to avoid overheating of the electrical equipment  
6.4 and to ensure safe and normal operation of the elevator.

6.5 *[For text of subpart 16, see Minnesota Rules]*

6.6 **1307.0067 AMENDMENTS TO ASME A17.1/CSA B44-2016.**

6.7 Subpart 1. **ASME A17.1/CSA B44-2016 2.2.2.4.** ASME A17.1/CSA B44-2016 2.2.2.4  
6.8 is amended by adding a paragraph to read as follows:

6.9 An elevator pit drain shall discharge to the sanitary sewer using an indirect connection  
6.10 that precludes the possibility of sewage backup into the pit. If a sump is used, it shall be  
6.11 located outside the pit with a dry pan drain flowing to it. The sump for the elevator pit drain  
6.12 shall not be located in the elevator machine room.

6.13 Subp. 2. **ASME A17.1/CSA B44-2016 2.5.1.1 Between car and hoistway**  
6.14 **enclosures.** ASME A17.1/CSA B44-2016 2.5.1.1 is amended to read as follows:

6.15 **2.5.1.1. Between car and hoistway enclosures.** The clearance between the car and the  
6.16 hoistway enclosures shall not be less than 0.8 inches (20 mm), except on the sides used for  
6.17 loading and unloading. The distance between the car and the hydraulic piping, hydraulic  
6.18 fittings, electrical piping, electrical boxes, steam or hot water piping where permitted,  
6.19 sprinkler piping, where permitted, or any other item not by elevator design shall not be less  
6.20 than 0.8 inches (20 mm).

6.21 Subp. 3. **ASME A17.1/CSA B44-2016 2.7.3.1 General requirements.** ASME  
6.22 A17.1/CSA B44-2016 2.7.3.1 is amended by adding the following:

6.23 2.7.3.1.4 Access to elevator equipment space as referenced in 2.7.3.1.1 and 2.7.3.1.2  
6.24 shall not be through any toilet room.

7.1 Subp. 4. **ASME A17.1/CSA B44-2016 2.7.4.1.** ASME A17.1/CSA B44-2016 2.7.4.1  
7.2 is amended by adding a sentence to the end of the section as follows:

7.3 Raised surfaces intended as working space surrounding equipment shall have 72 inches  
7.4 clear headroom measured from the working surface.

7.5 Subp. 5. **ASME A17.1/CSA B44-2016 2.12.6.2.5.** ASME A17.1/CSA B44-2016  
7.6 2.12.6.2.5 is amended to read as follows:

7.7 The unlocking-device keyway and locked panel (see ASME A17.1/CSA B44-2016  
7.8 2.12.6.2.3) if provided, shall be located at a height not greater than 83 inches (2100 mm)  
7.9 above the landing and all keyways, with the exception of the keyway at the bottom landing  
7.10 and all private residence elevator keyways, shall have keyed plugs installed with the key  
7.11 for those plugs kept in the key box as defined in subpart 9.

7.12 Subp. 6. **ASME A17.1/CSA B44-2016 2.12.7.1.** ASME A17.1/CSA B44-2016 2.12.7.1  
7.13 is amended to read as follows:

7.14 **2.12.7.1.1** Hoistway access switches shall be provided when the rate of speed is greater than  
7.15 30 ft./min. at:

7.16 *[For text of items A and B, see Minnesota Rules]*

7.17 Subp. 7. **ASME A17.1/CSA B44-2016 2.12.7.1.2.** ASME A17.1/CSA B44-2016  
7.18 2.12.7.1.2 is deleted in its entirety.

7.19 Subp. 8. **ASME A17.1/CSA B44-2016 2.14.7.1.4.** ASME A17.1/CSA B44-2016  
7.20 2.14.7.1.4 is amended to read as follows:

7.21 Each elevator shall be provided with an electric light that includes an OSHA-recognized  
7.22 guard and a GFCI convenience outlet fixture on both the car top and the bottom of the car.

8.1 Subp. 9. **ASME A17.1/CSA B44-2016 2.27 Emergency operation and signaling**  
8.2 **devices.** ASME A17.1/CSA B44-2016 2.27 is amended by adding the following language  
8.3 at the beginning of section 2.27.8:

8.4 **2.27.8 Switch keys.** The key switches required by ASME A17.1/CSA B44-2016 2.27.2  
8.5 to 2.27.5 for elevators in a building shall be operable by the same key. The keys shall be a  
8.6 Group 3 Security (see section 8.1). There shall be a key for each switch provided. Keys  
8.7 shall be painted or marked red.

8.8 These keys shall be kept on premises, in a key box labeled "Fire Dept" approved by  
8.9 the authority having jurisdiction. The key box shall be located in the elevator lobby, on the  
8.10 main egress floor or in the fire command room. When there is not a fire command room  
8.11 and site conditions prohibit installation at the elevator lobby, the authority having jurisdiction  
8.12 shall specify the location of the Fire Dept key box. Keys for emergency access doors  
8.13 (2.11.1.2) and hoistway door unlocking device (2.12.6.2.4) of Group 1 shall be accessible  
8.14 to emergency personnel and a set shall be included in the elevator emergency key box.

8.15 Where applicable, Groups 1, 2, and 3 (see section 8.1) security shall be provided in a  
8.16 separate black trimmed key box approved by the authority having jurisdiction. The key box  
8.17 shall be labeled "Elevator Personnel Only" located in the elevator machine room or location  
8.18 specified by the authority having jurisdiction. Keys shall be tagged and labeled. The locked  
8.19 cylinder shall be uniformly keyed throughout the state.

8.20 Subp. 10. **ASME A17.1/CSA B44-2016 2.27.1.1.3(a).** ASME A17.1/CSA B44-2016  
8.21 2.27.1.1.3(a) is deleted in its entirety.

8.22 Subp. 11. **ASME A17.1/CSA B44-2016 3.28.1 Information included on layout**  
8.23 **drawing.** ASME A17.1/CSA B44-2016 3.28.1 is amended by adding the following subitem:

8.24 (p) the method used to comply with 3.18.3.8 (protection of cylinders buried in the  
8.25 ground).



9.1 Subp. 12. **ASME A17.1/CSA B44-2016 4.3.15 Car safeties.** ASME A17.1/CSA  
9.2 B44-2016 4.3.15 is amended by adding a sentence to read as follows:

9.3 All hand-powered elevators shall be equipped with a broken rope safety device.

9.4 Subp. 13. **ASME A17.1/CSA B44-2016 7.2.4.6 Application of safeties.** ASME  
9.5 A17.1/CSA B44-2016 7.2.4.6 is amended by adding a sentence at the end of the section as  
9.6 follows:

9.7 All hand-powered dumbwaiters shall be equipped with a broken rope safety device.

9.8 Subp. 14. **ASME A17.1/CSA B44-2016 8.10.1.1.3.** ASME A17.1/CSA B44-2016  
9.9 8.10.1.1.3 is deleted and replaced with the following:

9.10 **Elevator inspector qualifications.** Inspectors shall have a current license issued by the  
9.11 Department of Labor and Industry as a master elevator constructor or elevator journeyworker  
9.12 constructor.

9.13 Inspectors shall have proof of successful completion of the National Elevator Industry  
9.14 Education program examination, equivalent program, or equivalent experience. Within 18  
9.15 months of the employment start date, any person performing inspections shall be certified  
9.16 to the ASME QEI-1 standard as a qualified elevator inspector (QEI) by an organization  
9.17 recognized by the commissioner. Upon initial certification, persons performing inspections  
9.18 shall maintain the QEI certification.

9.19 Subp. 15. **ASME A17.1/CSA B44-2016 8.11.1.3 Periodic inspection and test**  
9.20 **frequency.** ASME A17.1/CSA B44-2016 8.11.1.3 Periodic inspection and test frequency.  
9.21 The frequency as established by the authority having jurisdiction shall be as stated in the  
9.22 Minnesota Table N-1.

9.23 MINNESOTA TABLE N-1

9.24 INSPECTION AND TEST INTERVALS IN "MONTHS"

		Periodic Tests				
		Periodic Inspections		Category 1		
10.3	Reference Section	Equipment Type	Requirement	Interval	Requirement	Interval
10.5	8.11.2	Electric elevators	8.11.2.1	12	8.6.4.19	12
10.6	8.11.3	Hydraulic elevators	8.11.3.1	12	8.6.5.14	12
10.7	8.11.4	Escalators & moving walks	8.11.4.1	12	8.6.8.15	12
10.8	8.11.5.1	Sidewalk elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.10	8.11.5.3	Hand elevators	8.11.2.1	12	8.6.4.19	12
10.11	8.11.5.4	Dumbwaiters	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.13	8.11.5.5	Material lifts & dumbwaiters w/automatic transfer devices	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.15	8.11.5.6	Special purpose personnel elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.17	8.11.5.7	Inclined elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.19	8.11.5.8	Shipboard elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.21	8.11.5.9	Screw-column elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.23	8.11.5.10	Rooftop elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.25	8.11.5.12	Limited use/limited-application elevators	8.11.2.1, 8.11.3.1	12	8.6.4.19, 8.6.5.14	12
10.27	8.11.5.13	Elevators used for construction	8.11.2.1, 8.11.3.1	3	8.6.4.19, 8.6.5.14	12
10.29	Periodic Tests					
10.30			Periodic Inspections		Category 3	
10.31	Reference Section	Equipment Type	Requirement	Interval	Requirement	Interval
10.33	8.11.2	Electric elevators	8.11.2.1	12	N/A	N/A

11.1	8.11.3	Hydraulic elevators	8.11.3.1	12	8.6.5.15	60
11.2	8.11.4	Escalators & moving walks	8.11.4.1	12	N/A	N/A
11.3	8.11.5.1	Sidewalk elevators	8.11.2.1,	12	8.6.5.15	60
11.4			8.11.3.1			
11.5	8.11.5.3	Hand elevators	8.11.2.1	12	N/A	N/A
11.6	8.11.5.4	Dumbwaiters	8.11.2.1,	12	8.6.5.15	60
11.7			8.11.3.1			
11.8	8.11.5.5	Material lifts & dumbwaiters	8.11.2.1,	12	8.6.5.15	60
11.9		w/automatic transfer devices	8.11.3.1			
11.10	8.11.5.6	Special purpose personnel	8.11.2.1,	12	8.6.5.15	60
11.11		elevators	8.11.3.1			
11.12	8.11.5.7	Inclined elevators	8.11.2.1,	12	8.6.5.15	60
11.13			8.11.3.1			
11.14	8.11.5.8	Shipboard elevators	8.11.2.1,	12	8.6.5.15	60
11.15			8.11.3.1			
11.16	8.11.5.9	Screw-column elevators	8.11.2.1,	12	8.6.5.15	60
11.17			8.11.3.1			
11.18	8.11.5.10	Rooftop elevators	8.11.2.1,	12	8.6.5.15	60
11.19			8.11.3.1			
11.20	8.11.5.12	Limited use/limited-application	8.11.2.1,	12	8.6.5.15	60
11.21		elevators	8.11.3.1			
11.22	8.11.5.13	Elevators used for construction	8.11.2.1,	3	8.6.5.15	60
11.23			8.11.3.1			
11.24					Periodic Tests	
11.25					Periodic Inspections	Category 5
11.26	Reference	Equipment Type	Require-	Interval	Require-	Interval
11.27	Section		ment		ment	
11.28	8.11.2	Electric elevators	8.11.2.1	12	8.6.4.20	60
11.29	8.11.3	Hydraulic elevators	8.11.3.1	12	8.6.5.16	60
11.30	8.11.4	Escalators & moving walks	8.11.4.1	12	N/A	N/A
11.31	8.11.5.1	Sidewalk elevators	8.11.2.1,	12	8.6.4.20,	60
11.32			8.11.3.1		8.6.5.16	

12.1	8.11.5.3	Hand elevators	8.11.2.1	12	8.6.4.20,	60
12.2					8.6.5.16	
12.3	8.11.5.4	Dumbwaiters	8.11.2.1,	12	8.6.4.20,	60
12.4			8.11.3.1		8.6.5.16	
12.5	8.11.5.5	Material lifts & dumbwaiters	8.11.2.1,	12	8.6.4.20,	60
12.6		w/automatic transfer devices	8.11.3.1		8.6.5.16	
12.7	8.11.5.6	Special purpose personnel	8.11.2.1,	12	8.6.4.20,	60
12.8		elevators	8.11.3.1		8.6.5.16	
12.9	8.11.5.7	Inclined elevators	8.11.2.1,	12	8.6.4.20,	60
12.10			8.11.3.1		8.6.5.16	
12.11	8.11.5.8	Shipboard elevators	8.11.2.1,	12	8.6.4.20,	60
12.12			8.11.3.1		8.6.5.16	
12.13	8.11.5.9	Screw-column elevators	8.11.2.1,	12	8.6.4.20,	60
12.14			8.11.3.1		8.6.5.16	
12.15	8.11.5.10	Rooftop elevators	8.11.2.1,	12	8.6.4.20,	60
12.16			8.11.3.1		8.6.5.16	
12.17	8.11.5.12	Limited use/limited-application	8.11.2.1,	12	8.6.4.20,	60
12.18		elevators	8.11.3.1		8.6.5.16	
12.19	8.11.5.13	Elevators used for construction	8.11.2.1,	3	8.6.4.20,	60
12.20			8.11.3.1		8.6.5.16	

12.21 GENERAL NOTE: The intervals in this table shall be for periodic tests and inspections.  
 12.22 Factors such as the environment, frequency and type of usage, quality of maintenance, etc.,  
 12.23 related to the equipment should be taken into account by the authority having jurisdiction  
 12.24 prior to establishing more frequent inspection and test intervals.

12.25 **1307.0090 EXISTING INSTALLATIONS.**

12.26 Subpart 1. [Repealed, 31 SR 935]

12.27 Subp. 2. **Conditions for continued operation.** All existing installations of equipment  
 12.28 governed by ASME A17.1/CSA B44-2016, ASME A17.3-2015, and ASME A90.1-2015  
 12.29 may be continued in service as long as they are properly maintained and are, in the opinion  
 12.30 of the authority having jurisdiction, installed and maintained in a safe condition. The authority

13.1 having jurisdiction shall order the installation of the following basic safety devices: automatic  
13.2 noncontact door reopening devices; top of car, under car lights, and pit lights, with ground  
13.3 fault interrupter outlets; pit ladder; emergency door unlocking device; and emergency lock  
13.4 box complying with part 1307.0067, subpart 9. All hand-powered elevators and  
13.5 hand-powered dumbwaiters shall be equipped with a broken rope safety device. Elevator  
13.6 machine room lighting shall meet the requirements of ASME A17.1/CSA B44-2016 2.7.9.1  
13.7 to provide 19 footcandles of illumination at the floor level. The installation of these safety  
13.8 devices does not require compliance with ASME A17.1/CSA B44-2016.

13.9 *[For text of subparts 3 to 5, see Minnesota Rules]*

13.10 Subp. 6. **Other requirements.** Existing installations covered by subpart 2 shall  
13.11 conform to the requirements of: ASME A17.1/CSA B44-2016 Part 1, and 5.10, 8.1, 8.6,  
13.12 8.7, 8.8, 8.9, 8.10, and 8.11 as amended by this and other sections of this chapter. Alterations  
13.13 shall conform to the requirements of ASME A17.1/CSA B44-2016, Part 8.7, or ASME  
13.14 A17.3-2015, whichever is more restrictive.

13.15 Subp. 7. **Compliance schedule.** The authority having jurisdiction shall notify the  
13.16 owner of an existing elevator of the applicable ASME code and its associated state  
13.17 amendments (1) at the time of adoption or (2) following inspection of an elevator not in  
13.18 compliance with the applicable ASME code and its associated state amendments. The  
13.19 following applies to elevators or related devices upon the owner receiving notification:

13.20 *[For text of item A, see Minnesota Rules]*

13.21 B. Where noncompliance with the applicable ASME code and its associated state  
13.22 amendments does not create an imminent danger, the owner or manager of the property  
13.23 shall submit for review and approval a time schedule for compliance with the authority  
13.24 having jurisdiction within 60 calendar days of receipt of notification by the authority having  
13.25 jurisdiction.

14.1 Any compliance schedule submitted for an existing elevator shall result in compliance  
14.2 with the code requirements within five years of submission of the compliance schedule.  
14.3 ~~Elevators not in compliance with the code requirements~~ The authority having jurisdiction,  
14.4 acting under Minnesota Statutes, section 326B.175, is authorized to take an elevator that is  
14.5 not in compliance with the code requirements within five years of submission of the  
14.6 compliance schedule ~~may be taken~~, out of service as ~~provided in Minnesota Statutes, section~~  
14.7 ~~326B.175.~~

14.8 Subp. 8. **Removal of existing elevators, dumbwaiters, escalators and moving walks.**

14.9 *[For text of items A to D, see Minnesota Rules]*

14.10 E. **Dormant elevator, dormant dumbwaiter, or dormant escalator.** A dormant  
14.11 elevator, dormant dumbwaiter, or dormant escalator shall be placed out of service in  
14.12 accordance with ASME A17.1/CSA B44-2016 8.11.1.4.

14.13 F. **Temporarily dormant elevator, temporarily dormant dumbwaiter, or**  
14.14 **temporarily dormant escalator.** A temporarily dormant elevator, temporarily dormant  
14.15 dumbwaiter, or temporarily dormant escalator shall have its power disconnected by removing  
14.16 fuses, where applicable, and placing a seal on the mainline disconnect switch in the "OFF"  
14.17 position. The car shall be parked and the hoistway doors left in the closed and latched  
14.18 position. A wire seal and notification shall be installed on the mainline disconnect switch  
14.19 by an authority having jurisdiction. This installation shall not be used until it has been put  
14.20 in safe running order and is in condition for use. Annual inspections shall continue for the  
14.21 duration of the temporarily dormant status by an authority having jurisdiction. The  
14.22 temporarily dormant status shall be reviewed on an annual basis, and shall not exceed a  
14.23 three-year period. The inspector shall file a report with the supervising authority having  
14.24 jurisdiction describing the current conditions. The wire seal and notification shall not be  
14.25 removed for any purpose without permission from the authority having jurisdiction. When  
14.26 the elevator, dumbwaiter, or escalator has exceeded the three-year temporarily dormant

15.1 status, the unit shall be placed out of service according to ASME A17.1/CSA B44-2016  
15.2 8.11.1.4.

15.3 **1307.0092 REFERENCED CODES, STANDARDS, AND SPECIFICATIONS.**

15.4 **Section 9.1 ASME A17.1 referenced documents.** References to NFPA 13-1985 shall  
15.5 be deleted and replaced with references to NFPA 13-2016.

15.6 **1307.0110 MINNESOTA AMENDMENTS TO ASME A18.1-2017.**

15.7 Subpart 1. **ASME A18.1-2017 section 2.1 Runways.**

15.8 A. ASME A18.1-2017 2.1.2.5 is amended to read as follows:

15.9 **2.1.2.5.** All doors, except as provided in paragraph 2.1.2.9, shall be provided with a  
15.10 combination mechanical lock and electric contact. Locking devices shall be protected against  
15.11 tampering from the landing side. The locking devices shall permit a door to be opened only  
15.12 if the platform floor is within 51 mm (2 inches) of the respective landing. The platform shall  
15.13 be permitted to move away from the landing under control of the normal operating device  
15.14 if the door is closed but not locked, provided that the device will cause the platform to stop  
15.15 if it moves more than 51 mm (2 inches) away from the landing before the door is locked.

15.16 B. ASME A18.1-2017 2.1.2 Partial runway enclosure provided, is amended by  
15.17 adding a new paragraph 2.1.2.9 to read as follows:

15.18 **2.1.2.9.** Where the lift is installed at a location that does not have guards at the upper  
15.19 landing as allowed by building codes (see definition), the requirements of paragraphs 2.1.2.2,  
15.20 2.1.2.3, and 2.1.2.4 shall be permitted to be omitted when platform gates are provided. They  
15.21 shall extend to a height at least equal to the top terminal landing height plus 152 mm (6  
15.22 inches) measured when the platform is at its lowest position. The gates shall be of  
15.23 unperforated construction, self-closing, and be provided with electric contact to prevent  
15.24 movement of the platform if the gates are not closed. The gates shall not be permanently

16.1 deformed when a force of 556 N (125 lbf) is applied on any 102 mm (4 inches) by 102 mm  
16.2 (4 inches) area.

16.3 C. ASME A18.1-2017 2.1.2 Partial runway enclosure provided, is amended by  
16.4 adding a new paragraph 2.1.2.10 to read as follows:

16.5 **2.1.2.10.** The clearance between the platform floor and the upper landing sill shall be  
16.6 permitted to be increased to 76 mm (3 inches) if a platform gate complying with paragraph  
16.7 2.1.2.9 and an automatically folding ramp to service the upper landing is provided. When  
16.8 deployed, the ramp shall have a minimum overlap at the upper landing sill of 51 mm (2  
16.9 inches) and shall be substantially level. It shall be provided with an electric contact, which  
16.10 will stop the movement of the platform within 152 mm (6 inches) of travel away from the  
16.11 upper landing if the ramp has failed to rise to its retracted position.

16.12 D. ASME A18.1-2017 2.1.3 Runway enclosure not provided.

16.13 For purposes of A18.1-2017 section 2 Vertical platform lifts, 2.1.3 is deleted in its  
16.14 entirety. However, as referenced in A18.1-2017 section 5.1 Runways, 2.1.3 remains in full  
16.15 force and effect.

16.16 E. ASME A18.1-2017 2.1.7 Lower level access ramps and pits is amended to read  
16.17 as follows:

16.18 **2.1.7 Lower level across ramps and pits.** Lifts shall be permitted to have a pit. Where  
16.19 a pit is not provided, a floor-mounted or retractable platform floor-mounted ramp complying  
16.20 with the requirements for ramps in ICC/ANSI A117.1 and having a maximum rise of 102  
16.21 mm (4 inches) shall be provided. When backing down an incline from the lift platform may  
16.22 be necessary, the slope of the incline shall not exceed 1 in 20.

16.23 F. ASME A18.1-2017 2.1.7.1 is deleted in its entirety.

16.24 G. ASME A18.1-2017 2.1.7.2 is deleted in its entirety.



17.1 Subp. 2. [Repealed, 39 SR 91]

17.2 Subp. 3. **ASME A18.1-2017 section 2.10 Operating devices and control equipment.**

17.3 A. ASME A18.1-2017 2.10.1 Operation is amended to read as follows:

17.4 **2.10.1 Operation.** Operation of the lift from the landings and from the platform shall  
17.5 be controlled by "UP" and "DOWN" control switches at all stations, and shall be by means  
17.6 of the continuous pressure type. Control switches shall be 51 mm (2 inches) minimum wide  
17.7 and 102 mm (4 inches) minimum high. Controls shall be 1219 mm (48 inches) maximum  
17.8 and 381 mm (15 inches) minimum above the platform floor or facility floor or ground level.  
17.9 Operation devices shall be designed so that both the "UP" and "DOWN" circuits cannot be  
17.10 operated at the same time.

17.11 B. ASME A18.1-2017 2.10.2.2 is amended to read as follows:

17.12 **2.10.2.2.** The attendant shall operate the platform by means of a continuous pressure  
17.13 switch so located that the attendant has full view of the platform throughout its travel. A  
17.14 manually reset emergency stop switch shall also be provided at that location.

17.15 Subp. 4. **ASME A18.1-2017 section 2.11 Emergency signals.**

17.16 A. ASME A18.1-2017 section 2.11 Emergency signals is amended to read as  
17.17 follows:

17.18 **2.11 Emergency signals.** If the platform is installed in an area not visible or audible  
17.19 to persons at all times, or installed in an enclosed runway, emergency signaling devices  
17.20 shall be provided in accordance with the requirements of paragraphs 2.11.1 and 2.11.2.  
17.21 Standby power shall be provided in accordance with paragraph 2.11.3.

17.22 B. ASME A18.1-2017 2.11.2 is amended to read as follows:

17.23 **2.11.2.** The lift shall be provided with a means of two-way communication complying  
17.24 with ASME A17.1/CSA B44-2016.

18.1 Subp. 5. **ASME A18.1-2017 section 2.12 Standby power.** ASME A18.1-2017 section  
18.2 2.12 Standby power is amended as follows:

18.3 **2.12 Standby power.** In buildings and structures where standby power is required or  
18.4 furnished to operate a vertical lift, the operation shall be in accordance with section 2.12.  
18.5 Lifts not required to provide standby power are not required to be equipped with battery  
18.6 power.

18.7 **2.12.1 Standby power.** Except where permitted by 2.12.1.1, the vertical lift shall be  
18.8 powered by a standby power system from the building.

18.9 **2.12.1.1 Battery power.** A lift equipped with rechargeable battery power capable of  
18.10 cycling the lift under full load for five cycles minimum after building power is removed  
18.11 shall be permitted.

18.12 **2.12.2 Battery power, rated number of cycles.** Except where permitted by 2.12.3,  
18.13 where a lift provided with battery power serves an area with more wheelchair users than  
18.14 the rated number of cycles provided by battery power, or where the authority having  
18.15 jurisdiction determines that the anticipated number of wheelchair users is greater than the  
18.16 rated number of cycles provided by battery power, the lift shall be powered by a standby  
18.17 power system from the building.

18.18 **2.12.3 Existing buildings without standby power.** Where an existing building is not  
18.19 required to provide a building standby power system, the installation of a lift shall not require  
18.20 the installation of a building standby power system. A battery standby power system  
18.21 complying with 2.12.1.1 shall be provided.

18.22 **2.12.4 Auxiliary items.** Auxiliary items necessary for lift operation such as power  
18.23 doors and runway lighting shall remain operational under standby power.

18.24 Subp. 6. **ASME A18.1-2017 3.6.8 Platform guarding.** ASME A18.1-2017 3.6.8  
18.25 Platform guarding is amended to read as follows:

19.1 **3.6.8 Platform guarding.** Platform guarding shall be in accordance with paragraph  
19.2 3.6.8.1, or, when safety issues are effectively addressed and approved by the authority  
19.3 having jurisdiction, in accordance with paragraph 3.6.8.2.

19.4 Subp. 7. **ASME A18.1-2017 section 3.10.1 Operation.** ASME A18.1-2017 3.10.1  
19.5 Operation is amended to read as follows:

19.6 **3.10.1 Operation.** Operation of the lift from the landings and from the platform shall  
19.7 be controlled by control switches at all stations, and shall be by means of the continuous  
19.8 pressure type. Control switches shall be 2 inches (50 mm) minimum wide and 4 inches (100  
19.9 mm) minimum high. Controls shall be 48 inches (1220 mm) maximum and 15 inches (380  
19.10 mm) minimum above the platform floor or facility floor or ground level. Controls shall be  
19.11 located within forward or side reach of the passenger as defined in ANSI A117.1. Operation  
19.12 devices shall be designed so that both the "UP" and "DOWN" circuits cannot be operated  
19.13 at the same time.

19.14 Subp. 8. **ASME A18.1-2017 section 3.11 Emergency signals.**

19.15 A. ASME A18.1-2017 section 3.11 Emergency signals is amended to read as  
19.16 follows:

19.17 **3.11 Emergency signals.** If the lift is installed in an area not visible or audible to  
19.18 persons at all times, or installed in an enclosed runway, emergency signaling devices shall  
19.19 be provided in accordance with the requirements of paragraphs 3.11.1 and 3.11.2.

19.20 B. ASME A18.1-2017 3.11.2 is amended to read as follows:

19.21 **ASME 3.11.2.** The lift shall be provided with a means of two-way communication  
19.22 complying with ASME A17.1/CSA B44-2016.

19.23 Subp. 9. **ASME A18.1-2017 section 3.12 Standby power.** ASME A18.1-2017 section  
19.24 3.12 Standby power is amended to read as follows:

20.1           **3.12 Standby power.** In buildings and structures where standby power is required or  
20.2 furnished to operate an inclined lift, the operation shall be in accordance with section 3.12.  
20.3 Lifts not required to provide standby power are not required to be equipped with battery  
20.4 power.

20.5           **3.12.1 Standby power.** Except where permitted by paragraph 3.12.1.1, the inclined  
20.6 lift shall be powered by a standby power system from the building.

20.7           **3.12.1.1 Battery power.** A lift equipped with rechargeable battery power capable of  
20.8 cycling the lift under full load for five cycles minimum after building power is removed  
20.9 shall be permitted.

20.10          **3.12.2 Battery power, rated number of cycles.** Except where permitted by paragraph  
20.11 3.12.3, where a lift provided with battery power serves an area with more wheelchair users  
20.12 than the rated number of cycles provided by battery power, or where the authority having  
20.13 jurisdiction determines that the anticipated number of wheelchair users is greater than the  
20.14 rated number of cycles provided by battery power, the lift shall be powered by a standby  
20.15 power system from the building.

20.16          **3.12.3 Existing buildings without standby power.** Where an existing building is not  
20.17 required to provide a building standby power system, the installation of a lift shall not require  
20.18 the installation of a building standby power system. A battery standby power system  
20.19 complying with 3.12.1.1 shall be provided.

20.20          **3.12.4 Auxiliary items.** Auxiliary items necessary for lift operation such as power  
20.21 doors and runway lighting shall remain operational under standby power.

20.22          Subp. 10. **ASME A18.1-2017 6.1.1 Clearances.** ASME A18.1-2017 6.1.1 Clearances  
20.23 is amended to read as follows:

20.24          **6.1.1 Clearances.** Clearances between the platform and adjacent surfaces shall not be  
20.25 less than 20 mm (.75 inches). At no point in its travel shall the edge of the platform facing

21.1 the upper landing be more than 600 mm (24 inches) above a step or landing as measured  
21.2 vertically. Headroom clearance measured vertically from any position on the platform floor  
21.3 shall be 1372 mm (54 inches) minimum throughout the travel of the platform or alternate  
21.4 methods, approved by the authority having jurisdiction, shall be provided, which will stop  
21.5 the movement of the platform in the direction of travel should the clearance be reduced.

21.6 **REPEALER.** Minnesota Rules, parts 1307.0047, subparts 8, 10, 11, 12, 13, and 14; and  
21.7 1307.0095, are repealed.

21.8 **EFFECTIVE DATE.** This rule is effective March 31, 2020, or five business days after  
21.9 publication of the notice of adoption in the State Register, whichever is later.