

Office of the Revisor of Statutes

Administrative Rules



TITLE: Adopted Permanent Rules Adopting Changes to Minnesota Rules, Chapter 1311,
Rehabilitation of Existing Buildings

AGENCY: Department of Labor and Industry

REVISOR ID: R-4511

MINNESOTA RULES: Chapter 1311

The attached rules are approved for
filing with the Secretary of State

A handwritten signature in cursive script that reads "Sheree Speer".

Sheree Speer
Assistant Deputy Revisor

1.1 **Department of Labor and Industry**

1.2 **Adopted Permanent Rules Adopting Changes to Minnesota Rules, Chapter 1311,**
1.3 **Rehabilitation of Existing Buildings**

1.4 **1311.0010 ADOPTION BY REFERENCE OF THE INTERNATIONAL EXISTING**
1.5 **BUILDING CODE.**

1.6 Subpart 1. **General.** For the purposes of this chapter, "IEBC" means the 2018 edition
1.7 of the International Existing Building Code as promulgated by the International Code Council
1.8 (ICC), Washington, D.C. The IEBC is incorporated by reference and made a part of the
1.9 Minnesota State Building Code, except as qualified by the applicable provisions in Minnesota
1.10 Rules, chapter 1300, and as amended in this chapter. Portions of this publication reproduce
1.11 excerpts from the 2018 IEBC, International Code Council (ICC), Washington, D.C.,
1.12 reproduced with permission, all rights reserved. The 2018 IEBC is not subject to frequent
1.13 change and a copy of the 2018 IEBC, with amendments for use in Minnesota, is available
1.14 in the office of the commissioner of labor and industry.

1.15 Subp. 1a. **Deleted appendices.** The appendices to the IEBC are deleted and are not
1.16 made a part of this code.

1.17 Subp. 2. **Mandatory chapters.** IEBC chapters 2 to 16 are required and are incorporated
1.18 into the Minnesota State Building Code, except as qualified by the applicable provisions in
1.19 Minnesota Rules, chapter 1300, and as amended by this chapter. Amendments to IEBC
1.20 section 305 are incorporated by reference in this chapter, but the amendments to that section
1.21 are located in Minnesota Rules, chapter 1341, the Minnesota Accessibility Code. Referenced
1.22 documents cited in IEBC section 305, and Minnesota Rules, chapter 1341, apply, unless
1.23 otherwise stated or deleted. For the complete application and mandatory requirements
1.24 relating to IEBC section 305, see Minnesota Rules, chapter 1341.

1.25 Subp. 3. **Replacement chapters and provisions.** The following IEBC chapters or
1.26 sections are deleted and replaced with the provisions listed in items A to D:

3.1 Subp. 12. **Minnesota State Building Code.** References to the "Minnesota State
3.2 Building Code" in this chapter shall have the same meaning as "code" in part 1300.0070,
3.3 subpart 8.

3.4 **1311.0202 SECTION 202, GENERAL DEFINITIONS.**

3.5 Subpart 1. **Section 202, General definitions; added.** The following definitions are
3.6 added to IEBC section 202 as follows:

3.7 **APPROVED.** "Approved" means approval by the building official, pursuant to the Minnesota
3.8 State Building Code, by reason of: inspection, investigation, or testing; accepted principles;
3.9 computer simulations; research reports; or testing performed by either a licensed engineer
3.10 or by a locally or nationally recognized testing laboratory.

3.11 **CODE.** For purposes of this chapter, "the code" or "this code" means Minnesota Rules,
3.12 chapter 1311, Adoption of the International Existing Building Code.

3.13 Subp. 2. **Section 202, General definitions; amended.** The following definitions in
3.14 IEBC section 202 are amended to read as follows:

3.15 **CODE OFFICIAL.** "Code official" and "building code official" have the same meaning
3.16 as "building official" in part 1300.0070, subpart 5.

3.17 **EXISTING BUILDING.** "Existing building" means a building erected prior to the effective
3.18 date of this code, or one for which a legal building permit has been issued.

3.19 **HISTORIC BUILDING.** "Historic building" has the meaning given in part 1300.0070,
3.20 subpart 12a.

3.21 **REPAIR.** "Repair" means the reconstruction, individual component replacement, or renewal
3.22 of any part of an existing building for the purpose of its maintenance or to correct damage.

3.23 **SUBSTANTIAL DAMAGE.** "Substantial damage" means damage of any origin sustained
3.24 by a structure whereby the cost of restoring the structure to its before-damaged condition

4.1 would equal or exceed 50 percent of the market value of the structure before the damage
4.2 occurred.

4.3 **SUBSTANTIAL IMPROVEMENT.** "Substantial improvement" means any repair,
4.4 alteration, addition, or improvement of a building or structure, the cost of which equals or
4.5 exceeds 50 percent of the market value of the structure, before the improvement or repair
4.6 is started. If the structure has sustained substantial damage, any repairs are considered
4.7 substantial improvement regardless of the actual repair work performed. The term does not,
4.8 however, include either of the following:

4.9 1. any project for improvement of a building required to correct existing health, sanitary,
4.10 or safety code violations identified by the code official and that is the minimum
4.11 necessary to ensure safe living conditions; or

4.12 2. any alteration of a historic building, provided that the alteration will not preclude
4.13 the building's continued designation as a historic building.

4.14 **TECHNICALLY INFEASIBLE, ACCESSIBILITY.** "Technically infeasible, accessibility"
4.15 means an alteration of a building that has little likelihood of being accomplished because
4.16 the existing structural conditions require the removal or alteration of a load-bearing member
4.17 that is an essential part of the structural frame, or because other physical or site constraints
4.18 prohibit modification or addition of elements, spaces, or features which are in full and strict
4.19 compliance with the minimum requirements for new construction and which are necessary
4.20 to provide accessibility.

4.21 **TECHNICALLY INFEASIBLE, STAIR CONSTRUCTION.** "Technically infeasible,
4.22 stair construction" means an alteration of a building that has little likelihood of being
4.23 accomplished because the existing structural conditions require the removal or alteration
4.24 of a load-bearing structural element that is an essential part of the structural frame, or because
4.25 other existing physical or site constraints prohibit modification or addition of elements,

5.1 spaces, or features which are in full and strict compliance with the minimum requirements
5.2 for stair construction.

5.3 **1311.0301 SECTION 301, ADMINISTRATION.**

5.4 Subpart 1. **Section 301.3.1 Prescriptive compliance methods.** IEBC section 301.3.1
5.5 is amended to read as follows:

5.6 **301.3.1 Prescriptive compliance methods.** Alterations, additions, or changes of
5.7 occupancy complying with chapter 5 of this code shall be considered in compliance
5.8 with the provisions of this code.

5.9 Subp. 2. **Section 301.5 Compliance with accessibility.** IEBC section 301.5 is amended
5.10 to read as follows:

5.11 **301.5 Compliance with accessibility.** Accessibility requirements for existing buildings
5.12 shall comply with Minnesota Rules, chapter 1341, the Minnesota Accessibility Code.

5.13 **1311.0302 SECTION 302, GENERAL PROVISIONS.**

5.14 IEBC section 302.3 is amended by adding a subsection to read as follows:

5.15 **302.3.1 Window cleaning anchors.** Building anchors for window cleaning safety shall
5.16 comply with the Minnesota State Building Code.

5.17 **1311.0305 SECTION 305, ACCESSIBILITY FOR EXISTING BUILDINGS.**

5.18 IEBC section 305.1 is amended to read as follows:

5.19 **305.1 General.** Existing buildings or portions of existing buildings undergoing maintenance,
5.20 change of occupancy, additions, alterations, or reconstruction due to substantial damage or
5.21 substantial improvements shall be made accessible to persons with disabilities as required
5.22 by Minnesota Rules, chapter 1341. Refer to Minnesota Rules, chapter 1341, the Minnesota
5.23 Accessibility Code, for the complete application of section 305.

6.1 **1311.0402 [Renumbered 1311.0502]**

6.2 **1311.0403 [Renumbered 1311.0503]**

6.3 **1311.0405 [Renumbered 1311.0504]**

6.4 **1311.0405 SECTION 405, STRUCTURAL.**

6.5 IEBC section 405.2.4 is amended to read as follows:

6.6 **405.2.4 Substantial structural damage to gravity load-carrying components.** Gravity
 6.7 load-carrying components that have sustained substantial structural damage shall be
 6.8 rehabilitated to comply with the applicable provisions for all dead, live, or snow loads,
 6.9 including snow drift effects, in the International Building Code. Undamaged gravity
 6.10 load-carrying components that receive dead, live, or snow loads from rehabilitated
 6.11 components shall also be rehabilitated or shown to have the capacity to carry the design
 6.12 loads of the rehabilitation design.

6.13 (IEBC subsection 405.2.4.1 and the exceptions remain unchanged.)

6.14 **1311.0407 [Renumbered 1311.0506]**

6.15 **1311.0502 SECTION 502, ADDITIONS.**

6.16 Subpart 1. **Section 502.4 Existing structural elements carrying gravity load.** IEBC
 6.17 section 502.4 is amended to read as follows:

6.18 **502.4 Existing structural elements carrying gravity load.** Any existing gravity
 6.19 load-carrying structural element for which an addition and its related alterations cause an
 6.20 increase in design dead, live, or snow load, including snow drift effects, that increases the
 6.21 demand-capacity ratio to more than 105 percent, shall be replaced or altered as needed to
 6.22 carry the gravity loads required by the International Building Code for new structures. The
 6.23 evaluation of demand-capacity ratios and calculation of design gravity loads, forces, and
 6.24 capacities shall account for the cumulative effects of additions and alterations since original
 6.25 construction. Any existing gravity load-carrying structural element whose vertical

7.1 load-carrying capacity is decreased as a part of the addition and its related alteration shall
7.2 be considered an altered element subject to the requirements of IEBC section 503.3. Any
7.3 existing element that will form part of the lateral load path for any part of the addition shall
7.4 be considered an existing lateral load-carrying structural element subject to the requirements
7.5 of IEBC section 502.5.

7.6 (The exception remains unchanged.)

7.7 Subp. 1a. **Section 502.5 Existing structural elements carrying lateral load.** The
7.8 first exception to IEBC section 502.5 is amended to read as follows:

7.9 1. Any existing lateral load-carrying structural element for which an addition causes
7.10 an increase in demand-capacity ratio to no more than 110 percent shall be permitted
7.11 to remain unaltered. For purposes of calculating demand-capacity ratios, the demand
7.12 shall consider applicable load combinations with design lateral loads or forces in
7.13 accordance with IBC section 1609. For purposes of this exception, comparisons of
7.14 demand-capacity ratios and calculation of design lateral loads, forces, and capacities
7.15 shall account for the cumulative effects of additions and alterations since original
7.16 construction.

7.17 (The second exception remains unchanged.)

7.18 Subp. 2. **Section 502.6 Smoke alarms in existing portions of a building.** IEBC
7.19 section 502.6 is amended to read as follows:

7.20 **502.6 Smoke alarms in existing portions of a building.** Where an addition is made to a
7.21 building or structure of a Group R or I-1 occupancy, the existing building shall be provided
7.22 with smoke alarms in accordance with the Minnesota Building Code, chapter 1305.

7.23 **1311.0503 SECTION 503, ALTERATIONS.**

7.24 Subpart 1. **Section 503.1 General.** IEBC section 503.1, the exceptions, are amended
7.25 to read as follows:

8.1 **Exceptions:**

8.2 1. An existing stairway shall not be required to comply with the requirements of the
8.3 International Building Code provided the existing or replacement stairway complies
8.4 with the following: Existing stairs in buildings shall be permitted to remain if the rise
8.5 does not exceed 8.25 inches (210 mm) and the run is not less than 9 inches (229 mm).
8.6 Existing stairs are permitted to have a minimum width of 36 inches (914 mm), but not
8.7 less than the width required for the number of occupants served, as determined by the
8.8 International Building Code.

8.9 2. The replacement of an existing stairway may maintain its original rise and run if
8.10 compliance with exception 1 is technically infeasible.

8.11 3. Handrails otherwise required to comply with IBC chapter 10 shall not be required
8.12 to comply with handrail extension requirements if the handrail extensions hinder the
8.13 required means of egress.

8.14 Subp. 2. **Section 503.3 Existing structural elements carrying gravity load.** IEBC
8.15 section 503.3 is amended to read as follows:

8.16 **503.3 Existing structural elements carrying gravity load.** Any existing gravity
8.17 load-carrying structural element for which an alteration causes an increase in design dead,
8.18 live, or snow load, including snow drift effect, that increase the demand-capacity ratio to
8.19 more than 105 percent, shall be replaced or altered as needed to carry the gravity loads as
8.20 required by the International Building Code for new structures. The evaluation of
8.21 demand-capacity ratios and calculation of design gravity loads, forces, and capacities shall
8.22 account for the cumulative effects of additions and alterations since original construction.
8.23 Any existing gravity load-carrying structural element whose gravity load-carrying capacity
8.24 is decreased as a part of the alteration shall be shown to have the capacity to resist the
8.25 applicable design gravity loads required by the International Building Code for new
8.26 structures.

9.1 (The exceptions remain unchanged.)

9.2 Subp. 2a. **Section 503.4 Existing structural elements carrying lateral load.** The
9.3 exception to IEBC section 503.4 is amended to read as follows:

9.4 **Exception:** Any existing lateral load-carrying structural element for which an alteration
9.5 causes an increase in demand-capacity ratio to no more than 110 percent shall be
9.6 permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the
9.7 demand shall consider applicable load combinations with design lateral loads or forces
9.8 in accordance with IBC section 1609. For purposes of this exception, comparisons of
9.9 demand-capacity ratios and calculation of design lateral loads, forces, and capacities
9.10 shall account for the cumulative effects of additions and alterations since original
9.11 construction.

9.12 Subp. 3. [Repealed, 39 SR 95]

9.13 Subp. 4. [Repealed, 39 SR 95]

9.14 Subp. 5. [Repealed, 39 SR 95]

9.15 Subp. 6. [Repealed, 39 SR 95]

9.16 Subp. 7. [Repealed, 39 SR 95]

9.17 Subp. 8. **Section 503.14 Smoke alarms.** IEBC section 503.14 is amended to read as
9.18 follows:

9.19 **503.14 Smoke alarms.** Individual sleeping units and individual dwelling units in Group R
9.20 and I-1 occupancies shall be provided with smoke alarms in accordance with the Minnesota
9.21 Building Code, chapter 1305.

9.22 Subp. 9. **Section 503.15 Carbon monoxide alarms.** IEBC section 503.15 is amended
9.23 to read as follows:

10.1 **503.15 Carbon monoxide alarms.** Carbon monoxide alarms shall be provided to protect
 10.2 sleeping units and dwelling units in Group I-1, I-2, I-4, and R occupancies in accordance
 10.3 with IBC section 915.

10.4 (The exceptions remain unchanged.)

10.5 **1311.0504 SECTION 504, FIRE ESCAPES.**

10.6 IEBC section 504.4 is amended to read as follows:

10.7 **504.4 Dimensions.** Existing and replacement fire escape stairs shall meet the minimum
 10.8 width, capacity, riser height, and tread depth as specified in Table 504.4.

10.9 TABLE 504.4
 10.10 DIMENSIONS FOR EXISTING AND REPLACEMENT FIRE ESCAPE STAIRS

10.11		Serving More Than 10	Serving 10 or Fewer
10.12	Feature	Occupants	Occupants
10.13	Minimum Width	22 inches	18 inches
10.14	Maximum Riser Height	9 inches	12 inches
10.15	Minimum Tread Depth	9 inches	6 inches

10.16 **1311.0505 SECTION 505, WINDOWS AND EMERGENCY ESCAPE OPENINGS.**

10.17 Subpart 1. **Section 505.3 Replacement window emergency escape and rescue**
 10.18 **openings.** IEBC section 505.3 is amended by adding a subsection to read as follows:

10.19 **505.3.1 Licensed facilities.** Windows in rooms used for foster care or day care licensed
 10.20 or registered by the state of Minnesota shall comply with the provisions of section
 10.21 505.3 or all of the following conditions, whichever is more restrictive:

- 10.22 a. minimum of 20 inches in clear opening width;
- 10.23 b. minimum of 20 inches in clear opening height;
- 10.24 c. minimum of 648 square inches (4.5 square feet) clear opening; and

11.1 d. maximum of 48 inches from the floor to the bottom of the clear opening.

11.2 Subp. 2. **Section 505.4 Emergency escape and rescue openings.** IEBC section 505.4
11.3 is amended to read as follows:

11.4 **505.4 Emergency escape and rescue openings.** Emergency escape and rescue openings
11.5 shall be operational from the inside of the room without the use of keys or tools. Bars,
11.6 grilles, grates, or similar devices are permitted to be placed over emergency escape and
11.7 rescue openings provided that the minimum net clear opening size complies with the code
11.8 that was in effect at the time of construction and such devices shall be releasable or removable
11.9 from the inside without the use of a key, tool, or force greater than that which is required
11.10 for normal operation of the escape and rescue opening. Where such bars, grilles, grates, or
11.11 similar devices are installed, they shall not reduce the net clear opening of the emergency
11.12 escape and rescue openings.

11.13 **1311.0506 SECTION 506, CHANGE OF OCCUPANCY.**

11.14 Subpart 1. **Section 506.1 Compliance.** IEBC section 506.1 is amended to read as
11.15 follows:

11.16 **506.1 Compliance.** Changes in the use or occupancy of any building that would place the
11.17 building in a different division of the same group of occupancy or in a different group of
11.18 occupancies shall be permitted if such building is made to comply with the requirements
11.19 of the International Building Code for such division or group of occupancy. Subject to the
11.20 approval of the building official, the use or occupancy of existing buildings shall be permitted
11.21 to be changed and the building is allowed to be occupied for purposes in other groups without
11.22 conforming to all of the requirements of this code for those groups, provided the new or
11.23 proposed use is equally or less hazardous, based on life and fire risk, than the existing use
11.24 based on Table 506.1.

12.1 **Exception:** The building need not be made to comply with IBC chapter 16 unless
 12.2 required by section 506.4.

12.3 (IEBC subsection 506.1.1 remains unchanged.)

12.4 Subp. 2. **Table 506.1 Life safety and fire risk.** IEBC section 506.1 is amended by
 12.5 adding a table to read as follows:

12.6 TABLE 506.1 LIFE SAFETY AND FIRE RISK

12.7	RELATIVE HAZARD	OCCUPANCY CLASSIFICATION ^(a)
12.8	1 (Highest Hazard)	H, I-2, I-3
12.9	2	A-1, A-2, A-3, A-4
12.10	3	A-5, E, 1-1, R-1, R-2, I-4
12.11	4	R-3, R-4, M
12.12	5	B, F-1, S-1, IRC-1, IRC-3
12.13	6	F-2, S-2, IRC-2
12.14	7 (Lowest Hazard)	U, IRC-4

12.15 ^(a) IRC-1, IRC-2, IRC-3, and IRC-4 occupancy classifications are included only to
 12.16 determine relative hazard level where residential structures are converted to nonresidential
 12.17 uses in a change of occupancy. See part 1300.0070, subpart 12b, for occupancy
 12.18 classifications.

12.19 Subp. 3. **Section 506.1.2 Small assembly spaces.** IEBC section 506.1 is amended by
 12.20 adding a subsection to read as follows:

12.21 **506.1.2 Small assembly spaces.** The following rooms and spaces shall not be classified
 12.22 as assembly occupancies:

12.23 1. A room or space used for assembly purposes with an occupant load of less than
 12.24 50 persons and accessory to another occupancy shall be classified as part of that
 12.25 occupancy or as a Group B occupancy.

13.1 2. A room or space used for assembly purposes that is less than 750 square feet
13.2 (70 m²) in area and accessory to another occupancy shall be classified as part of
13.3 that occupancy or as a Group B occupancy.

13.4 Subp. 4. **Section 506.4.1 Live loads.** The exception to IEBC section 506.4.1 is amended
13.5 to read as follows:

13.6 **Exception:** Structural elements whose demand-capacity ratio considering the
13.7 change of occupancy is not more than 105 percent of the demand-capacity ratio
13.8 based on previously approved live loads need not comply with this section. For
13.9 purposes of this exception, the comparison of demand-capacity ratios and
13.10 calculation of design gravity loads, forces, and capacities shall account for the
13.11 cumulative effects of additions and alterations since original construction.

13.12 **1311.0606 [Renumbered 1311.0405]**

13.13 **1311.0702 SECTION 702, BUILDING ELEMENTS AND MATERIALS.**

13.14 IEBC section 702.5 is amended and a subsection is added to read as follows:

13.15 **702.5 Replacement window emergency escape and rescue openings.** Where windows
13.16 are required to provide emergency escape and rescue openings in Group R-2 and R-3
13.17 occupancies, replacement windows shall be exempt from the requirements of IBC sections
13.18 1030.2, 1030.3, and 1030.4, provided that the replacement window meets the following
13.19 conditions:

13.20 1. The replacement window is the manufacturer's largest standard size window that
13.21 will fit within the existing frame or existing rough opening. The replacement window
13.22 shall be permitted to be of the same operating style as the existing window or a style
13.23 that provides for an equal or greater window opening area than the existing window.

13.24 2. The replacement window is not part of a change of occupancy.

14.1 Window opening control devices complying with ASTM F2090 shall be permitted for use
14.2 on windows required to provide emergency escape and rescue openings.

14.3 **702.5.1 Licensed facilities.** Windows in rooms used for foster care or day care licensed or
14.4 registered by the state of Minnesota shall comply with the provisions of section 702.5 or
14.5 all of the following conditions, whichever is more restrictive:

- 14.6 a. minimum of 20 inches in clear opening width;
- 14.7 b. minimum of 20 inches in clear opening height;
- 14.8 c. minimum of 648 square inches (4.5 square feet) clear opening; and
- 14.9 d. maximum of 48 inches from the floor to the bottom of the clear opening.

14.10 **1311.0706 SECTION 706, STRUCTURAL.**

14.11 IEBC section 706.2 is amended to read as follows:

14.12 **706.2 Addition or replacement of roofing or replacement of equipment.** Any existing
14.13 gravity load-carrying structural element for which an alteration causes an increase in design
14.14 dead, live, or snow load, including snow drift effects, that increases the demand-capacity
14.15 ratio to more than 105 percent shall be replaced or altered as needed to carry the gravity
14.16 loads required by the International Building Code for new structures. The evaluation of
14.17 demand-capacity ratios and calculation of design gravity loads, forces, and capacities shall
14.18 account for the cumulative effects of additions and alterations since original construction.

14.19 **Exceptions:**

- 14.20 1. Buildings of Group R occupancy with not more than five dwelling or sleeping units
- 14.21 used solely for residential purposes where the altered building complies with the
- 14.22 conventional light-frame construction methods of the International Building Code.

15.1 2. Buildings in which the increased dead load is due entirely to the addition of a second
15.2 layer of roof covering weighing 3 pounds per square foot (0.1437 kN/m²) or less over
15.3 an existing single layer of roof covering.

15.4 **1311.0801 SECTION 801, GENERAL.**

15.5 IEBC section 801.1 is amended by deleting the exception and amending the section to
15.6 read follows:

15.7 **801.1 Scope.** Level 2 alterations as described in IEBC section 603 shall comply with the
15.8 requirements of this chapter.

15.9 (The exception pertaining to accessibility requirements is deleted.)

15.10 **1311.0805 SECTION 805, MEANS OF EGRESS.**

15.11 Subpart 1. **Section 805.2 General.** IEBC section 805.2 is amended to read as follows:

15.12 **805.2 General.** The means of egress shall comply with the requirements of IEBC section
15.13 805.

15.14 **Exception:** Means of egress conforming to the requirements of the Minnesota
15.15 Building Code chapter under which the building was constructed shall be considered
15.16 compliant means of egress if, in the opinion of the code official, they do not
15.17 constitute a distinct hazard to life.

15.18 Subp. 2. [See repealer.]

15.19 **1311.0806 SECTION 806, STRUCTURAL.**

15.20 Subpart 1. **Section 806.2 Existing structural elements carrying gravity loads.** IEBC
15.21 section 806.2 is amended to read as follows:

15.22 **806.2 Existing structural elements carrying gravity loads.** Any existing gravity
15.23 load-carrying structural element for which an alteration causes an increase in design dead,
15.24 live, or snow load, including snow drift effects, that increases the demand-capacity ratio to

16.1 more than 105 percent shall be replaced or altered as needed to carry the gravity loads
16.2 required by the International Building Code for new structures. The evaluation of
16.3 demand-capacity ratios and calculation of design gravity loads, forces, and capacities shall
16.4 account for the cumulative effects of additions and alterations since original construction.
16.5 Any existing gravity load-carrying structural element whose gravity load-carrying capacity
16.6 is decreased as part of the alteration shall be shown to have the capacity to resist the
16.7 applicable design dead, live, and snow loads, including snow drift effects, required by the
16.8 International Building Code for new structures.

16.9 (The exceptions remain unchanged.)

16.10 Subp. 2. **Section 806.3 Existing structural elements resisting lateral loads.** The
16.11 exception to section 806.3 is amended to read as follows:

16.12 **Exception:** Any existing lateral load-carrying structural element for which an alteration
16.13 causes an increase in demand-capacity ratio to no more than 110 percent shall be
16.14 permitted to remain unaltered. For purposes of calculating demand-capacity ratios, the
16.15 demand shall consider applicable load combinations with design lateral loads or forces
16.16 in accordance with IBC section 1609. For purposes of this exception, comparisons of
16.17 demand-capacity ratios and calculation of design lateral loads, forces, and capacities
16.18 shall account for the cumulative effects of additions and alterations since original
16.19 construction.

16.20 **1311.0807 SECTION 807, ELECTRICAL.**

16.21 Subpart 1. **Section 807.1 New installations.** IEBC section 807.1 is amended to read
16.22 as follows:

16.23 **807.1 New installations.** All newly installed electrical equipment and wiring relating to
16.24 work done in any work area shall comply with the materials and methods requirements of
16.25 NFPA 70.

17.1 Subp. 2. **Section 807.2 Existing installations.** IEBC section 807.2 is amended to read
17.2 as follows:

17.3 **807.2 Existing installations.** Existing wiring in all work areas in Group A-1, A-2, A-5, H,
17.4 and I occupancies shall be upgraded to meet the materials and methods requirements of
17.5 NFPA 70.

17.6 **1311.0808 [Renumbered 1311.0807]**

17.7 **1311.0809 SECTION 809, PLUMBING.**

17.8 IEBC section 809.1 is amended to read as follows:

17.9 **809.1 Minimum fixtures.** Where the occupant load of the story is increased by more than
17.10 20 percent, plumbing fixtures for the story shall be provided in quantities specified in
17.11 Minnesota Rules, chapter 1305, based on the increased occupant load.

17.12 **1311.0810 [Renumbered 1311.0809]**

17.13 **1311.0810 SECTION 810, ENERGY CONSERVATION.**

17.14 IEBC section 810.1 is amended to read as follows:

17.15 **810.1 Minimum requirements.** For energy conservation requirements, see Minnesota
17.16 Rules, chapters 1322 and 1323, as applicable.

17.17 **1311.0811 [Renumbered 1311.0810]**

17.18 **1311.0901 SECTION 901, GENERAL.**

17.19 IEBC section 901.2 is amended by deleting the exception to section 901.2.

17.20 **1311.0907 SECTION 907, ENERGY CONSERVATION.**

17.21 IEBC section 907.1 is amended to read as follows:

17.22 **907.1 Minimum requirements.** For energy conservation requirements, see Minnesota
17.23 Rules, chapters 1322 and 1323, as applicable.

18.1 **1311.0908 [Renumbered 1311.0907]**

18.2 **1311.1006 SECTION 1006, STRUCTURAL.**

18.3 The exception to IEBC section 1006.1 is amended to read as follows:

18.4 **Exception:** Structural elements whose demand-capacity ratio considering the change
18.5 of occupancy is not more than 105 percent of the demand-capacity ratio based on
18.6 previously approved live loads. The evaluation of demand-capacity ratios and calculation
18.7 of design gravity loads, forces, and capacities shall account for the cumulative effects
18.8 of additions and alterations since original construction.

18.9 **1311.1009 SECTION 1009, PLUMBING.**

18.10 IEBC section 1009.1 is amended to read as follows:

18.11 **1009.1 Increased demand.** Where the occupancy of an existing building or part of an
18.12 existing building is changed such that the new occupancy is subject to increased or different
18.13 plumbing fixture requirements in accordance with Minnesota Rules, chapter 1305, or to
18.14 increased water supply requirements in accordance with Minnesota Rules, chapter 4714,
18.15 the new occupancy shall comply with Minnesota Rules, chapter 4714.

18.16 **1311.1010 [Renumbered 1311.1009]**

18.17 **1311.1011 SECTION 1011, CHANGE OF OCCUPANCY CLASSIFICATION.**

18.18 Subpart 1. **Section 1011.1.1 Compliance with chapter 9.** IEBC section 1011.1.1 is
18.19 amended to read as follows:

18.20 **1011.1.1 Compliance with chapter 9.** The requirements of IEBC chapter 9 shall be
18.21 applicable throughout the building for the new occupancy classification based on the
18.22 separation conditions in sections 1011.1.1.1 and 1011.1.1.2.

18.23 (IEBC subsections 1011.1.1.1 and 1011.1.1.2 remain unchanged.)

19.1 Subp. 2. **Section 1011.2.1 Fire sprinkler system.** IEBC section 1011.2.1 is amended
19.2 to read as follows:

19.3 **1011.2.1 Fire sprinkler system.** Where a change in occupancy classification occurs
19.4 that requires an automatic fire sprinkler system to be provided based on the new
19.5 occupancy in accordance with Minnesota Rules, chapter 1305, such system shall be
19.6 provided throughout the area where the change of occupancy occurs.

19.7 **1311.1012 [Renumbered 1311.1011]**

19.8 **1311.1103 SECTION 1103, STRUCTURAL.**

19.9 Subpart 1. **Section 1103.1 Additional gravity loads.** IEBC section 1103.1 is amended
19.10 to read as follows:

19.11 **1103.1 Additional gravity loads.** Any existing gravity load-carrying structural element for
19.12 which an addition and its related alterations cause an increase in design dead, live, or snow
19.13 load, including snow drift effects, that increases the demand-capacity ratio to more than
19.14 105 percent shall be replaced or altered as needed to carry the gravity loads required by the
19.15 International Building Code for new structures. The evaluation of demand-capacity ratios
19.16 and calculation of design gravity loads, forces, and capacities shall account for the cumulative
19.17 effects of additions and alterations since original construction. Any existing gravity
19.18 load-carrying structural element whose gravity load-carrying capacity is decreased as part
19.19 of the addition and its related alterations shall be considered to be an altered element subject
19.20 to the requirements of section 806.2. Any existing element that will form part of the lateral
19.21 load path for any part of the addition shall be considered to be an existing lateral load-carrying
19.22 structural element subject to the requirements of section 1103.3.

19.23 (The exceptions remain unchanged.)

19.24 Subp. 2. **Section 1103.2 Lateral force-resisting systems.** The exceptions to IEBC
19.25 section 1103.2 are amended to read as follows:

20.1 **Exceptions:**

20.2 1. Buildings of Group R occupancy with no more than five dwelling or sleeping units
20.3 used solely for residential purposes where the existing building and the addition comply
20.4 with the conventional light-frame construction methods of the IBC.

20.5 2. Any existing lateral load-carrying structural element for which an addition causes
20.6 an increase in demand-capacity ratio to no more than 110 percent shall be permitted
20.7 to remain unaltered. For purposes of calculating demand-capacity ratios, the demand
20.8 shall consider applicable load combinations with design lateral loads or forces in
20.9 accordance with IBC section 1609. For purposes of this exception, comparisons of
20.10 demand-capacity ratios and calculation of design lateral loads, forces, and capacities
20.11 shall account for the cumulative effects of additions and alterations since original
20.12 construction.

20.13 Subp. 3. [See repealer.]

20.14 **1311.1105 SECTION 1105, CARBON MONOXIDE ALARMS IN GROUPS I-1, I-2,**
20.15 **I-4, AND R.**

20.16 IEBC section 1105.1 is amended to read as follows:

20.17 **1105.1 Carbon monoxide alarms in existing portions of a building.** Where an addition
20.18 is made to a building or structure of a Group I-1, I-2, I-4, or R occupancy, the existing
20.19 building shall be equipped with carbon monoxide alarms in accordance with IBC section
20.20 915.

20.21 **1311.1106 SECTION 1106, STORM SHELTERS.**

20.22 IEBC section 1106.1 is amended to read as follows:

20.23 **1106.1 Addition to a Group E occupancy.** Where an addition with an occupant load of
20.24 50 or more is made to an existing Group E occupancy, the addition shall have a storm shelter
20.25 constructed in accordance with ICC 500 in the following counties: Anoka, Benton, Blue

21.1 Earth, Brown, Carver, Chippewa, Chisago, Cottonwood, Dakota, Dodge, Faribault, Fillmore,
 21.2 Freeborn, Goodhue, Hennepin, Houston, Isanti, Jackson, Kandiyohi, LeSueur, Lincoln,
 21.3 Lyon, Martin, McLeod, Meeker, Murray, Nicollet, Nobles, Olmsted, Pipestone, Ramsey,
 21.4 Redwood, Renville, Rice, Rock, Scott, Sherburne, Sibley, Steele, Stearns, Swift, Wabasha,
 21.5 Waseca, Washington, Watonwan, Winona, Wright, and Yellow Medicine.

21.6 **Exceptions:**

- 21.7 1. Group E day care facilities.
- 21.8 2. Group E occupancies accessory to places of religious worship.
- 21.9 3. Additions meeting the requirements for shelter design in ICC 500.

21.10 (Subsections 1106.1.1 and 1106.1.2 remain unchanged.)

21.11 **1311.1201 SECTION 1201, GENERAL.**

21.12 IEBC section 1201.2 is amended to read as follows:

21.13 **1201.2 Report.** A historic building undergoing alteration or change of occupancy shall be
 21.14 investigated and evaluated. A written report shall be prepared and filed with the code official
 21.15 by a registered design professional when such a report is necessary in the opinion of the
 21.16 code official. The report shall identify each required safety feature that is in compliance
 21.17 with this chapter and where compliance with provisions of this chapter would be damaging
 21.18 to the contributing historic features.

21.19 **1311.1301 [Renumbered 1311.1401]**

21.20 **1311.1301 SECTION 1301, GENERAL.**

21.21 Subpart 1. **Section 1301.2 Applicability.** IEBC section 1301.2 is amended to read as
 21.22 follows:

21.23 **1301.2 Applicability.** Structures existing prior to the effective date of this code, in which
 21.24 there is work involving additions, alterations, or change of occupancy shall be made to

22.1 conform to the requirements of IEBC chapter 13 or the provisions of IEBC chapters 6 to
22.2 12. The provisions of sections 1301.2.1 to 1301.2.5 shall apply to existing occupancies that
22.3 will continue to be, or are proposed to be, in Groups A, B, E, F, I-2, M, R, and S. These
22.4 provisions shall not apply to buildings with occupancies in Group H, I-1, I-3, or I-4.

22.5 (IEBC subsections 1301.2.1, 1301.2.2, 1301.2.3, 1301.2.4, and 1301.2.5 remain unchanged.)

22.6 Subp. 2. **Section 1301.3.1 Hazards.** IEBC section 1301.3.1 is amended to read as
22.7 follows:

22.8 **1301.3.1 Hazards.** Where the code official determines that an unsafe condition or
22.9 hazardous building, as defined in Minnesota Statutes, section 463.15, exists as provided
22.10 for in Minnesota Rules, part 1300.0180, such unsafe condition or hazard shall be abated
22.11 in accordance with Minnesota Statutes, sections 463.15 to 463.26.

22.12 Subp. 3. **Section 1301.3.2 Compliance with other codes.** IEBC section 1301.3.2 is
22.13 amended to read as follows:

22.14 **1301.3.2 Compliance with other codes.** Compliance with other codes is deleted in its
22.15 entirety.

22.16 **1311.1302 [Renumbered 1311.1402]**

22.17 **1311.1401 SECTION 1401, GENERAL.**

22.18 IEBC section 1401.2 is amended to read as follows:

22.19 **1401.2 Conformance.** Buildings that are unsafe, as provided in Minnesota Rules, part
22.20 1300.0180, shall not be moved. Any repair, alteration, or change of occupancy undertaken
22.21 within the moved structure shall comply with the requirements of this code applicable to
22.22 the work being performed. Any field-fabricated elements shall comply with the requirements
22.23 of the International Building Code.

23.1 **1311.1402 SECTION 1402, REQUIREMENTS.**

23.2 Subpart 1. **Section 1402.3 Wind loads.** IEBC section 1402.3 is amended to read as
23.3 follows:

23.4 **1402.3 Wind loads.** Buildings shall comply with International Building Code wind
23.5 provisions, as applicable.

23.6 **Exceptions:**

23.7 1. Detached one- and two-family dwellings and Group U occupancies where wind
23.8 loads at the new location are not higher than those at the previous location.

23.9 2. Structural elements whose demand-capacity ratio is not increased to more than 110
23.10 percent. For purposes of this exception, comparisons of demand-capacity ratios and
23.11 calculation of design lateral loads, forces, and capacities shall account for the cumulative
23.12 effects of additions and alterations since original construction.

23.13 Subp. 2. **Section 1402.5 Snow loads.** IEBC section 1402.5 is amended to read as
23.14 follows:

23.15 **1402.5 Snow loads.** Structures shall comply with International Building Code snow loads
23.16 as applicable where snow loads at the new location are higher than those at the previous
23.17 location.

23.18 **Exception:** Structural elements whose demand-capacity ratio is not increased to more
23.19 than 105 percent. For purposes of this exception, comparisons of demand-capacity
23.20 ratios and calculation of design gravity loads, forces, and capacities shall account for
23.21 the cumulative effects of additions and alterations since original construction.

24.1 **1311.1401 [Renumbered 1311.1301]**

24.2 **REPEALER.** Minnesota Rules, parts 1311.0401; 1311.0404; 1311.0802; 1311.0803;
24.3 1311.0805, subpart 2; 1311.0807; 1311.1007; 1311.1103, subpart 3; and 1311.1203, are
24.4 repealed.

24.5 **EFFECTIVE DATE.** Minnesota Rules, parts 1311.0010 to 1311.1401, are effective March
24.6 31, 2020, or five business days after publication of the notice of adoption in the State
24.7 Register, whichever is later.