

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads												TAG Meeting Results				
Blue - Current MN Amendment    Purple - Code Change Proposal    Red - Revisit												Recommendations    A - Accept Model Code    AM - Amend Model Code				
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
<b>1305.011 Adoption of International Building Code by Reference and Administrative Authority</b>																
.1-B1					1305.0011 Subp. 1	Adoption of IBC and administrative authority	Y	Current language references 2018 IBC	N	N	Carry over amendment, adjust dates	AM	AM	Y		
.2-B1					1305.0011 Subp. 4	Seismic and earthquake provisions	Y	Current language-deletes all seismic and earthquake provisions	N	N	Carry over amendment	AM	AM	Y		Discussion.
<b>IBC/MR 1305 Chapter 2 - Definitions (Structural)</b>																
1-B2	IBC	2	202	202		Definitions		2021 IBC Definition Changes (Carried through to 2024) - Dangerous; Dead Load; Deleted Design Displacement; Deleted Design Pro in Responsible Charge; Fire Retardant Treated Wood; Glass Mat Gypsum Panel; Gypsum Panel Product; Gypsum Sheathing; Gypsum Wallboard; Impact Protective System; Individual Truss Member; Insulating Sheathing; Intermodal Shipping Container; Permanent Individual Truss Member Diagonal Bracing; Permanent Individual Truss Member Restraint; Positive Roof Drainage; Preservative-Treated Wood; Primary Structural Frame; Secondary Structural Members; Storage Racks, Steel Cantilevered; Strength; Underpinning; Wall, Load Bearing; Windborne Debris Region;					A	Y		

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads												TAG Meeting Results				
Blue - Current MN Amendment    Purple - Code Change Proposal    Red - Revisit												Recommendations    A - Accept Model Code    AM - Amend Model Code				
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
2-B2	IBC	2	202	202		Definitions						A	Y			
<b>ICCEB/MR 1311 Chapter 2 - Definitions (Structural)</b>																
2.1-EB2	IEBC	2	202	202		Dangerous	N	Revised 2021 - Expands loading conditions; Added 'aftershock' 2024.			Seismic and earthquake provisions made non-applicable elsewhere in MN code.		A	Y		
2.2-EB2	IEBC	2	202			Disproportionate Earthquake Damage	N	Revised definition 2024	N	N	Seismic and earthquake provisions made non-applicable elsewhere in MN code.		A	Y		Discussion
<b>IBC/MR 1305 Chapter 4 - Special Detailed Requirements Based on Occupancy and Use (Structural Provisions)</b>																

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High					Y or N	Y or N	
5-B4	IBC	4	403.2.2; 403.2.2.1- 403.2.2.4	403.2.2; 403.2.2.1- 403.2.2.4	403.2.3; 403.2.3.1- 403.2.3.4	High Rise Buildings - Construction - Structural integrity of interior exit stairways and elevator hoistway enclosures		Changes in 2021 and 2024. Adds new language, adds Soft Body Impact, adds glass wall provisions. Renumbered 2021.	H	L		A				
<b>IBC/MR 1305 Chapter 14 - Exterior Walls (Structural Provisions)</b>																
6-B15	IBC	14	1402.3- 1402.3.1		1402.3	Exterior Walls-Wind Resistance		Revised 2024. Renamed 2024. Adds specifics for application, adds requirements for attachments through exterior insulation	H	M						
7-B14	IBC	14	1404.5; 1405.1- 1405.3.6, including Tables	1404.17	1404.17	Installation of Wall Coverings - Fastening		Revision 2024. Moved from 1404.17 and 2603.12 and 2603.13. Revisions to Tables 1404.5.3.1 and 1404.5.3.2 footnotes for wood structural panels. Subsequent section parts renumbered.	H	M						
8-B14	IBC	14	1404.11.2	1404.10.2	1404.10.2	Exterior Adhered Masonry Veneer - porcelain tile		Revised 2021. New dimensional and weight limitations	H	L						
9-B14	IBC	14	1404.15; 1404.15.1- 1404.15.2	1404.15; 1404.15.1- 1404.15.2	1404.14; 1404.14.1	Vinyl Siding and Insulated Vinyl Siding; Application; Installation Over Foam Plastic Insulating Sheathing		Revised in 2021 and 2024. New limitations on use related to wind pressure and weight; Fastener requirements; New table - Required Minimum Wind Load Design Pressure Rating for Vinyl Siding Installed Over Foam Plastic Sheathing Alone	H	M						
10-B14	IBC	14	1404.18; 1404.18.1- 1404.18.2	1404.18	1404.18	Polypropylene Siding; Installation: Fastener Requirements		Revised in 2024. Added installation and fastener requirements.	H	M						
11-B14	IBC	14	1404.19; 1404.19.1			Fiber-mat reinforced cementitious backer units; Installation		Added in 2024.	H	M						
<b>IBC/MR 1305 Chapter 16 - Structural Design</b>																

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
12-B16	IBC	16	1601	1601	1601	Scope		Changed in 2024. Removed "regulated by this code" from end of sentence.	L	L		A				
13-B16	IBC	16	1602.1	1602.1	1602.1	Notations		Changes in 2021 and 2024 E, L, Pg(asd), Pg, V, V <sub>T</sub> .	L	L		A				
14-B16	IBC	16	1603.1; 1603.1.2; 1603.1.3; 1603.1.5; 1603.1.9	1603.1.4	1603.1; 1603.1.1-1603.1.9	Construction Documents		Slight change in 2021 for Wind Design Data, 5. Design Wind Pressures. Multiple changes in 2024.	L	L		A				
15-B16	IBC	16	1604.3	1604.3	1604.3	General Design Requirements, Serviceability		2021 removed earthquake loading drift limit language.	L	L		A				
16-B16	IBC	16	Table 1604.3	Table 1604.3	Table 1604.3	Deflection Limits		2024, added footnote j, snow load can be taken at .7 design snow for deflection limits.	M	L		A				
17-B16	IBC	16	1604.4	1604.4	1604.4	Analysis		2024 revised design requirements for non-flexible or non-rigid or wood diaphragms.	H	L		A				
18-B16	IBC	16	Table 1604.5	Table 1604.5	Table 1604.5	Risk Categories		2021 adds buildings with multiple uses including assembly spaces over 300 and cumulative over 2500. 2021 adds I-4s. In 2024, multiple changes, including footnote a.	H	M		A				
19-B16	IBC	16	1604.5	1604.5	1604.5	Risk Category		2024 adds exception for some freestanding parking garages.	M	L		A				
20-B16	IBC	16	1604.5.1	1604.5.1	1604.5.1	Risk Categories, Multiple Occupancies		2024 adds detail to conditions where multiple occupancy buildings must be assigned higher risk category, or when can be separated.	H	L		A				
21-B16	IBC	16	1604.5.2			Risk Categories, Photovoltaic Panel Systems		New in 2024, assigns risk category to PV panel systems.	M	M		A				
22-B16	IBC	16	1604.8.2	1604.8.2	1604.8.2	Anchorage, Structural Walls		2024 revised language applies to all structural walls. Revised language for seismic.	M	M		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
23-B16	IBC	16	1605.1; 1605.1.1	1605.1; 1605.1.1	1605.1	Load Combinations, General		2021 revised language refers design to ASCE 7 or 1605.2, adds 3 exceptions. 2024 revises exception 2, seismic related, adds exception 4 for tornado loads.	H	L		A				
24-B16	IBC	16			1605.2	Load Combinations Using Strength Design or Load and Resistance Factor Design		Deleted in 2021.	N	N						
25-B16	IBC	16	1605.2	1605.2	1605.3.2	Alternative Allowable Stress Design Load Combinations		Renumbered, 2021 revisions, 2024 exception 2 revisions for flat roof snow loads.	M	L		A				
26-B16	IBC	16	1606.1			General, Dead Loads		New language in 2024. Buildings, structures, and parts thereof shall be designed to resist the effects of dead loads.	H	L		A				
27-B16	IBC	16	1606.2	1606.2	1606.2	Weights of Materials of Construction, Dead Loads		2021 changed section title from "Design Dead Loads."	H	N		A				
28-B16	IBC	16	1606.3	1606.3		Weight of Fixed Service Equipment, Dead Loads		New section in 2021.	H	L		A				
29-B16	IBC	16	1606..4	1606.4		Photovoltaic Panel Systems, Dead Loads		New section in 2021.	H	L		A				
30-B16	IBC	16	1606.5	1606.5		Vegetative and Landscaped Roofs, Dead Loads		New section in 2021.	H	L		A				
31-B16	IBC	16	1607.1	1607.1	1607.1	General, Live Loads		New language in 2024. Buildings, structures, and parts thereof shall be designed to resist the effects of live loads.	H	L		A				
32-B16	IBC	16	Table 1607.1	Table 1607.1	Table 1607.1	Minimum Uniformly Distributed Live Loads and Minimum Concentrated Live Loads		Multiple revisions in 2021. More revisions in 2024.	H	L		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
33-B16	IBC	16	1607.2	1607.2	1607.2	Loads not Specified		2021 changes reference to Section 1607 - was Table 1607.	H	L		A				
34-B16	IBC	16	1607.3; 1607.3.1; 1607.3.2			Uniform Live Loads		2024 new language addresses loads on sloping surfaces, partial loading of floors, and partial loading of roofs.	H	L		A				
35-B16	IBC	16	1607.4	1607.4	1607.4	Concentrated Live Loads		2024 minor language change.	H	L		A				
36-B16	IBC	16	1607.5	1607.5	1607.5	Partition Loads		2024 revised format to create exception, does not allow 1607.13 reduction for partition loads.	M	L		A				
37-B16	IBC	16	1607.6; 1607.6.1	1607.6	1607.6	Helipads, Concentrated Loads		2024 revised and reorganized creating the subsection.	H	L		A				
38-B16	IBC	16	1607.7	1607.7		Passenger Vehicle Garages		New section in 2021 for floors. 2024 revision changes OR to AND.	H	M		A				
39-B16	IBC	16	1607.8; 1607.8.1; 1607.8.2	1607.8; 1607.8.1; 1607.8.2	1607.7; 1607.7.1; 1607.7.2	Heavy Vehicle Loads; Loads; Fire Truck and Emergency Vehicles		Renumbered in 2021.	L	N		A				
40-B16	IBC	16	1607.8.8.2			Heavy Vehicle Loads, Fire Truck and Emergency Vehicles		2024 revision addresses fire dept and emergency vehicles.	H	L		A				
41-B16	IBC	16	1607.8.3; 1607.8.4; 1607.8.4.1; 1607.8.5; 1607.9	1607.8.3; 1607.8.4; 1607.8.4.1; 1607.8.5; 1607.9;		Heavy Vehicle Garages; Forklifts and Movable Equipment; Impact and Fatigue; Posting; Loads on Handrails, Guards, Grab Bars and Seats		Renumbered in 2021.	L	N		A				
42-B16	IBC	16	1607.9.1			Concentrated Load, Handrails and Guards		2024 renames section, language change addresses glass handrail and guards per 2407.	H	L		A				
43-B16	IBC	16	1607.9.1.1			Uniform Load, Handrails and Guards		2024 renames section, language addresses design loads and adds Exception 3.	H	L		A				
44-B16	IBC	16	1607.9.1.2	1607.9.1.2		Guard Component Loads		2021 change itemizes balusters, panel fillers, and guard infill components.	H	L		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High					Y or N	Y or N	
45-B16	IBC	16	1607.9.2	1607.9.2		Grab Bars, Shower Seats and Accessible Benches		2021 renames section, changes references to "accessible benches" and "shower seat".	H	L		A				
46-B16	IBC	16	1607.10	1607.17		Fixed Ladders		New section in 2021. Moved to 1607.10 in 2024.	H	M		A				
47-B16	IBC	16	1607.12; 1607.12.1- 1607.12.3	1607.11; 1607.11.1- 1607.11.3		Impact Loads; Elevators; Machines; Elements Supporting Hoists for Façade Access and Building Maintenance Equipment		Renumbered in 2021 and again in 2024.	L	N		A				
48-B16	IBC	16	1607.12.4	1607.11.4		Fall Arrest, Lifeline, and Rope Descent System Anchorages		2021 section renumbered, renamed, language revised. Only renumbered 2024.	H	L		A				
49-B16	IBC	16	Deleted	1607.13		Distribution of Floor Loads		Renumbered 2021, deleted 2024.	L	N		A				
50-B16	IBC	16	1607.13	1607.12		Reduction in Uniform Live Loads		Renumbered in 2021 and in 2024. 2024 revised language, no substantive change.	H	L		A				
51-B16	IBC	16	1607.13.1; Table 1607.13.1; 1607.13.1.1	1607.12.1; Table 1607.12.1; 1607.12.1.1		Reduction in Uniform Live Loads - multiple subsections		Renumbered in 2021 and 2024.	L	N		A				
52-B16	IBC	16	1607.13.1.2	1607.12.1.2		Heavy Live Loads		Renumbered in 2021 and 2024. Clarifying revision to Exception 1.	H	L		A				
53-B16	IBC	16	1607.13.1.3	1607.12.1.3		Passenger Vehicle Garages		Renumbered in 2021 and 2024. Clarifying revision to Exception 1.	H	L		A				
54-B16	IBC	16	1607.13.2	1607.12.2	1607.11.2	Alternative Live Load Reduction		Renumbered in 2021. Rewritten in 2024.	H	L		A				
55-B16	IBC	16	Deleted	1607.14; 1607.14.1	1607.13; 1607.13.2	Roof Loads; Distribution of Roof Loads		Renumbered 2021, deleted 2024.	L	N		A				
56-B16	IBC	16	1607.14	1607.14.2	1607.13.2	Reduction in Uniform Roof Live Loads		Renamed from "General" in 2021 and renumbered. Adds "canopies" in 2024.	L	N		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
57-B16	IBC	16	1607.14.1	1607.14.2.1	1607.13.2.1	Ordinary Roofs, Awnings, and Canopies		Renumbered 2021 and 2024	L	N		A				
58-B16	IBC	16	1607.14.2	1607.14.2.2	1607.13.3	Occupiable Roofs		2021 Changed "roof garden" to "landscaped roofs". Renumbered 2021 and 2024.	L	N		A				
59-B16	IBC	16	Deleted	1607.14.3	1607.13.4	Awnings and Canopies		Renumbered 2021, deleted 2024.								
60-B16	IBC	16	1607.14.3; 1607.14.3.1; 1607.14.3.2	1607.14.4; 1607.14.4.1; 1607.14.4.2	1607.13.5; 1607.13.5.1; 1607.13.5.2	Photovoltaic Panel Systems, Roof Live Loads and two subsections		Renumbered in 2021 and 2024	L	N		A				
61-B16	IBC	16	1607.14.3.3	1607.14.4.3		Elevated Photovoltaic (PV) Support Structures with Open Grid Framing		Renumbered in 2021. Renamed in 2024 with some language revision.	M	L		A				
62-B16	IBC	16	1607.14.3.4	1607.14.4	1607.13.5.3	Ground-Mounted Photovoltaic (PV) Panel Systems		Renumbered 2021 and 2024. Renamed 2021 from "Photovoltaic Panels or Modules Installed as an Independent Structure". Language revised 2021 and 2024.	M	L		A				
63-B16	IBC	16	1607.14.3.5	1607.14.4.5	1607.13.5.4	Ballasted PV Panel Systems		Renumbered 2021 and 2024. Renamed 2021 from "Photovoltaic Panels or Modules Installed as an Independent Structure". Language revised 2021 and 2024.	L	N		A				
64-B16	IBC	16	1607.15	1607.15; 1607.15.1- 1607.15.4	1607.14; 1607.14.1- 1607.14.4	Crane Loads		Renumbered 2021. Revised 2024 for design per ASCE 7 Section 4.9. and 1607.15.1-1607.15.4 deleted.	M	L		A				
65-B16	IBC	16		1607.16; 1607.16.1; 1607.16.2	1607.15; 1607.15.1; 1607.15.2	Interior Walls and Partitions; Fabric Partitions; Fire Walls		Renumbered in 2021.	L	N		A				
66-B16	IBC	16	1607.17	1607.18		Library Stack Rooms		New in 2021. Renumbered 2024.								
67-B16	IBC	16	1607.18; 1607.18.1	1607.19; 1607.19.1		Seating for Assembly Uses; Horizontal Sway Loads		New in 2021. Renumbered 2024.	H	M						



[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High					Y or N	Y or N	
68-B16	IBC	16	1607.19; 1607.19.1; 1607.19.2	1607.20; 1607.20.1; 1607.20.2		Sidewalks, Vehicular Driveways, and Yards Subject to Trucking; Uniform and Concentrated Loads		New in 2021. Renumbered in 2024.	H	L						
69-B16	IBC	16	1607.20	1607.21		Stair Treads		New in 2021. Renumbered in 2024.	H	L						
70-B16	IBC	16	1607.21; 1607.21.1; 1607.21.2; 1607.22.3	1607.22; 1607.22.1; 1607.22.2; 1607.22.3		Residential Attics; Uninhabitable Attics without Storage; Unhabitable Attics with Storage; Attics Served by Stairs		New in 2021. Renumbered in 2024.	H	L						
71-B16	IBC	16	1608.1		1608.1	General, Snow Loads		Exception added 2024 for Temporary Structures complying with 3103.6.1.1.	H	L						
72-B16	IBC	16	1608.2; Figures 1608.2(1) - 1608.2(4)		1608.2; MR 1305.1608.2	Ground Snow Loads	Y	Subsection revised 2024. Figures revised. MN amendment does not reference Figures	H	L		AM				
73-B16	IBC	16	1609.1.1		1609.1.1	Determination of Wind Loads		2024 changes "basic design" to "basic. Adds exception 7 for Temporary Structures complying with 3103.6.1.2. Reference to Figures revised.	H	L						
74-B16	IBC	16	Table 1609.2		Table 1609.2	Windborne Debris Protection Fastening Schedule for Wood Structural Panels		2024 revision to footnote a.	H	L						
75-B16	IBC	16	Deleted	1609.2.2	1609.2.2	Application of ASTM E1996		Deleted in 2024.	N	N						
76-B16	IBC	16	1609.2.2	1609.2.3	1609.2.3	Garage Doors		Renumbered 2024.	H	L		A				
77-B16	IBC	16	1609.3; 160.3.1; Table 1609.3.3		1609.3; 1609.3.1; 1609.3.1	Basic Design Wind Speed		In 2024 changed "basic design" to "basic" throughout section. Sends determination for Hawaii, US Virgin Islands, Puerto Rico to ASCE Wind Design Geodatabase.	H	L		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment    Purple - Code Change Proposal    Red - Revisit													Recommendations    A - Accept Model Code    AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High					Y or N	Y or N	
78-B16	IBC	16	Figure 1609.3(1); Figure 1609.3(2); Figure 1609.3(3); Figure 1609.3(4)		Figure 1609.3(1); Figure 1609.3(2); Figure 1609.3(3); Figure 1609.3(4)	Basic Design Wind Speeds, V, for Risk Category II-IV Buildings and Other Structures		Figures revised 2024.	H	L		A				
79-B16	IBC	16	Figures 1609.3(5) - 1609.3(12)		Figures 1609.3(5) - 1609.3(12)	Basic Design Wind Speed Figures for Hawaii		Figures for Hawaii deleted in 2024.	N	N		A				
80-B16	IBC	16	1609.5; Figure 1609.5			Tornado Loads; Tornado-Prone Regions		New in 2024.	H		Discuss					
81-B16	IBC	16	1609.6; 1609.6.1; 1609.6.2	1609.5; 1609.5.1; 1609.5.2	1609.5; 1609.5.1; 1609.5.2	Roof Systems; Roof Deck; Roof Coverings		Renumbered 2024. Adds tornado pressures 2024. Moves Asphalt Shingles to its own subsection.	H	L		A				
82-B16	IBC	16	1609.6.2.1			Asphalt Shingles		New section in 2024. Was combined with Roof Coverings. Language similar.	H	L		A				
83-B16	IBC	16	1609.6.3; 1609.6.3.1; 1609.6.3.2	1609.5.3	1609.5.3	Rigid Tile; Aerodynamic Uplift; Tornado Loads		Renumbered 2024. Reorganizes. Adds tornado loads.	H	L		A				
84-B16	IBC	16	1609.7			Elevators, Escalators and Other Conveying Systems		New in 2024. Where exposed to outdoors, use ASCE 7 for wind.	H	L		A				
85-B16	IBC	16	1610	1610	1610	Soil and Hydrostatic Pressure		Renamed section 2021.	N	N		A				
86-B16	IBC	16	1610.1	1610.1	1610.1	Lateral Pressures		Renamed section 2021 - was "General." Clarifying language changes in 2021. More clarifying language changes in 2024.	H	N		A				
87-B16	IBC	16	1611.1	1611.1	1611.1	Design Rain Loads		Section rewritten 2024.	H	L		A				

[Link to 2024 IBC](#)

[Link to 2021 IBC](#)

[Link to 2018 IBC](#)

[Link to 2020 MN Building Code](#)

[Link to MN Rules 1305](#)

To Be Completed by TAG Leads													TAG Meeting Results			
Blue - Current MN Amendment   Purple - Code Change Proposal   Red - Revisit													Recommendations   A - Accept Model Code   AM - Amend Model Code			
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter							N - None, L - Low, M-Med, H-High	Y or N				Y or N		
88-B16	IBC	16	Deleted	Figures 1611.1(1); 1611.1(2); 1611.1(3); 1611.1(4); 1611.1(5)	Figure 1611.1	100-Year, 1-Hour Rainfall, Western US; Central US; Eastern US; Alaska; Hawaii		Renumbered 2021. Deleted 2024. New 1611.1 refers to new Table 1611.1.	H	L		A				
89-B16	IBC	16	Table 1611.1			Design Storm Return Period by Risk Category		New in 2024.	H	L		A				
90-B16	IBC	16	1612.2	1612.2	1612.2	Flood Loads Design and Construction		Revised in 2024. MR 1305.0011 Subp. 5 deletes flood hazard and floodproofing provisions and references MR 1335 Floodproofing Regulations. <i>(NOTE: In January, 2022, MN Construction Codes Advisory Council accepted the Flood Resistant Design TAG's recommendation to revise flood regs by adopting ASCE Standard 24-14 Flood Resistant Design and Construction. Rulemaking not completed.)</i>	N	N		A				
91-B16	IBC	16	1613	1613	1613	Earthquake Loads (all subsections)		Revised in 2024. MR 1305.0011 Subp. 4 deletes seismic and earthquake provisions.	N	N		A				
92-B16	IBC	16	1614.1	1614.1	1614.1	Atmospheric Ice Loads		in 2024, exception added for temporary structures complying with IBC 3103.6.1.6. <i>(NOTE: 3103.6.1.6 revised in 2024.)</i>	M	L		A				