

**Construction Codes &  
Licensing Division**

September 22, 2008

Mr. Bruce Kilander  
Great Lakes Window and Siding Co.  
14650 Glenda Drive  
Apple Valley, MN 55124

Subject: State Appeals Board results of September 9, 2008 - #08-02

Dear Mr. Kilander,

This is to confirm that the State Appeals Board has denied your appeal of the decision by the Rochester Building Official in the matter of whether an egress window needs to be installed in the basement remodeling project you are responsible for at 3421 16<sup>th</sup> Avenue NW in Rochester, Minnesota. The vote was 5-0 against your appeal with any conditions as listed in the minutes of the meeting (see enclosed). The Board finds in favor of the building official's determination that this remodeled basement is to have an egress window installed in accordance with the intent of IRC Section 310.1.1 and Minnesota Rule part 1309.0100 Subp 2.

The building official is responsible to see that the completed installation complies with these findings including any other applicable provisions of the Minnesota Building Code.

CONSTRUCTION CODES & LICENSING DIVISION

Sincerely,



Thomas Downs Jr., Chair  
State Appeals Board

Enc: Minutes

Cc: Ron Boose, Rochester Building Official  
Appeals Board Members  
Steve Hernick, State Building Official  
Registered attenders

