



Construction Codes &
Licensing Division

July 13, 2010

Mr. Todd Trabant
Division Manager
Champion Window Company
5100 Hwy 169 N. Suite B
New Hope, MN 55428

Subject: State Appeals Board results of July 12, 2010 - #10-01

Dear Mr. Trabant,

This is to confirm that the State Appeals board has approved your appeal of the decision by the City of Coon Rapids Building Official, in the matter of the bathroom window replaced at 10452 Mississippi Blvd. NW, Coon Rapids, Minnesota. The vote was 5-0 in favor of your appeal. The Board finds that the window replaced by your company in the bathroom of this property is not required by the building code to be of approved safety glazing.

By the way of this letter we are notifying the building official that this window is approved for installation at its present location without being safety glazed.

CONSTRUCTION CODES & LICENSING DIVISION

Sincerely,

Gary Hagedorn, Chair
State Appeals Board

Enc: Minutes

Cc: Doug Whitney, City of Coon Rapids, Building Official
Appeals Board Members
Stephen Hernick, State Building Official
All registered attendees