



M.R. CHAPTER 4714, SECTION 603.5.21

1. DIRECT CONNECTION TO POTABLE WATER SYSTEM WITH A SVB OR PVB




- MUST NOT BE SUBJECTED TO BACK PRESSURE
- IF SUBJECTED TO BACK PRESSURE, AN RPZ IS REQUIRED
- AVB TYPICALLY NOT USED SINCE VALVES ARE NOT ALLOWED DOWNSTREAM

2. CONNECTION TO MOP SINK FAUCET WITH PRESSURE BLEEDING DEVICE



3. DIRECT CONNECTION TO POTABLE WATER SYSTEM WITH ASSE 1055 CHEMICAL DISPENSER



AVB = ATMOSPHERIC VACUUM BREAKER  
PVB = PRESSURE VACUUM BREAKER

RPZ = REDUCED-PRESSURE PRINCIPLE  
SVB = SPILL-PROOF VACUUM BREAKER