



NOTE: ALL FIXTURES SHOWN ARE PRIVATE USE, ALL PIPE SIZES SHOWN ARE MINIMUM PIPE SIZES REQUIRED, AND NOT ALL REQUIRED CLEANOUTS ARE SHOWN

VERTICAL WET VENTING REQUIREMENTS:

- LIMITED TO VERTICAL DRAIN RECEIVING THE DISCHARGE FROM THE TRAP ARM OF ONE AND TWO DFU UPPER FIXTURES.
- LIMITED TO THE SAME STORY.
- THE WET VENT MUST NOT EXCEED 6 FEET IN DEVELOPED LENGTH.
- EACH WET-VENTED SECTION MUST NOT BE LESS THAN ONE PIPE SIZE EXCEEDING THE MINIMUM WASTE SIZE OF THE UPPER FIXTURE OR ONE PIPE SIZE LARGER THAN THE MINIMUM REQUIRED SIZE FOR THE SUM OF THE FIXTURES SERVED BY THE WET-VENTED SECTION, WHICHEVER IS LARGER, *BUT IN NO CASE LESS THAN 2 INCHES.*