

# Administrative and Minnesota Provisions TAG

## Meeting Notes

**Date:** Tuesday, September 17<sup>th</sup>, 2024

**Meeting Location:** Hybrid-DLI Isanti Room/WebEx

**Call to order:** Greg Metz

### **Attendance:**

**TAG Members attending:** Greg Metz, Scott Anderson, Mike Swanson, Jerry Backlund, Lonnie Johnson, Arlen Madsen, Jared Ellingson,

**TAG Members absent:** David Selinsky, Arlen Madsen, Tyler Krahn, Jared Ellingson, Eric Boyd

**Guests attending:** Amanda Spuckler, Nick Erickson, Don Sivigny, Dan Hylland, Allison Eastham, Jeffery Lebowski, Shawn Wetterlin, Maggie Chen

### **Worksheet and Code Change Proposal Review:**

TAG Members reviewed the code change proposals described below.

Minnesota Rules, parts 1303.2402 and 1303.2403 Requirements for Passive and Active Radon Control Systems  
The TAG members reviewed multiple code change proposals for passive and active radon control systems. The TAG consensus is to accept code change proposals.

Minnesota Rules, part 1300.0070 Definitions, Single-family dwelling. TAG members reviewed a code change proposal to add a definition for single-family dwelling. TAG members previously tabled the proposal to revise the language for clarification. The TAG consensus is to accept the code change proposal as amended.

Minnesota Rules, part 1300.0070 Definitions, Two-family dwelling. TAG members reviewed a code change proposal to add a definition for Two-family dwelling. TAG members previously tabled the proposal to revise the language for clarification. The TAG consensus is to accept the code change proposal as amended.

Minnesota Rules, part 1301.1000, Mandatory Continuing Education, subp. 3. TAG members reviewed a code change proposal to require a minimum six hours of continuing education in plan review and inspections of plumbing code compliance. The TAG consensus is to accept the code change proposal as amended.

Minnesota Rules, part 1301.1600, Continuing Education, subp. 2. TAG members reviewed a code change proposal to require a minimum number of hours of continuing education for construction code inspectors and

those disciplines they inspect such as building, mechanical and plumbing. The TAG consensus is to accept the code change proposal as amended.

Minnesota Rules, part 1300.120, Work Exempt from Permit.

The TAG members reviewed a code change proposal that adds language exempting piers constructed over lakes, rivers, or wetlands where the pier is not used as a means of egress from a building or a required accessible route or where the pier is not used as an accessible fishing pier. The TAG consensus is to accept the code change proposal as amended.

Minnesota Rules, part 1303.1600, Subp. 2 Soil Under Slab on Grade.

The TAG members reviewed a code change proposal for providing frost protection for exterior door landings. The TAG members consensus is not to accept the code change proposal, code change proposal was withdrawn.

Minnesota Rules, part 1300.0030, subp.2 Application.

TAG members reviewed a code change proposal to add language that includes change of occupancy. This language is for consistency in the MNSBC. The TAG consensus is to accept the code change proposal.

**Meeting Adjourned:** 3:00 PM

**Prepared by:** Greg Metz