

Commercial Building Code 1305 TAG

Meeting Notes

Date: Thursday, September 19, 2024

Meeting Location: DLI Isanti Room/WebEx Event

Call to order:

Ryan Rehn

Attendance:

TAG Members Attending: Ryan Rehn, Britt McAdamis, Scott Anderson, Jerry Norman, Steve Ubl, Larry Farris, Forrest Williams, Tara Ketchum, Barry Greive, Dori Dufresne, Clayton Talbot

TAG Members Not Attending:

Guests Attending: Amanda Spuckler, Allison Eastham, Jim Weaver, Shawn Wetterlin

Worksheet and Code Change Proposal Review:

Reviewed Code Change Proposals (CCP) to chapters 7-10 of the International Building Code.

- CCP 25 – IBC 706.2 – Fire wall structural stability: The TAG supported the CCP but not the proposed exception. Discussion was tabled to coordinate with other CCPs and related code sections.
- CCP 26 – IBC 706.8 – Fire wall openings: The TAG discussed the CCP and supported allowing only one fire wall to be protected. Discussion was tabled to coordinate with other CCPs and related code sections.
- CCP 27 – IBC 706.11 – Fire wall duct and air transfer openings: The TAG tabled discussion to coordinate with other CCPs and related code sections.
- CCP 119 – IBC 716.1(2) – Opening fire protection assembly: The TAG consensus is to support the proposed modifications to the table that are necessary to replicate the 2-hour fire resistive provisions in section 706.4 for fire walls. The table is also modified reorder assembly types from most to least restrictive.
- CCP 43 – IBC 1010.1.1 – Size of doors: The TAG consensus is to support the proposed change that separates provisions for minimum door width and height and adds a provision for opposite swinging doors.
- CCP 44.1 – IBC 1010.1.6 – Thresholds, exception 2: The TAG consensus is to support the change to align the threshold requirements in the building code with the requirements of the accessibility code.
- CCP 45.1 – IBC 1010.2.13 – Controlled egress doors: The TAG tabled this proposal so the proponent could clarify the the occupancy groups associated with this change.
- CCP 98 – IBC 1010.1.9.7 – Controlled egress: the TAG tabled this proposal to coordinate with CCP 45.1 that addresses the same code section. Code change proposals will be coordinated into one CCP.
- CCP 96 – IBC 1010.1.9.8.1 – Delayed egress: CCP was tabled for a new version at the request of the proponent.

Meeting Adjourned: 12:30 PM

Prepared by: Britt McAdamis