

1311 Existing Building Code TAG

Meeting Notes

Revised July 12, 2024

Date: Tuesday, June 25, 2024

Meeting Location: DLI Isanti Room/WebEx Event

Call to order:

Mike Bunnell

Attendance:

TAG Members attending: Mike Bunnell, Wendy Rannenberg, Clayton Talbot, Greg Karow, Jerry Backlund, Lisa Consie, Whitney Loughheed, Scott Anderson

Others attending: Amanda Spuckler, Sarah Anderson, Geoffrey Jillson, Eric Lacey, Britt McAdamis, Chad Payment, Kevin Rolfes, Anna Scholin

Worksheet and Code Change Proposal Review:

Reviewed Code Change Proposals for the 2024 International Existing Building Code (IEBC) and Minnesota Rules, Chapter 1311. Discussion included items from previous meetings. TAG recommendations to accept model code language, modify model code language, or carry forward current MR 1311 amendments are recorded in the TAG Members Worksheet.

Worksheet items related to structural were sent for review to the Structural TAG. The Structural TAG recommended accepting or deleting structural related items. The 1311 TAG recommends accepting the Structural TAG's recommendations.

Worksheet Item 8-23 R-2 Occupancies with One Exit (IEBC Table 804.5.1.1(1)) was discussed and tabled.

Worksheet Item 9-13 Emergency Responder Communications Enhancement Systems (IEBC 908) was discussed and tabled.

Code Change Proposals:

CCP-EB-8 Prescriptive Life Safety & Fire Risk Table (Minnesota Rules, part 1311.0506, subpart 2) – The code change proposal reorders IRC-1 and IRC-2 structures in the table. The code change proposal was withdrawn.

CCP-EB-9 Change of Occupancy Hazard Tables (2024 IEBC Tables 1011.5, 1011.6, and 1011.7) – The TAG members reviewed a code change proposal to add IRC structures to these tables for purposes of converting IRC buildings to IBC structures. The TAG consensus is to accept the code change proposal.

CCP-EB-10 References to Other Codes – Residential Code (Minnesota Rules, part 1311.0020, subp. 9) – A code change proposal to allow IRC buildings to comply with chapter 1311 was withdrawn. Chapter 1300 does not permit IRC occupancies to comply with chapter 1311. **A consensus of TAG members requested that a suggestion be made to the 1309 Residential Code TAG to consider adding provisions to MR Chapter 1309 for existing IRC buildings.**

CCP-EB-11 References to Other Codes - Fire Code (Minnesota Rules, part 1311.0020, subp. 3) – The TAG members reviewed a code change proposal to amend this subpart so all references to IFC mean Minnesota Rules, chapter 7511. TAG consensus is to accept the code change proposal.

Worksheet Items 11-9 through 15-2 were reviewed.

Next Meeting:

Date: July 9, 2024

Time: 9:00 AM

Location: DLI Isanti Room

Meeting Adjourned: 12:00 PM

Prepared by: Wendy Rannenberg