

Residential Code (1309) TAG

Meeting #7 Notes

Date: 2/4/2025

Meeting Location: DLI – Washington Room/Webex Event

Call to order: 9:02 am

Attendance:

TAG Members Attending:

Terence Olson (DLI), Jesse Szykuloski (DLI), Kyle Thrapp, Nathan Weber, Keith Demarest, Steve Kartak, Lisa Hartwig, Greg Olson, Curtis (CJ) Johnson, Chris Rosival (DLI)

TAG Members Not Attending:

All in attendance.

Guests Attending:

Steve Shold (DLI) Amanda Spuckler (DLI), Mackenzie Johnson (DLI)

Worksheet and Code Change Proposal Review:

The TAG reviewed chapter 3 worksheet items 178 through 246 corresponding to 2024 IRC sections R319.6 through R332.1 and Code Change Proposals (CCPs) for sections R319.1 and R319.5.2.2.

- Worksheet line 125, Section R315.5.2.2. The TAG consensus is to accept the CCP.
- Worksheet line 126, Section R315.1 Sleeping lofts. The TAG consensus is to accept the CCP.
- Worksheet line 179, Section R319.6 Dwelling additions. A CCP will be submitted for this section.
- Worksheet line 180, Section R315.1 Alterations or repairs of existing basements. A CCP will be submitted for this section.
- Worksheet line 181, Section R310.6.1, sleeping rooms in existing basements, Minnesota Rules, part 1309.0310, subpart 3. A CCP will be submitted for this section.
- Worksheet line 182, Section R319.7.1 Existing emergency escape and rescue openings. A CCP will be submitted for this section.
- Worksheet line 188, Section R321.1.1 Window fall protection, where required. The TAG consensus is to repeal the current Minnesota amendment and accept the model code language.
- Worksheet line 189, Section R321.2.2 Window fall protection, window opening height. The TAG consensus is to repeal the current Minnesota amendment and accept the model code language.
- Worksheet line 193, Minnesota Rules part 1309.0320, Guest rooms. The TAG consensus is to repeal the current Minnesota amendment. This section was deleted in the 2021 IRC.
- Worksheet line 195, Section R322.3 Care facilities. The TAG consensus is to modify this section to refer to other chapters of the Minnesota State Building Code.

- Worksheet line 208, Section R325.1 Habitable rooms. The TAG consensus is to accept the CCP, which was also accepted by the Mechanical Code TAG.
- Worksheet line 210, Section R325.1.2 Natural ventilation. The TAG consensus is to accept the CCP, which was also accepted by the Mechanical Code TAG.
- Worksheet line 211, Section R325.1.3 Adjoining rooms. The CCP modifies the section to require whole-house mechanical ventilation systems. The TAG consensus is to accept the CCP, which was also accepted by the Mechanical Code TAG.
- Worksheet line 212, Section R325.3 Mechanical ventilation. The CCP deletes section R325.3 due to changes made to other sections. The TAG consensus is to accept the CCP, which was also accepted by the Mechanical Code TAG.
- Worksheet line 214, Section R325.8 Required heating. The CCP modifies the section to require heating systems to be designed. The TAG consensus is to accept the CCP, which was also accepted by the Mechanical Code TAG.
- Worksheet line 215, Section R325.8.1 Required heating. Tabled pending review by Mechanical Code TAG.

Next Meeting:

Date: 2/25/2025

Time: 9:00 am.

Location: DLI – Washington Room

Meeting Adjourned: 11:40 am.

Prepared by:

Terence Olson