

To Be Completed by TAG Leads											TAG Meeting Results					
Structural TAG Review Worksheet 1303, 1305 IBC, 1311 IEBC											Recommendations A - Accept Model Code AM - Amend Model Code					
Item Number	2024 Code and Chapter		2024 Code & Section	2021 Code & Section	2020 MN Code Section	Code Section Heading/Topic	MN Amendment?	Description of change(s) to code language	Safety/Health Value	Cost Impact	Staff Comment	Staff Recommendation	TAG Recommendation	TAG Group Consensus	Stakeholder Consensus	Comments
	Code	Chapter														
IBC/MR 1305 Chapter 16 - Structural Design																
72-B16	IBC	16	1608.2; Figures 1608.2(1) - 1608.2(4)		1608.2; MR 1305.1608.2	Ground Snow Loads	Y	Subsection revised 2024. Figures revised. MN amendment does not reference Figures. Changing reference for loading to ASCE 7 Hazard Tool https://asce7hazardtool.online/ .	H		Coordinate with 1303 and 1309.				Table 5/2. Discussed 5/16-Tabled. 9/19/24 - Tabled until review of IRC/1309. Discussed 12/5/24. Map by county discussed. Tabled.	
IBC/MR 1305 Chapter 19 - Concrete																
177-B19	IBC	19			1305.1904.3	Corrosion Protection	Y	Amendment adds subsection. 1904.3 Corrosion protection. Where bonded reinforcing and prestressing steel is located in concrete assigned to Exposure Class F3 or Exposure Class C2, the steel shall be protected from corrosion by one of the following methods: 1. Impermeable barrier. 2. Epoxy coating in accordance with ACI 318. 3. Hot dipped galvanizing in accordance with ACI 318.							Tabled 6/6/24 MO to research ACI 318-19. Remains tabled 12/5.	
Other Code Change Proposals (See Residential CCPs in separate worksheet.)																
					MR 1303.1700	Ground Snow Load	Y	Current MR language: The ground snow load, Pg, to be used in determining the design snow loads for buildings and other structures shall be 60 pounds per square foot in the following counties: Aitkin, Becker, Beltrami, Carlton, Cass, Clearwater, Cook, Crow Wing, Hubbard, Itasca, Kanabec, Kittson, Koochiching, Lake, Lake of the Woods, Mahnommen, Marshall, Mille Lacs, Morrison, Norman, Otter Tail, Pennington, Pine, Polk, Red Lake, Roseau, St. Louis, Todd, and Wadena. The ground snow load, Pg, to be used in determining the design snow loads for buildings and other structures shall be 50 pounds per square foot in all other counties.								
247a-B10	IBC	10	1010.1.5.1		CCP-STR-3-CCP-STR-3a.2	Landings at Exterior Exit Doors		Scott Anderson proposal	H			A	Y		To be modified. Revision received 9/19.	
247b-B18	IBC	18	1809.5.1		MR 1305.1809 / CCP-STR-3-CCP-STR-3a.2	Frost Protection (general) and Frost Protection at Required Exits		Scott Anderson proposal	L			Tabled			To be modified. Revision received 9/19.	
248-B18	IBC	18	1809.5		MR 1305.1809 / CCP-STR-4	Shallow Foundation Frost Protection		Scott Anderson proposal								