

Structural TAG

Meeting Notes

Date: Thursday, August 15, 2024

Meeting Location: Hybrid-DLI Isanti Room/WebEx

Call to order: Dan Kelsey, 9:00 AM

Attendance:

TAG Members attending: Wendy Rannenberg, Randy Johnson, Chris Kehl, Craig Oswell, Dan Kelsey, John Timm, Kyle Dimler, Mitch Okeson

TAG Members absent: Eric Boyd

Guests attending: Amanda Spuckler, Chad Payment, Ed Lisinski

Worksheet and Code Change Proposal Review:

TAG members continued discussion of revisions to a code change proposal for Minnesota Rules, part 1303.1600, Depth for Frost Protection.

The TAG members continued reviewing a code change proposal that revises the footing depth requirements for heated and unheated buildings based on the air freezing index (AFI) and assigns each county in Minnesota to one of three zones. The consensus of TAG members is that decreasing the minimum footing depths for heated and semi-heated buildings in some zones is reasonable, and that adding 12" to the depth for unheated structures will provide necessary additional protection. Discussion to refine details of the revision to the code change proposal will continue at future meetings.

TAG members reviewed structural-related changes in chapters 24-33 of the 2024 International Building Code.

The next meeting is scheduled for Thursday, September 19, 2024.

Meeting Adjourned: 11:04 AM

Prepared by: Wendy Rannenberg