

Structural TAG

Meeting Notes

Date: Thursday, September 19, 2024

Meeting Location: Hybrid-DLI Isanti Room/WebEx

Call to order: Dan Kelsey, 9:00 AM

Attendance:

TAG Members attending: Wendy Rannenberg, Randy Johnson, Chris Kehl, Craig Oswell, Dan Kelsey, John Timm, Kyle Dimler, Mitch Okeson

TAG Members absent: Eric Boyd

Guests attending: Chad Payment, Jo Sunder

Worksheet and Code Change Proposal Review:

TAG members recommended accepting changes to Minnesota Rules, part 1303.1600, Depth for Frost Protection that revises the footing depth requirements for heated and unheated buildings, dividing Minnesota into three zones. The proposal decreases the minimum footing depths for heated and semi-heated buildings in some zones and requires an additional 12" depth for unheated structures.

TAG members discussed and tabled a proposed revision to IBC 1010.5.1 regarding landings at exterior exit doors.

TAG members discussed and tabled a proposed revision to MR 1305.1809 regarding general frost protection and frost protection at required exits.

TAG members reviewed structural-related changes in chapter 16 of the 2024 International Building Code.

The next meeting is scheduled for Thursday, November 7, 2024.

Meeting Adjourned: 11:35 AM

Prepared by: Wendy Rannenberg